

962672


Final Report

June 1972

PARAMETRIC STUDY OF THERMAL PROBLEMS IN DENSELY POPULATED SHELTERS

CONTRACT DAHC20-71-C-0290
DCPA Work Unit 1215D

Approved for public release; distribution unlimited.



Reproduced by
NATIONAL TECHNICAL
INFORMATION SERVICE
U S Department of Commerce
Springfield VA 22151



STANFORD RESEARCH INSTITUTE
Menlo Park, California 94025 • U.S.A.

196

UNCLASSIFIED

Security Classification

DOCUMENT CONTROL DATA - R & D

(Security classification of title, body of abstract and indexing annotation must be entered when the overall report is classified)

1. ORIGINATING ACTIVITY (Corporate author) Stanford Research Institute 333 Ravenswood Avenue Menlo Park, California 94025		2a. REPORT SECURITY CLASSIFICATION Unclassified	
3. REPORT TITLE PARAMETRIC STUDY OF THERMAL PROBLEMS IN DENSELY POPULATED SHELTERS		2b. GROUP (Not applicable)	
4. DESCRIPTIVE NOTES (Type of report and inclusive dates) Final Report			
5. AUTHOR(S) (First name, middle initial, last name) Frank C. Allen			
6. REPORT DATE June 1972		7a. TOTAL NO. OF PAGES 102	7b. NO. OF REFS 68
8a. CONTRACT OR GRANT NO. DAHC20-71-C-0290		9a. ORIGINATOR'S REPORT NUMBER(S) None	
b. PROJECT NO. 1200		9b. OTHER REPORT NO(S) (Any other numbers that may be assigned this report) SRI Project URU-1218	
c. Task 1210			
d. DCPA Work Unit 1215D			
10. DISTRIBUTION STATEMENT Approved for Public Release; Distribution Unlimited.			
11. SUPPLEMENTARY NOTES		12. SPONSORING MILITARY ACTIVITY Defense Civil Preparedness Agency Washington, D.C. 20301	
13. ABSTRACT Thermal problems treated analytically in this report relate to transfer of metabolic heat from human bodies to a shelter environment and to some effects of population density on optimum clothing, skin wetness, limits for thermal equilibrium, and contributions made by each of six processes for heat/mass transfer. These processes include: radiation and convection at skin or clothing surfaces, heat conduction through clothing, respiratory heat exchange, vapor diffusion through dry skin, and evaporation of sweat at wet skin surfaces. Thermal equilibrium is maintained in cool environments by modifying thermal resistance of clothing and in warm environments by adjusting the ratio of wet to total skin areas. Also, an analysis of moist-air mixing processes is used to evaluate operational requirements for partial recirculation of ventilating air during cold weather. Analyses and computations are based on correlated data from the scientific literature. Results are presented graphically in 9 figures and numerically in 18 tables.			

DD FORM 1473
1 NOV 65REPLACES DD FORM 1473, 1 JAN 64, WHICH IS
OBSOLETE FOR ARMY USE.

UNCLASSIFIED

Security Classification

Security Classification

14. KEY WORDS	LINK A		LINK B		LINK C	
	ROLE	WT	ROLE	WT	ROLE	WT
Shelters						
Survival						
Thermal environment						
Thermal problems						
Population density						
Environmental control						
Metabolic heat						
Thermal equilibrium						
Temperature						
Humidity						
Radiation						
Convection						
Evaporation						
Insensible weight loss						
Clothing						
Heat transfer						
Ventilation						
Air distribution						
Psychrometric process						
Partial recirculation						
Air mixing						
Cold weather						

SUMMARY

Introduction

The problems investigated in this study relate to the effects of population density on the transfer of metabolic heat and moisture from sedentary persons to the environment in shelters. Also, parameters associated with nonuniform (varistate) environments and partial recirculation of ventilating air during cool or cold seasons are evaluated.

Metabolic Heat Transfer

To maintain deep-tissue and skin-surface temperatures within ranges compatible with acceptable levels of comfort, the human body must reject heat to the environment by one or more physical processes in accordance with equations for thermal equilibrium,

$$S = M - W - (R_s + C_s + C_r) - (E_w + E_d + E_r) = 0$$

in which quantities are energy rates, as follows:

S = heat storage (positive if mean body temperature tends to increase)

M = metabolic energy expenditure (100 kcal/hr for a sedentary person having a skin surface area of 2 square meters)

W = external work performed (zero for sedentary persons)

R_s = heat transfer by radiation at exposed surfaces of skin or clothing

C_s = heat transfer by convection at exposed surfaces of skin or clothing

C_r = heat associated with change in temperature of respired air

E_w = heat transfer by evaporation of sweat at wet skin areas

E_d = heat transfer by diffusion of water vapor through dry skin areas

E_r = heat of vaporization associated with moisture added to respired air.

The components of sensible heat, $(R_s + C_s + C_r)$, and latent heat, $(E_w + E_d + E_r)$, are positive if the process tends to cool the body.

Each of the heat transfer processes has been evaluated, together with appropriate coefficients, by reference to scientific literature, and the results are used to synthesize a program for computing metabolic parameters under selected conditions. The program is based on maintenance of model skin temperatures under all combinations of conditions for which thermal equilibrium is possible by varying either the insulating value of clothing or the evaporative cooling effect associated with sweat gland activity. The threshold for regulatory secretion of sweat corresponds to the temperature at which the required insulating value of clothing is just zero. At higher temperatures, sweat rates and skin wetness are increased to develop the required evaporative cooling effect. A limit for thermal equilibrium is reached when either the skin is completely wet or a maximum sweat rate is attained. Within an air temperature range of 10°C (50°F) to 52°C (125.6°F), model skin temperatures for sedentary persons vary from 32°C (89.6°F), at which skin is typically dry, to 36°C (96.8°F), at which skin may be completely wet in a humid environment.

Computed values of metabolic data relating to sedentary persons are tabulated in the report for the nine combinations of conditions listed in Table S-1. For each of nine values of air temperature and three values of relative humidity, the numerical tables include the following items of metabolic data:

- Saturated vapor pressure at mean skin temperature
- Latent heat transfer
- Sensible heat transfer
- Heat storage
- Heat transfer by radiation at exposed surfaces
- Heat transfer by convection at exposed surfaces
- Sensible heat transfer associated with respiration
- Latent heat transfer associated with respiration
- Latent heat transfer by vapor diffusion through dry skin
- Latent heat transfer by evaporation at wet skin areas
- Partial pressure of water vapor in the environment
- Thermal resistance of clothing needed for thermal equilibrium in cool environment
- Ratio of wet to total skin areas

TABLE S-1
DATA FOR NUMERICAL TABLES OF METABOLIC PARAMETERS

TABLE NUMBER	A-2	A-3	A-4	A-5	A-6	A-7	A-8	A-9	A-10
SKIN TEMPERATURE, T ₃ , AT AIR TEMPERATURE, T, (CELSIUS) T ₃ =34 T ₃ =34+1.5*ATN(0.1967*(T-31))	X	X	X	X	X	X	X	X	X
ATTENUATION FACTOR, F ₃ , FOR VAPOR DIFFUSION THROUGH CLOTHED SKIN AREAS F ₃ =1.0 F ₃ =1/(1+0.1*K ₂) F ₃ =1/(1+0.2*K ₂)	X	X	X	X	X	X	X	X	X
MEAN RADIANT TEMPERATURE, T ₁ , IN OCCUPIED SPACE (CELSIUS) T ₁ =T T ₁ =T ₃ OR T ₁ =T ₂ T ₁ =(T ₃ +T)/2 OR T ₁ =(T ₂ +T)/2	X	X	X	X	X	X	X	X	X
CONVECTION COEFFICIENT, H ₁ , FOR EXPOSED SKIN OR CLOTHING KCAL/(HR*SQ M*°C)	4.0	4.0	4.0	3.4	5.0	7.0	4.0	4.0	4.0
EVAPORATION COEFFICIENT, E ₁ , FOR WET SKIN AREAS KCAL/(HR*SQ M*MMHG)	8.0	8.0	8.0	6.8	10.0	14.0	8.0	8.0	8.0
RELATIVE AIR VELOCITY, V ₁ CENTIMETERS/SECOND FEET/MINUTE	15 30	15 30	15 30	10 20	23 45	45 90	15 30	15 30	15 30

T₃=SKIN TEMPERATURE, T₂=CLOTHING TEMPERATURE, T=AIR TEMPERATURE (CELSIUS)
K₂=THERMAL RESISTANCE OF CLOTHING (CLO UNITS)

- Temperature gradient through clothing.

Relationships among metabolic parameters are illustrated graphically in the report by Figures 4, 5, and 6, which are based on conditions shown for Tables A-3 and A-4 in Table S-1.

Effects of Population Density

If ventilating air is supplied to an unoccupied, insulated room through openings at one end and removed through openings at the opposite end, temperatures and longitudinal air velocities in the space should be virtually uniform, and the mean radiant temperature should be equal to the air temperature. The entry of people into this room would divert air to levels near the ceiling because people partially obstruct air flow near the floor level. If the population becomes dense and overhead clearance is relatively large, most of the air may flow through the overhead space. Air velocities near the floor may then approach the low values associated with natural convection, and coefficients for transfer of metabolic heat and moisture would be proportionately reduced. The increase in population density would also cause a change in mean radiant temperature to a value that is intermediate between mean wall surface temperature and the mean temperature of exposed skin or clothing surfaces. The magnitude of these effects is closely related to quantities that are evaluated in the study of metabolic parameters under the conditions listed in Table S-1. Tabulated values of relative air velocity include 20, 30, 45, and 90 feet per minute. Values are tabulated at an air velocity of 30 feet per minute with mean radiant temperatures that are:

- Equal to air temperature
- Equal to the temperature of exposed skin or clothing surfaces
- The mean of air temperature and the temperature of exposed skin or clothing.

Shelter Ventilation

When ventilating air is well distributed in accordance with the distribution of heat loads in an occupied space, the environment may approach spatial uniformity. On the other hand, if the ventilating air moves horizontally through the space from one boundary to an opposite boundary, environmental conditions will change gradually as metabolic heat and moisture are added along the air stream. The environmental temperature adjacent to the boundary along which air is supplied to the space will be essentially

the same as the supply air temperature. If the ventilating system supplies only atmospheric (outside) air to the space, shelter temperatures during wintertime may be warm at the end from which air is exhausted, but may be far below the prescribed minimum of 50°F near the end to which air is supplied. This study demonstrates that a minimum temperature of 50°F in the occupied space of a shelter that has insulated or massive walls can be maintained during very cold weather by partial recirculation of ventilating air, a mixing process that utilizes metabolic heat for tempering fresh air.

Ventilation process lines, each of which shows the locus of environmental states along a path of air flow, are determined on the basis of a pair of linear equations that approximate metabolic data derived in the section on Metabolic Parameters. These equations are:

$$\rho = 0.25 \text{ when } T \leq 82.5^{\circ}\text{F}$$

and

$$\rho = 0.06T - 4.7 \text{ when } T \geq 82.5^{\circ}\text{F}$$

where

ρ = ratio of latent to total metabolic heat

T = air temperature of local environment.

Several ventilation process lines, each of which approaches the value $T = 95^{\circ}\text{F}$ asymptotically, are shown graphically on Figure 7 in the report. This figure also includes isoventilation lines that relate the temperature of exhaust (or recirculated) air to ventilating rate, when fresh or mixed air is supplied to the occupied space at a temperature of 50°F.

A computer program that simulates the process for mixing fresh and recirculated air was developed on the basis of a nonuniform environment and used to evaluate parameters associated with the partial recirculation process when the mixed (supply) air temperature is 50°F and the fresh air temperature varies from +50°F to -50°F. The results are shown graphically on Figure S-1 and numerically in Appendix B of the report.

The effects of heat transmission through building elements on surface temperatures, interactions among metabolic parameters, partial recirculation of air, and the configuration of ventilating systems should be investigated in depth.




FIGURE S-1 VENTILATION OF AN OCCUPIED SPACE WITH MIXED FRESH AND RECIRCULATED AIR AT 50°F

ABSTRACT

The thermal problems considered in these studies are associated with the transfer of metabolic heat and moisture from the human body to a shelter environment and with the effects thereon of population density. The studies are also concerned with the requirements and rationale for partial recirculation of ventilating air in shelters during cool and cold weather.

An analytical model for thermal metabolism is developed and used to evaluate metabolic parameters under several conditions of shelter occupancy. This model includes the effects of six processes for transfer of metabolic heat: radiation at skin or clothing surfaces, convection at skin or clothing surfaces, heat conduction through clothing, respiratory heat exchange, vapor diffusion through dry skin, and evaporation of sweat from wet skin surfaces. Thermal equilibrium is maintained in cool environments by modifying the thermal resistance of clothing, and in warm environments by adjusting the ratio of wet to total skin surface, that is, the rate of evaporative cooling. The parameters are correlated graphically, and supplementary data are included in numerical tables.

Ventilation process lines for various environments are shown on a psychrometric chart, together with isoventilation lines for an initial or mixed air temperature of 50°F , as supplied to the shelter. Parameters associated with partial recirculation of air when ambient conditions are less than or equal to 50°F are compared graphically.

CONTENTS

SUMMARY

ABSTRACT	ii
LIST OF ILLUSTRATIONS.	v
LIST OF TABLES	vi
I INTRODUCTION.	1
II METABOLIC PARAMETERS.	3
Respiratory Heat Exchange	7
Volume and Mass of Inspired Air.	7
Properties of Respired Air	10
Diffusion of Moisture Through Dry Skin.	16
Evaporation of Sweat.	18
Convective Heat Exchange.	19
Radiative Heat Exchange	21
Heat Conduction Through Clothing.	22
Simultaneous Effects.	23
Graphic Comparison of Metabolic Data.	25
III SHELTER VENTILATION	31
Ventilation Process Lines	31
Seasonal Recirculation of Air	34
IV CONCLUSIONS AND RECOMMENDATIONS	40
Conclusions	40
Recommendations	46
REFERENCES	47
BIBLIOGRAPHY	53
APPENDICES	
A NUMERICAL TABULATION OF METABOLIC PARAMETERS	A-1
B TABULATED DATA RELATING TO PARTIAL RECIRCULATION OF AIR.	B-1

ILLUSTRATIONS

1	Basic Parameters Associated with Energy Metabolism.	6
2	Relationship of Pulmonary Ventilation to Energy Expenditure	8
3	Thermal Properties of Respired Air.	13
4	Characteristic Temperatures and Related Metabolic Param- eters for Sedentary Persons in Thermal Equilibrium.	27
5	Transfer of Metabolic Heat to a Typical Environment from Sedentary Persons in Optimum Clothing	28
6	Components of Metabolic Heat Associated with Thermal Equilibrium for Sedentary Persons in Optimum Clothing	29
7	Process Lines for Ventilating a Space with Mixed Air at 50°F.	35
8	Ventilation of an Occupied Space with Mixed Fresh and Recirculated Air at 50°F.	39
9	Effects of Air Velocity and Mean Radiant Temperature on Metabolic Heat Transfer	44

TABLES

1	Properties of Respired Air.	15
A-1	Data for Numerical Tables of Metabolic Parameters	A-3
A-2	Metabolic Parameters, Set 1	A-4
A-3	Metabolic Parameters, Set 2	A-6
A-4	Metabolic Parameters, Set 3	A-8
A-5	Metabolic Parameters, Set 4	A-10
A-6	Metabolic Parameters, Set 5	A-12
A-7	Metabolic Parameters, Set 6	A-14
A-8	Metabolic Parameters, Set 7	A-16
A-9	Metabolic Parameters, Set 8	A-18
A-10	Metabolic Parameters, Set 9	A-20
A-11	Metabolic Heat Transfer--Program Listing.	A-22
B-1	Partial Recirculation of Ventilating Air: Mixed Air Temperature = 50°F, Fresh Air Temperature = 50°F.	B-2
B-2	Partial Recirculation of Ventilating Air: Mixed Air Temperature = 50°F, Fresh Air Temperature = 40°F.	B-3
B-3	Partial Recirculation of Ventilating Air: Mixed Air Temperature = 50°F, Fresh Air Temperature = 20°F.	B-4
B-4	Partial Recirculation of Ventilating Air: Mixed Air Temperature = 50°F, Fresh Air Temperature = 0°F	B-5
B-5	Partial Recirculation of Ventilating Air: Fixed Air Temperature = 50°F, Fresh Air Temperature = -20°F	B-6
B-6	Recirculation of Air--Program Listing	B-7

INTRODUCTION

If a shelter or other occupied space is to remain habitable, means must be provided for maintaining an environment that is capable of supporting essential metabolic processes. Thus, oxygen consumed must be replaced, excessive concentrations of carbon dioxide and other noxious constituents must not be allowed to develop, and the transfer of metabolic heat and moisture to the environment must be possible with near-normal body temperatures. In general, elementary control of a shelter environment can be accomplished most economically by ventilation with air from the surrounding atmosphere.

Per capita ventilating rates required to maintain an environment in which the effective temperature is equal to or less than a stated value during at least a stated percentage of the hours in an average year have been determined for shelters in various climatic locations.^{1*} Criteria based on these determinations have been promulgated for application to shelters;² these criteria specify that effective temperatures in occupied shelters shall be 82° FET or less during at least 90 percent of the days in an average year. It is further specified that the minimum temperature in a shelter environment shall not be less than 50°F. Capacities of ventilation systems determined under these criteria vary from 5 SCFM per person in Alaska to 40 SCFM per person along part of the Gulf coast of Texas.[†] These criteria are based on analyses in which the environment is assumed to be spatially uniform. Air entering an occupied space is

* References are listed at the end of the report

† The unit SCFM refers to standard cubic feet per minute, that is, air having a dry density of 0.075 lb/ft³.

assumed to mix completely and instantaneously with air in the space. The shelter structure is assumed to be perfectly insulated or "adiabatic."

Assumption of a uniform environment is consistent with air conditioning practice, in which air is usually well distributed within occupied spaces by a system of ducts and diffusion outlets. A more realistic assumption for the case of shelters would be that air will not be distributed in proportion to heat loads, but that heat and moisture will be added gradually to air stream as it passes through occupied spaces--in particular, through large, densely-populated spaces. Some effects of this gradual addition of heat and moisture to ventilating air have been demonstrated experimentally in the monoman calorimeter,³ and analytically in a study of ventilating and mixing processes in shelters.⁴

Studies documented herein are concerned with the reciprocal effects of population density in a shelter on the thermal environment and the physical processes for transfer of metabolic heat from the human body to its surroundings. The studies include the derivation of a set of quantitative requirements for seasonal recirculation of ventilating air in shelters. Problems associated with population density stem from the facts that human bodies obstruct the normal flow of ventilating air and change the mean radiant temperature within an occupied space. These effects usually interfere to some degree with transfer of metabolic heat and therefore tend to modify the effective temperature or other index of environmental habitability. A meaningful study of these problems can only be made in conjunction with an evaluation of all significant physical processes for transfer of metabolic heat and moisture and the physiological reactions that can control these processes. The usual partition of metabolic heat into sensible and latent fractions is not sufficient for the purpose. A major effort has therefore been devoted to development of an analytical model for metabolic interactions with the environment.

II METABOLIC PARAMETERS

Seasonal and spatial variations in temperature may be relatively large if an occupied shelter is ventilated with outside air and no apparatus is provided for supplementary heating or cooling. Temperatures in occupied spaces may rise to 100°F or more during warm seasons or fall to 50°F or less during cold seasons. To maintain a tolerable degree of comfort throughout this wide range of environmental conditions, clothing that is adapted to the prevailing condition must be worn. Thus, heavy or multilayered clothing would be optimum when the temperature is 50°F, and light (or no) clothing would be optimum during hot weather. This situation is not adequately represented by metabolic data for nude and clothed persons in technical literature in which the term "clothed" implies clothing that is suited to normal room temperatures. Thus, at lower temperatures, the data include either a large storage component or a high metabolic rate to obtain a heat balance. Moreover, published data evaluate only the sensible and latent components of metabolic heat. Such data do not provide information on the relative contributions made to thermal equilibrium by radiation, convection, and the several modes of evaporation.

For almost 50 years, the effective temperature index (ET) has served as a means for evaluating habitability of an environment.⁵ This index, which considers the effects of temperature, humidity, and air motion, was determined empirically from subjective responses of persons during short exposures in test environments. In 1947, Yaglou suggested that mean skin temperature could be used as an index of comfort.⁶ Since that time there has been a continuing effort to devise a comprehensive index of comfort based on measurable physiological quantities. This

effort has led to a better understanding of processes and control mechanisms for transfer of metabolic heat and moisture, and has resulted in the development of several methods for evaluating environments with regard to human comfort.⁷⁻¹⁴ Recent investigators have defined rational relationships for the diffusion of water vapor through dry skin, a process that has been controversial since Sanctorius first measured weight loss associated with insensible perspiration in the seventeenth century.¹¹⁻¹⁵ Evaluation of this diffusion process and the process for latent heat transfer in the respiratory tract are of special interest in connection with the present study because these phenomena should be sensitive to changes in environmental humidity. Earlier sources of metabolic data have indicated that humidity has no significant effect on the partition of metabolic heat.^{9,16-18}


For the purposes of this study, empirical expressions that define six processes for transfer of metabolic heat and moisture are evaluated by reference to technical and scientific literature to establish a reasonable level of confidence in the results. These expressions are then used to synthesize a computer program for calculation of combined effects and resultant parameters. The six contributory processes are as follows:

- Heat and moisture transfer in the respiratory tract
- Vapor diffusion through dry skin surface
- Evaporation of sweat from wet skin surfaces
- Convection from exposed surfaces of skin or clothing
- Radiation from exposed surfaces of skin or clothing
- Heat conduction through clothing.

Insofar as possible, data from original sources are interpreted and reduced to a common denominator in accordance with definitions and procedures outlined in recent biological handbooks.¹⁹⁻²⁰

Most of the available data on energy expenditure, work capacity, and pulmonary ventilation is based on indirect calorimetry; that is, metabolic rates are deduced from measurements of breathing volume, temperature, pressure and changes in oxygen and carbon dioxide concentration during respiration. A value of 4.825 kilogram calories per liter of oxygen consumed is often used for this purpose.¹⁹ However, the true energy equivalent for oxygen varies with the respiratory quotient (RQ), which is the volumetric ratio of carbon dioxide produced to oxygen consumed. The normal range of variation for this energy/oxygen equivalent can be illustrated by constructing a triaxial graph based on a set of linear equations derived by MacHattie.^{21,22} This graph, which is shown in Figure 1, has three coordinate scales to represent the composition of a mixture of metabolized nutrients; that is, percentages of typical carbohydrates, fats, and proteins. Curves for other parameters are superimposed on this triaxial grid and are identified in Figure 1. According to Weir,²³ an average diet will result in metabolism of 10 to 15 percent of proteins with an RQ of about 83 percent. The energy equivalent for oxygen, K, would then be slightly more than 4.8 kilogram calories per liter of oxygen, STPD.* Under STPD conditions, oxygen has a density of 1.4277 grams per liter, or 0.08915 pounds per cubic foot.²⁴ The parameters evaluated in Figure 1 are typical for normal subjects engaged in sedentary activities, but may not be representative for persons having metabolic disorders (such as diabetes) or persons engaged in strenuous activities. Severe exercise and the onset of muscular

* The abbreviation STPD refers to the standard volume of a gas measured in the dry state at a pressure of one atmosphere and a temperature 0°C. Breathing volumes are usually measured in the expired ATPS state, but reported in the BTPS state. ATPS refers to a volume of air in the saturated state at ambient temperature and pressure; BTPS refers to a volume of air in the saturated state at normal body temperature and ambient atmospheric pressure.



C, F and P are, respectively, the percentages of carbohydrate, fat and protein metabolized in a mixture of these fuels
H is caloric value of the metabolized mixture (kcal/gram).
W is quantity of metabolic water produced (grams/kcal).
Based on data from Reference 21.

FIGURE 1 BASIC PARAMETERS ASSOCIATED WITH ENERGY METABOLISM

fatigue are characteristically accompanied by the formation of blood lactates and an RQ greater than unity.²⁵ With regard to the storage of drinking water in shelters, it is interesting to note that the metabolic process produces about 0.12 grams of water per kilogram calorie of energy expenditure. For a man having an average metabolic rate of 75 kcal/hr, this is about 0.48 lb/day or 0.057 gal/day.

Respiratory Heat Exchange

Volume and Mass of Inspired Air

Respiratory heat exchange includes a sensible heat fraction (identified with the difference between the temperatures of inspired and expired air) and a latent heat fraction (associated with the change in moisture content of respired air). The magnitude of both effects is proportional to the rate of pulmonary ventilation, which in turn is proportional to the rate of energy expenditure or the oxygen consumption. Experimental data from nine sources are plotted in Figure 2. These data have been reduced to the STPD condition and converted from the expired to the inspired state, as necessary. A respiratory quotient of 85 percent was assumed in treating data that did not include values for this parameter.²³ For the purpose of evaluating respiratory heat exchange, an equation that relates the inspired mass of dry air to the metabolic rate will be convenient.

In Figure 2, Curve A (dashed) represents data from a series of tests reported in 1912 by Douglas and Haldane in which one subject (Douglas) walked in the laboratory and on grass at speeds of 2 to 5 miles per hour.²⁶ Curve B (short lines) represents average values from basal metabolism tests made by Boyer and Bailey of 500 normal subjects.²⁷ Curves C and D (solid lines) represent data from Asmussen and Nielsen for activities in which arm action (Curve C) or leg action (Curve D) is predominant.²⁸ The increased pulmonary ventilation associated with arm




FIGURE 2 RELATIONSHIP OF PULMONARY VENTILATION TO ENERGY EXPENDITURE

motion is ascribed to mechanical manipulation of the rib cage. Curves E and F (dashed lines) represent data from Liddell for mining tasks that involve arm action (Curve E) and walking tasks (Curve F).²⁹ Curves G, H, J, and K (broken lines) represent data from Hermansen and Saltin.³⁰ Curves G and H are for trained athletes exercising on a bicycle ergometer (Curve G) or a treadmill (Curve H). Curves J and K are for untrained students exercising on a bicycle ergometer (Curve J) or a treadmill (Curve K). The trained athletes can extract more oxygen from a given quantity of air. Curve L (heavy dots) represents a series of tests for one subject exercising on a bicycle ergometer, first in the normal upright position and then while seated in an easy chair in a reclining position.^{31,32} The results in these two positions were virtually identical. Curve M is the lower boundary of plotted data from 611 tests with 86 subjects, as reported by 11 investigators.³³ These tests involved walking, running and bicycling. The upper boundary of the data would interfere with identity of curves C, J, and F. Lines through the origin and the diamonds, N and P, would represent values of 2.0 and 3.0 for the "ventilatory equivalent for oxygen." This quantity can be defined numerically as the number of liters of air expired in the BTPS state for each 100 cubic centimeters of oxygen used in the STPD state.¹⁹ In general, the ventilatory equivalent for oxygen associated with healthy persons engaged in normal activities will remain within the range of 2 to 3.³⁴ According to Knipping and Moncrieff,³⁴ lower values are characteristic for sleeping persons, and higher values may be associated with nervous tension or with the presence of such health disorders as heart disease, diabetes, anemia, and tuberculosis.

On the basis of data in Figure 2, a reasonable approximation for the mass of dry air inspired by people in shelters is

$$G = 0.006M \quad (1)$$

where

G = mass of dry air inspired (kilograms/hr)

M = metabolic rate (kilogram calories/hr).

If the subjects are athletes and the activity involves little or no arm motion, $G = 0.005M$ may be a better approximation. Equation (1) is used in subsequent computations relating to respiratory heat losses and shelter ventilation. The mass velocity of dry air inspired by a sedentary individual having a metabolic rate of 100 kcal/hr (397 Btu/hr) is therefore 0.60 kg/hr (1.32 lb/hr).

Properties of Respired Air

To evaluate the contribution made by respiration in the transfer of metabolic heat and moisture, a logical relationship between the properties of inspired and expired air must be deduced from the mass of literature relating to insensible weight loss or insensible perspiration. Insensible weight loss includes the moisture loss by diffusion through dry skin, the moisture added to respired air, and the differential mass associated with oxygen uptake and carbon dioxide rejection. For the purposes of this study, the experimental data and supporting information developed by Cole are most useful.³⁵⁻³⁸ Cole's data were obtained with subjects breathing either dried air or air saturated with moisture at temperatures of -30°C to $+50^{\circ}\text{C}$. On the basis of his investigations, Cole derived several conclusions that are pertinent to this study, as follows:

- Saturated air inspired at body temperature (37°C) is expired in the same condition.
- Air in the lungs is saturated with water vapor at body temperature.
- The upper respiratory tract serves as an efficient device for heat recovery. For example, during inspiration of cold air,

surfaces of the upper respiratory tract (nasal mucosa) are chilled. During expiration, these chilled surfaces are warmed by heat and moisture extracted from the expired air.

- The condition of expired air is independent of the rate of pulmonary ventilation.
- Within terrestrial limits, changes in altitude have little effect upon the condition of respiratory air.
- The body loses more heat and moisture during oral than during nasal breathing at room temperature.
- During nasal breathing, remote thermal stimuli can modify blood flow to nasal mucosa and raise or lower the temperature of inspired air in the pharynx and expired air at the anterior nares. A comparable effect is not exhibited during oral breathing. For example, during nasal breathing at room temperature, immersion of the feet in warm water at 45°C is accompanied by an increase of 2°C to 3°C in the temperature of expired air. Local heating (or cooling) of the dorsal region of the back is also accompanied by an increase (or decrease) in expired air temperature.

Cole's conclusions were generally confirmed by Ingelstedt.³⁹ The recovery of heat in the upper respiratory tract was well demonstrated by Seeley.⁴⁰ The temperatures of expired air indicated by Cole are in good agreement with values obtained by Seeley⁴⁰ and Webb,^{41,42} but are generally lower than data at moderate and high temperatures obtained by Burch^{43,44} and McCutchan and Taylor.⁴⁵ The experimental procedures of both Burch and McCutchan and Taylor were based on oral breathing, and the expired air was usually found to be less than saturated. In analyzing data on heat removed from the body by respiration, Burch included the effect of decomposition of carbonic acid. An analysis of heat exchange by Caldwell,

surfaces of the upper respiratory tract (nasal mucosa) are chilled. During expiration, these chilled surfaces are warmed by heat and moisture extracted from the expired air.

- The condition of expired air is independent of the rate of pulmonary ventilation.
- Within terrestrial limits, changes in altitude have little effect upon the condition of respiratory air.
- The body loses more heat and moisture during oral than during nasal breathing at room temperature.
- During nasal breathing, remote thermal stimuli can modify blood flow to nasal mucosa and raise or lower the temperature of inspired air in the pharynx and expired air at the anterior nares. A comparable effect is not exhibited during oral breathing. For example, during nasal breathing at room temperature, immersion of the feet in warm water at 45°C is accompanied by an increase of 2°C to 3°C in the temperature of expired air. Local heating (or cooling) of the dorsal region of the back is also accompanied by an increase (or decrease) in expired air temperature.

Cole's conclusions were generally confirmed by Ingelstedt.³⁹ The recovery of heat in the upper respiratory tract was well demonstrated by Seeley.⁴⁰ The temperatures of expired air indicated by Cole are in good agreement with values obtained by Seeley⁴⁰ and Webb,^{41,42} but are generally lower than data at moderate and high temperatures obtained by Burch^{43,44} and McCutchan and Taylor.⁴⁵ The experimental procedures of both Burch and McCutchan and Taylor were based on oral breathing, and the expired air was usually found to be less than saturated. In analyzing data on heat removed from the body by respiration, Burch included the effect of decomposition of carbonic acid. An analysis of heat exchange by Caldwell,

Gomez, and Fritts⁴⁶ shows that this endothermic reaction is counteracted by an exothermic effect arising from the combination of oxygen with blood.

Figure 3 shows a model for respiratory parameters associated with a wide range of environmental conditions. Within the range of inspired air temperatures extending from -30°C to $+50^{\circ}\text{C}$, the solid lines labeled 0% and 100% are a good representation for Cole's data.³⁶ The curves are extrapolated below and above this range. It is assumed that expired air temperatures associated with inspired air having relative humidities between 0 and 100 percent can be determined by linear interpolation. Therefore, in accordance with Cole's postulate that expired air is virtually saturated, the two solid curves on Figure 3 completely define the condition of expired air associated with any given condition of inspired air within these wide limits. With reference to Figure 3, the equation for expired air temperature is

$$T_e = U_o + \phi_i U/100, \quad (2)$$

where

T_e = expired air temperature ($^{\circ}\text{C}$)

ϕ_i = relative humidity of inspired air (percent)

U_o = expired air temperature when $\phi_i = 0\%$ ($^{\circ}\text{C}$)

$U = U_s - U_o$ = the maximum difference in expired air temperatures associated with humidity of inspired air ($^{\circ}\text{C}$)

U_s = expired air temperature when $\phi_i = 100\%$ ($^{\circ}\text{C}$).

The lower curve is a linear function of T_i , the temperature of inspired air,

$$U_o = 28 + 0.1 T_i \quad (3)$$




FIGURE 3 THERMAL PROPERTIES OF RESPIRED AIR

and the temperature difference, U , is an exponential function of T_i ,

$$U = \exp(0.040819T_i + 0.0001325T_i^2 - 0.0000000128T_i^4) \quad (4)$$

The numerical coefficients in Eq.(4) were determined by the following criteria:

- $T_e = 29^\circ\text{C}$ when $T_i = 0^\circ\text{C}$.
- $T_e = 37^\circ\text{C}$ when $T_i = 37^\circ\text{C}$.
- $T_e = 100^\circ\text{C}$ when $T_i = 100^\circ\text{C}$.
- $dT_e/dT_i = 1$ when $T_i = 100^\circ\text{C}$.

The first two criteria are salient data points that in themselves determine an exponential equation, $U = e^{0.045073T_i}$, which suggests that

$$T_e > T_i \text{ when } T_i > 87^\circ\text{C}.$$

The third and fourth criteria merge the two temperatures at 100°C and avoid this apparent incongruity.

Values of respiratory parameters based on Eq. (2), (3), and (4) are shown in Table 1 for a pulmonary ventilation rate of one kilogram of inspired dry air per hour, which from Eq. (1) corresponds to a metabolic rate of about 167 kilogram calories per hour. Column 1 shows the relative humidity of inspired air, and Column 2 is the humidity ratio times 100. Each group of three relative humidities is identified with an inspired air temperature and a corresponding saturation pressure, PS. Column 3 is the humidity ratio of expired air times 100, and Column 4 is the temperature of expired air on the Celsius scale. Column 5 is the mass of moisture added to or extracted from the respired air in grams per hour. Column 6 is the latent heat of vaporization for moisture added or extracted, in kilogram calories per hour. Column 7 is the sensible heat associated with the temperature difference, $T_e - T_i$, in kilogram

TABLE 1

PROPERTIES OF RESPIRED AIR

INSPIRED AIR RH% W*100	EXPIRED AIR W*100	SATEMP	MOISTX GRM/HR	LATENT KCL/HR	SENSEX KCL/HR	EXPRES MMHG
INSPIRED AIR TEMP= -50.0 C, PS= +2.9514E-02 MMHG						
0 0.00000	1.78125	+23.00	+17.81	+10.34	+17.82	21.066
50 0.00121	1.79052	+23.08	+17.59	+10.38	+17.84	21.173
100 0.00243	1.79980	+23.17	+17.97	+10.43	+17.87	21.280
INSPIRED AIR TEMP= -40.0 C, PS= +9.6252E-02 MMHG						
0 0.00000	1.89535	+24.00	+18.95	+10.99	+15.64	22.375
50 0.00396	1.90911	+24.12	+19.05	+11.05	+15.67	22.533
100 0.00792	1.92296	+24.23	+19.15	+11.11	+15.70	22.692
INSPIRED AIR TEMP= -30.0 C, PS= +2.8488E-01 MMHG						
0 0.00000	2.01605	+25.00	+20.16	+11.69	+13.46	23.755
50 0.01172	2.03648	+25.16	+20.25	+11.74	+13.50	23.988
100 0.02344	2.05709	+25.33	+20.34	+11.79	+13.54	24.223
INSPIRED AIR TEMP= -20.0 C, PS= +7.7387E-01 MMHG						
0 0.00000	2.14368	+26.00	+21.44	+12.42	+11.27	25.209
50 0.03183	2.17439	+26.23	+21.43	+12.41	+11.33	25.557
100 0.06369	2.20552	+26.47	+21.42	+12.41	+11.39	25.911
INSPIRED AIR TEMP= -10.0 C, PS= +1.9480E+00 MMHG						
0 0.00000	2.27862	+27.00	+22.79	+13.20	+9.07	26.739
50 0.08016	2.32579	+27.34	+22.46	+13.01	+9.17	27.272
100 0.16053	2.37384	+27.67	+22.13	+12.82	+9.26	27.815
INSPIRED AIR TEMP= +0.0 C, PS= +4.5813E+00 MMHG						
0 0.00000	2.42126	+28.00	+24.21	+14.02	+6.87	28.349
50 0.18182	2.49560	+28.50	+23.07	+13.35	+7.01	29.186
100 0.37879	2.57202	+29.00	+21.93	+12.69	+7.15	30.044
INSPIRED AIR TEMP= +10.0 C, PS= +9.2049E+00 MMHG						
0 0.00000	2.57202	+29.00	+25.72	+14.88	+4.67	30.044
50 0.38058	2.69259	+29.76	+23.12	+13.37	+4.88	31.393
100 0.76585	2.81835	+30.52	+20.52	+11.87	+5.09	32.795
INSPIRED AIR TEMP= +20.0 C, PS= +1.7531E+01 MMHG						
0 0.00000	2.73131	+30.00	+27.31	+15.80	+2.46	31.826
50 0.72895	2.93270	+31.19	+22.04	+12.74	+2.78	34.066
100 1.47519	3.14767	+32.38	+16.72	+9.66	+3.10	36.441
INSPIRED AIR TEMP= +30.0 C, PS= +3.1826E+01 MMHG						
0 0.00000	2.89961	+31.00	+29.00	+16.76	+0.25	33.699
50 1.33631	3.24539	+32.90	+19.09	+11.03	+0.72	37.516
100 2.73131	3.62895	+34.79	+8.98	+5.18	+1.22	41.703
INSPIRED AIR TEMP= +37.0 C, PS= +4.7076E+01 MMHG						
0 0.00000	3.02304	+31.70	+30.23	+17.47	-1.31	35.066
50 1.99761	3.53557	+34.35	+15.38	+8.88	-0.67	40.688
100 4.12780	4.12780	+37.00	+0.00	+0.00	+0.00	47.076
INSPIRED AIR TEMP= +40.0 C, PS= +5.5338E+01 MMHG						
0 0.00000	3.07740	+32.00	+30.77	+17.78	-1.98	35.666
50 2.36176	3.68623	+35.06	+13.24	+7.64	-1.25	42.324
100 4.90995	4.40563	+38.12	-5.04	-2.91	-0.49	50.033
INSPIRED AIR TEMP= +50.0 C, PS= +9.2554E+01 MMHG						
0 0.00000	3.26519	+33.00	+32.65	+18.86	-4.20	37.733
50 4.05564	4.36138	+37.95	+3.06	+1.76	-3.12	49.564
100 8.67709	5.79688	+42.90	-28.80	-16.55	-1.93	64.474
INSPIRED AIR TEMP= +60.0 C, PS= +1.4946E+02 MMHG						
0 0.00000	3.46354	+34.00	+34.64	+19.99	-6.44	39.904
50 6.82673	5.47634	+41.90	-13.50	-7.76	-4.83	61.200
100 15.33683	7.58126	+49.80	-67.56	-38.69	-2.98	91.657
INSPIRED AIR TEMP= +70.0 C, PS= +2.3379E+02 MMHG						
0 0.00000	3.67300	+35.00	+36.73	+21.19	-8.69	42.181
50 11.38460	7.42856	+47.26	-39.56	-22.69	-6.39	80.669
100 27.87069	14.91301	+59.51	-129.58	-73.86	-3.49	146.129
INSPIRED AIR TEMP= +80.0 C, PS= +3.5528E+02 MMHG						
0 0.00000	3.89420	+36.00	+38.94	+22.46	-10.94	44.570
50 19.10717	10.94783	+54.10	-81.59	-46.63	-7.90	113.123
100 55.15957	32.06338	+72.21	-230.96	-130.81	-3.34	257.014

calories per hour. Column 8 is the vapor pressure of saturated water vapor in expired air in millimeters of mercury. The values in Columns 5, 6 and 7 may be either positive or negative, and should be multiplied by 0.60 for a metabolic rate of 100 kcal/hr.

The range of inspired air temperatures in Figure 3 extends upward to 100°C (212°F). If the relative humidity is very low, air at this high temperature can be breathed without pain or injury;⁴⁵ in fact, whole body exposure in such an environment can be tolerated for a short time, as in a sauna bath.^{47,48} In saturated air, tolerance time for whole body exposure would be short at 40°C (104°F), and at dew point temperatures on the order of 50°C (122°F), condensation of hot water on the skin or nasal mucosa may be painful. Lind⁴⁹ found that respiratory discomfort was first apparent in saturated air at 39°C (102°F) in connection with mine rescue operations. Killick (quoted by Lind) had noted incipient discomfort at 54.5°C (130°F) for men at rest and 51.5°C (125°F) for men at work. Maldane noted that respiration in saturated air at 54.5°C (130°F) was slightly painful, at 48.9°C (120°F) work has hardly possible, and at 45°C (113°F) breathing was not difficult. On Figure 3, curve B (dashed line) is the locus of points having a dew point of 50°C (122°F). Therefore, curve B is essentially an upper limit for transient exposure during a fire in a hot confined environment. On Figure 3, the curve for $\phi_i = 100$ percent at inspired air temperatures higher than 50°C is needed for interpolation when the relative humidity of inspired air is less than 100 percent.

Diffusion of Moisture Through Dry Skin

A simple diffusion concept for the insensible loss of moisture through dry skin can be defined in terms of latent heat loss by the relationship,

$$H_d = K_d A_d (P_s - P_v), \quad (5)$$

where

H_d = metabolic heat dissipated in vaporization of diffusing moisture
(kcal/hour)

A_d = area of dry skin (m^2)

P_s = saturation pressure at skin temperature (mmHg)

P_v = partial pressure of water vapor in air (mmHg)

K_d = diffusion constant [$kcal/(hr.m^2.mmHg)$]

to obtain experimental data in which this relatively small effect is not obscured, sweat gland activity must be suppressed. This has been accomplished in several sets of experiments planned for the purpose by

- Performing tests at environmental temperatures in which active sweating does not occur⁵⁰⁻⁵²
- Using drugs (such as atropine) that inhibit sweating.^{53,54}
- Selecting subjects who do not have sweat glands.⁵⁵

When environmental temperatures are within the range of $21^{\circ}C$ to $28^{\circ}C$, with skin temperatures less than $34^{\circ}C$, the values of K_d in Eq. (5) are characteristically within the range of 0.2 to 0.5 [$kcal/(hr.m^2.mmHg)$].⁵⁰⁻⁵³

In general, the indicated values of K_d tend to increase with air or skin temperature, but higher values obtained at air temperatures above $29^{\circ}C$ or skin temperatures above $34^{\circ}C$ may reflect the effects of sweat gland activity.⁵¹⁻⁵³ The works of some investigators suggest a more complex relationship than that defined by Eq. (5).^{53,56,57}

For the purposes of this study, a value of 0.35 [$kcal/(hr.m^2.mmHg)$] is used for the diffusion constant, K_d , in Eq. (5). This is consistent

with the value used in some recent studies of human comfort.^{12,14} The diffusion of moisture through skin surfaces is essentially a mass transfer process that can be halted by an impervious covering. It is also quite apparent that the process can be attenuated by layers of clothing in proportion to the effective permeability of the skin clothing system.^{13,14} Some of the computations in the present study of metabolic parameters include an attenuation factor, F_e , the magnitude of which is inversely proportional to the insulating value of clothing,

$$F_e = \frac{1}{1 + 0.1 K_c} \quad (6)$$

where K_c is the thermal resistance of clothing in "clo" units. A clothing ensemble that has a resistance of 1 clo would have a surface-to-surface temperature difference of 0.18°C when conductive heat flux is $1 \text{ kcal}/(\text{hr} \cdot \text{m}^2)$.

Evaporation of Sweat

The production and evaporation of sweat is a metabolic process that is used under physiological control for maintaining thermal equilibrium in a warm environment. When evaporative cooling is needed, the control mechanism adjusts the wetted area of skin surfaces in accordance with the requirement.^{59,60} Under any given set of environmental conditions, this cooling effect attains a maximum value when skin surfaces become completely wet or when the maximum rate of sweat production is reached. The maximum sustained rate of sweat production for a "standard" man is about one liter per hour, and the potential cooling effect of this fluid is about 600 kcal/hr or 2400 Btu/hr .⁹ Metabolic requirements for lesser rates of evaporative cooling may be limited by vapor pressure differentials or relative velocities of air motion in the environment. The effect is defined by the equation

$$E_{\max} = h_e A_e (P_s - P_v) \quad (7)$$

where

E_{\max} = metabolic heat dissipated by evaporation of sweat when skin surfaces are completely wet.

A_e = effective area of skin surface (m^2)

P_s = saturation pressure at skin temperature (mmHg)

P_v = partial pressure of water vapor in air (mmHg)

h_e = evaporative heat transfer coefficient [$kcal/hr.m^2.mmHg$].

The evaporative heat transfer coefficient, h_e , and the convective heat transfer coefficient, h_c , are both sensitive to air velocity and can be correlated through the Lewis relation.⁶¹ In connection with metabolic heat/mass transfer

$$h_e \approx 2h_c \quad (8)$$

when the coefficients are expressed in units of [$kcal/(hr.m^2.mmHg)$] and [$kcal/(hr.m^2.^{\circ}C)$]. This relationship has been demonstrated by Woodcock⁶² and Brebner, Kerslake, and Waddell.^{63,64}

Convective Heat Exchange

The transfer of metabolic heat by convection can be determined by the equation,

$$H_c = h_c A_c (T_c - T_a) \quad (9)$$

where

H_c = heat transfer at exposed surfaces of skin or clothing (kcal/hr)

A_c = effective area of exposed skin or clothing surfaces (m^2)

T_c = mean temperature of exposed surfaces ($^{\circ}C$)

T_a = temperature of environmental air ($^{\circ}C$)

h_c = convection heat transfer coefficient [$kcal/hr.m^2.^{\circ}C$]

The convective heat transfer coefficient, h_c , is sensitive to variations in relative air velocity. For numerical computations in connection with this study, a basic value of $h_c = 4.0$ is assumed to be representative for sedentary persons in shelters. According to Fanger¹¹ and Winslow, Gagge, and Herrington,⁶⁵ this value is appropriate for a relative air velocity of about 15 cm/s or 30 ft/min. For purposes of comparison, other computations are made in which h_c is assigned values of 3.4, 5.0, and 7.0 $kcal/(hr.m^2.^{\circ}C)$. These supplementary values are associated respectively with relative air velocities of about 11, 23, and 45 cm/s or 21, 45 and 90 ft/min. The value of $h_c = 3.4 kcal/(hr.m^2.^{\circ}C)$ or $h_c = 0.7 Btu/(hr.ft^2.^{\circ}F)$ is the minimum value obtained with very low velocities of ventilating air in a monoman calorimeter in which radiant heat transfer is suppressed by a reflective interior surface.³ Spontaneous movements by the sedentary test subjects created sufficient relative motion to prevent the occurrence of lower values for the convection coefficient. The effective surface area for conductive heat transfer is

$$A_c = F_c A_s, \quad (10)$$

where

A_s = effective area of skin surface, i.e., the total skin surface excluding areas insulated by chair seats or backs (m^2)

F_c = the ratio of exposed surface areas for clothed and nude persons.

In this study the value of F_c is determined by the equation^{11,12}

$$F_c = 1 + 0.1 K_c \quad (11)$$

where K_c is the insulating value of clothing in clo units.

Radiative Heat Exchange

In this study the transfer of metabolic heat from skin or clothing surfaces to the environment is determined in accordance with the Stefan-Boltzmann law in preference to a linear approximation.^{66,67} This permits a more realistic comparison of relative effects over a wide range of temperatures. The fundamental equation is

$$H_r = A_r K_r (T_r^4 - T_w^4) \quad (12)$$

where

H_r = heat transfer by radiation to or from exposed surfaces of skin or clothing (kcal/hr)

A_r = effective area of exposed skin or clothing surfaces (m^2)

T_r = mean absolute temperature of exposed skin or clothing surfaces ($^{\circ}K$)

T_w = mean radiant temperature of walls, furnishings and other surfaces "seen" by the subject, including other people ($^{\circ}K$)

K_r = the product of thermal emissivity of exposed skin and clothing surfaces (ϵ) and the Stefan-Boltzmann constant (σ).

The effective area, A_r , of skin and clothing surfaces for heat transfer by radiation is influenced by posture and is appreciably less than the aggregate area of skin or clothing surfaces.^{67,68} Thus,

$$A_r = F_r A_c \quad (13)$$

where A_c is defined by Eq. (10) and F_r is a dimensionless correction factor. In the present study, computations relating to the transfer of metabolic heat by radiation will be based on the values, $F_r = 0.65$, which is appropriate for an individual in a seated position,^{11,67,68} and $K_r = 4.8 \times 10^{-8} \text{ kcal}/(\text{hr} \cdot \text{m}^2 \cdot ^\circ\text{C}^4)$, which implies an effective emissivity of about 98 percent.^{11,24} To simulate the effects of a densely populated space, computations will include several values for T_w , the mean radiant temperature of the environment ($^\circ\text{K}$), as follows:

- $T_w = T_a + 273$
- $T_w = T_s + 273$
- $T_w = (T_s + T_a)/2 + 273$

where T_a and T_s are the air and mean skin temperatures ($^\circ\text{C}$), respectively.

Heat Conduction Through Clothing

The sensible heat conducted through clothing corresponds to that transferred to the environment by convection and radiation at exposed surfaces. The fundamental equation is

$$H_o = A_o (T_s - T_o) / (0.18K_c)$$

where

H_o = heat flux through clothing (kcal/hour)

A_o = skin surface area excluding parts insulated by contact with
furnishing (m^2)

T_s = mean skin temperature ($^\circ\text{C}$)

T_o = mean temperature of exposed clothing surfaces ($^\circ\text{C}$)

K_c = thermal resistance of clothing (clo units).

In this study, the thermal resistance of clothing, K_c , is an independent variable used to maintain thermal equilibrium at environmental temperatures below the threshold for sweating or evaporative regulation. Evaporative regulation is reserved for persons who are virtually nude.

Simultaneous Effects

The results of this study of relationships among metabolic parameters were obtained with a computer program in which the effects of the component processes for heat transfer are combined to interact and to proceed simultaneously. The program was synthesized under the following criteria:

- People in the shelter space are engaged in sedentary activities and are in thermal equilibrium with the prevailing environment.
- When environmental conditions of temperature and humidity are above the threshold at which the evaporation of sweat becomes necessary for maintaining thermal equilibrium, the people are virtually nude. Below this threshold, thermal equilibrium is maintained by adding increments of clothing, as necessary. Below this threshold, transfer of metabolic moisture is associated with the mechanisms of respiration and diffusion through dry skin, but not with sweat gland activity.
- At any air temperature, T_a °C, the mean skin temperature, T_s °C, is defined by the equation

$$T_s = 34 + 1.5 \arctan[0.1967(T_a - 31)]. \quad (15)$$

Skin temperatures determined with Eq. (15) are shown by the curve at the top of Figure 4. Several skin temperatures are 89.6°F, 91.4°F, 93.2°F, 95.0°F and 96.8°F when air temperatures are, respectively, 50.0°F, 80.6°F, 87.8°F, 95.0°F and 125.6°F.

The objective in using a curve of the shape defined by Eq. (15) is to simulate a well-defined transition between the zone of cool environments, in which thermal equilibrium is maintained by variations in clothing insulation, and the zone of warm environments, in which thermal equilibrium is maintained by production and evaporation of sweat.

- At any environmental state there are two rates of latent heat transfer that are associated with active sweating. One, E_{req} , is the rate of evaporative cooling required to maintain thermal equilibrium. The other, E_{max} , is the maximum rate of evaporative cooling that can be attained in the environment when the skin is completely wet, as defined by Eq. (7). The skin wetness is here defined as the ratio,

$$R_w = \frac{E_{req}}{E_{max}} \quad (16)$$

where the quantities E_{req} and E_{max} include the evaporation of sweat, but do not include vapor diffused through dry skin nor moisture transferred in the respiratory tract. However, moisture continues to diffuse through any dry portion of skin surface in accordance with Eq. (5). Heat storage and a consequent rise in body temperature would occur only when $E_{req} > E_{max}$, and the rate of heat storage is then

$$S = E_{max} - E_{req} \text{ kcal/hr} \quad (17)$$

The condition, $E_{req} = E_{max}$ determines a limiting environmental state for which the "relative strain index" is unity.⁸

Graphic Comparison of Metabolic Data

Computations needed for the graphic comparison of data relating to each of the contributing processes for metabolic heat transfer are based on the following set of physical and physiological parameters:

Barometric pressure	= 1.0 atmosphere
Body temperature	= 37°C
Metabolic rate, M	= 100 kcal/hr
External work	= 0
Skin surface (DuBois correlation)	= 2.0 m ²
Effective skin surface, A _s	= 1.9 m ²
Radiation area of nude skin, A _r	= 1.3 m ²
Radiation coefficient, K _r	= 4.8 × 10 ⁻⁸ (invariant)
Convection coefficient, h _c	= 4.0 kcal/(hr.m ² .°C)
Evaporation coefficient, h _e	= 8.0 kcal/(hr.m ² .mmHg)
Pulmonary ventilation, G	= 0.60 kg of dry air inspired per hour.

Results of the computations are presented in Figures 4 through 6. All computed data are shown as functions of air and wall temperature over the range of 0°C to 80°C. All data that are plotted as solid or dashed lines or curves are based on values of moisture diffusion through dry skin that are not attenuated by clothing. In addition, each figure shows two or more rows of prominent dots that indicate the effect of attenuating this diffusion process by the factor, F_e, as defined by Eq. (6). There is no attenuating effect when the thermal resistance of clothing is 0 clo units.

Skin and clothing temperatures, surface-to-air temperature differences, required insulating values for clothing, and ratios of wet to total skin areas are shown in Figure 4. In the cool zone, the temperature gradient from exposed clothing surfaces to the surrounding air is relatively small and does not change very much with air temperature. The effects of extreme changes in relative humidity are not very important. The thermal resistance of clothing required at 10°C (50°F), the minimum temperature for a shelter environment, is about 3 clo units.

In the warm zone, skin-to-air temperature differences increase rapidly with temperature but are unaffected by changes in relative humidity. However, the ratio of wet to total skin surface is very sensitive to changes in relative humidity. When this ratio becomes 1.0, no further increase in the rate of evaporative cooling is possible.

The sensible/total and latent/total metabolic heat ratios are evaluated in Figure 5. The effect of changes in relative humidity on the heat ratios at air temperatures of about 25°C is significant. The postulated effect of clothing on the diffusion of vapor through dry skin is also significant. This attenuating effect is indicated by the rows of dots in the lower left corner. These dots relate to the adjacent curves for 0 to 100 percent relative humidity.

In connection with warm environments, the broken lines determine values for the latent/total metabolic heat ratio when the required rate of evaporative cooling is greater than the maximum attainable (that is, thermal equilibrium is not possible and an increase in body temperature is inevitable). The broken lines and the solid lines intersect at state points where $E_{\text{req}} = E_{\text{max}}$ and skin surfaces are completely wet.

Contributions made by six heat transfer processes to maintenance of thermal equilibrium are evaluated in Figure 6 for three values of relative humidity--0, 50 and 100 percent. Heat transfer rates are expressed on




FIGURE 4 CHARACTERISTIC TEMPERATURES AND RELATED METABOLIC PARAMETERS FOR SEDENTARY PERSONS IN THERMAL EQUILIBRIUM




FIGURE 5 TRANSFER OF METABOLIC HEAT TO A TYPICAL ENVIRONMENT FROM SEDENTARY PERSONS IN OPTIMUM CLOTHING

EFFECTS ASSOCIATED WITH CURVES
 SR = Radiation at exposed surfaces
 SC = Convection at exposed surfaces
 ST = Respiratory temperature change
 LV = Respiratory moisture loss
 LD = Vapor diffusion through skin
 LE = Evaporation of sweat

Air velocity, $v \approx 0.15$ m/s (30 fpm)

Broken lines denote negative gradient, with air warmer than skin surface. Curves end at limiting condition for thermal equilibrium.




FIGURE 6 COMPONENTS OF METABOLIC HEAT ASSOCIATED WITH THERMAL EQUILIBRIUM FOR SEDENTARY PERSONS IN OPTIMUM CLOTHING

a logarithmic scale of percentages of metabolic rate as functions of air and wall temperatures. Each curve is identified by a symbol in accordance with explanatory notes. The curves terminate near the right side of each part of the figure at a state point for which $E_{req} = E_{max}$. This point is identified by an encircled dot. Radiative effects are less than convective effects in a cool environment, but are more than convective effects in a warm environment. For environments in which thermal equilibrium is maintained by optimum use of clothing, effects of this clothing in attenuating vapor diffusion through dry skin are indicated by rows of dots as in Figures 4 and 5.

Tables of numerical data relating to transfer of metabolic heat and moisture, the associated program listing, and explanatory notes are contained in Appendix A.

III SHELTER VENTILATION

Ventilation Process Lines

The metabolic data shown in Figure 5 suggest that the ratio of latent to total metabolic heat transfer can be adequately represented throughout the range of environmental conditions in which thermal equilibrium can be maintained by a constant and a linear equation,

$$o = 0.25 \quad (18)$$

when $T \leq 82.5^{\circ}\text{F}$, and

$$o = 0.06T - 4.7 \quad (19)$$

when $T \geq 82.5^{\circ}\text{F}$. In these expressions, o is dimensionless ratio of latent to total metabolic heat transfer and T is the environmental air temperature (Fahrenheit). In conjunction with equations for the thermodynamic properties of moist air and the following assumptions, these relationships determine equations for families of ventilation process lines:

- Ventilating air moves linearly through the occupied space, from one wall to an opposite wall.
- Metabolic heat and moisture are added gradually to air passing through the occupied space.
- There are no sources of heat or moisture other than metabolic effects. This implies that lighting loads and heat transmitted through walls and roof are relatively small and negligible.

When air temperatures are less than or equal to 82.5°F, equations for the family of ventilation process lines associated with Eq. (18) can be expressed as a function of specific enthalpy, H, and humidity ratio, W,

$$H - H_o = 4222 (W - W_o) \quad (20)$$

or as a function of humidity ratio, W, and air temperature, T,

$$\frac{0.5508 + W}{0.5508 + W_o} = \frac{7246 - T_o}{7246 - T} \quad (21)$$

When air temperatures are greater than or equal to 82.5°F, an equation for the family of process lines associated with Eq. (19) is

$$\frac{0.5508 + W}{0.5508 + W_o} = R_2 \left(\frac{R_3}{R_2} \right)^{0.006944}, \quad (22)$$

where

$$R_2 = \frac{2305 + T_o}{2305 + T}$$

$$R_3 = \frac{95 - T_o}{95 - T}.$$

In Eqs. (20), (21), and (22), T_o , W_o , and H_o are properties of moist air at any state point on a particular ventilation process line, and T, W, and H are properties of moist air at any other point on the same process line. Equations (20) and (21) are not valid when air temperatures are higher than 82.5°F, and Eq. (22) is not valid for temperatures lower than 82.5°F. The equations are not valid when the air is supersaturated. The units in these equations are

- Temperature, T (°F)

- Humidity ratio, $W = \frac{\text{pounds of moisture}}{\text{pounds of dry air}}$
- Specific enthalpy, $H = \text{Btu/lb of dry air.}$

Equations (20), (21), and (22) determine the locus of state points (on a psychometric chart) that develop in sequence as a stream of ventilating air moves through an occupied space.

This study is particularly concerned with ventilating systems that conserve heat for tempering purposes by partial recirculation of air during cold weather. In such a system there are three salient points of interest:

- (1) The state of fresh air
- (2) The state of mixed air supplied to the space
- (3) The state of air that is either recirculated or exhausted to atmosphere.

To identify air properties associated with each of these points, the corresponding item numbers above are used as subscripts. Then, if a space is occupied by sedentary persons in thermal equilibrium with a metabolic rate of $M = 400 \text{ Btu/hour/person}$, the rate of air supply to the space must be

$$\begin{aligned} V_2 &= \frac{400}{4.5 (H_3 - H_2)} \\ &= 88.89 / (H_3 - H_2) \end{aligned} \quad (23)$$

where

$V_2 = \text{rate of ventilation (SCFM per person)}$

$H_3 = \text{specific enthalpy of air leaving the space (Btu/lb of dry air)}$

H_2 = specific enthalpy of air entering the space (Btu/lb of dry air).

The associated flow rate of fresh (outside) air is

$$V_1 = 88.89 / (H_2 - H_1) , \quad (24)$$

where

V_1 = flow rate of fresh air (SCFM/person)

H_1 = specific enthalpy of fresh air (Btu/lb of dry air).

Several ventilation process lines determined analytically by Eqs. (20), (21), and (22) are shown on Figure 7. These lines resemble process lines based on experiments performed by Pefley, Cull, and Sekins.³ The six lines that originate at a temperature of 50°F bracket the possible range of 0 to 100 percent relative humidity. Thus, these lines represent process lines associated with the prescribed criterion for a minimum temperature of 50°F in a shelter environment.² Across this group of six process lines are a number of heavier lines that terminate at dots. These are isoventilation lines, based on Eq. (23), with the proviso that air is supplied to the shelter space at a temperature of 50°F. Each isoventilation line is labeled with the associated ventilating rate. A curve at the top of the chart shows the locus of points above which thermal equilibrium cannot be maintained. This line was determined from data in Figures 4 and 5 at state points where $E_{req} = E_{max}$. Effective temperature lines for 80 ET and 85 ET are also shown.

Seasonal Recirculation of Air

If a shelter ventilating system of either the supply or exhaust type is so arranged that fresh air enters an occupied space through a few openings with little or no distribution, environmental temperatures in




FIGURE 7 PROCESS LINES FOR VENTILATING A SPACE WITH MIXED AIR AT 50°F

the vicinity of these openings will not differ greatly from the outside temperature. During cold weather, temperatures may frequently be less than 50°F over a large part of the shelter space. This stressful condition could be eliminated by tempering or heating the fresh air. If heating apparatus is not provided (or is inoperable), the cold areas can be reduced or eliminated by recirculating part of the ventilating air. Partial recirculation is often used in air conditioning practice to reduce heating or cooling loads.

On Figure 7, the dashed line connecting three encircled dots at $T_1 = 35^\circ\text{F}$, $T_2 = 50^\circ\text{F}$, and $T_3 \approx 89^\circ\text{F}$ illustrates the geometrical configuration associated with a recirculating system for ventilating an occupied space. The dashed line is straight because the oblique coordinates on this psychrometric chart are specific enthalpy, H , and humidity ratio, W ; the lines of constant temperature are not parallel. Basic properties of moist air at the three state points are T_1 , W_1 , and H_1 for the fresh air; T_2 , W_2 , and H_2 for the mixed air; and T_3 , W_3 , and H_3 for the recirculated air. Points 2 and 3 must be on the same ventilation process line. In accordance with the principle of conservation of mass and energy in a mixing process, the properties of moist air at the three state points are related by the equations,

$$\frac{H_3 - H_1}{W_3 - W_1} = \frac{H_2 - H_1}{W_2 - W_1} = \frac{H_3 - H_2}{W_3 - W_2} \quad (25)$$

and the ratio of flow rates for fresh and mixed air is

$$\frac{V_1}{V_2} = \frac{H_3 - H_2}{H_3 - H_1} = \frac{W_3 - W_2}{W_3 - W_1} \quad (26)$$

Equations (18) through (26), together with precise relationships among psychrometric quantities (saturation pressure, humidity ratio, specific enthalpy, and temperature), were used as the basis for an iterative

computer program that determines the required flow rate for fresh air and evaluates properties of moist air at state points for fresh, mixed, and recirculated air when the input parameters are as follows:

- Flow rate of mixed air, V_2 (SCFM/person). This corresponds to the rated unit capacity of the ventilating system.
- Temperature of mixed air, T_2 ($^{\circ}$ F).
- Temperature of fresh air, T_1 ($^{\circ}$ F).
- Relative humidity of fresh air, ϕ_1 (%).

The program rejects combinations of input data that would lead to recirculated air having a dew point in excess of 90° F, which is just above the limit for metabolic equilibrium, or to supersaturated mixed air. If these causes for rejection occur, the program determines the minimum ventilating capacity that would satisfy these requirements.

Figure 8 is constructed with data calculated using the above program. This chart evaluates parameters associated with a recirculating system for ventilating a shelter with mixed air at a temperature $T_2 = 50^{\circ}$ F, when the fresh air temperature, T_1 , is less than or equal to 50° F. Since the prescribed minimum temperature for a shelter environment is 50° F, Figure 8 determines limiting parameters for design or operation of such systems. For example: If the unit capacity of a ventilating system is 12 SCFM per person, and the outside air temperature is 20° F, the temperature of recirculated air will be 72.6° F, the flow rate of fresh air should be 5.2 SCFM per person, and the humidity ratio of air leaving the shelter space will be higher than the humidity ratio of fresh air by about 0.004 pounds of moisture per pound of dry air.

On Figure 8, the blank area labeled "Fog" denotes conditions under which the mixed air would be supersaturated, if the fresh air were dry.

The boundaries of this fog region if the fresh air were saturated are indicated by two short dashed curves. The lower dashed curve and the adjacent solid line indicate ventilating rates below which the dew point of recirculated air would be more than 90°F and an increase in body temperatures should be expected.

Tables of numerical data relating to partial recirculation of ventilating air, the associated program listing, and explanatory notes are contained in Appendix B.




FIGURE 8 VENTILATION OF AN OCCUPIED SPACE WITH MIXED FRESH AND RECIRCULATED AIR AT 50°F

IV CONCLUSIONS AND RECOMMENDATIONS

Conclusions

Among elements that collectively determine the condition and variabilities of the environment in a ventilated shelter are several major factors:

- Prevailing ambient conditions with respect to air temperature and humidity.
- Size, shape, and compartmentation of the space, and furnishings provided therein.
- Utilization of the space with respect to number of people and duration of occupancy.
- Metabolic responses of each person to his local macroclimate with regard to physical activity and transfer of heat and moisture.
- Lighting and other internal heat sources supplementary to metabolic effects.
- Thermal characteristics of the structure with respect to transient and steady-state heat transfer.
- Per capita and total capacities of the ventilating system.
- Configuration of the ventilating system.

If a shelter were densely populated, the transfer of metabolic heat and moisture would be modified by the proximity of one person to another. The mean radiant temperature at any point in the shelter would be determined by temperatures of skin or clothing surfaces as well as temperatures

of wall and ceiling surfaces. Also, the flow of air through the space would be diverted by obstructions (people) near the floor to clear channels near the ceiling. The effect of this diversion would be to stratify the environment. Air velocities in the living space near floor level would be lower than air velocities in the overhead space. Consequently, capabilities for heat transfer by convection and evaporation of sweat would be reduced in the living space by an increase in population density. The establishment of vertical convection currents would be necessary to transfer of heat and moisture from lower to upper levels. Thus, temperatures and humidities in the living space would be somewhat higher than in the air stream overhead. The effects of population density on comfort in a shelter environment may be either adverse or beneficial, as determined by the season of the year and by relationships between metabolic parameters.

Section II, Metabolic Parameters, examines in some detail six biophysical processes for transfer of heat and moisture from the human body to its environment, first as isolated mechanisms, and then as simultaneous processes. A salient result of this study is a set of three figures (Figures 4, 5, and 6) that provide relatively complete information regarding metabolic responses in shelters occupied by sedentary persons dressed in optimum clothing. These data are based on an air velocity of about 30 feet per minute and equality of air and wall temperatures. Computations were also made with relative air velocities of about 20, 45, and 90 feet per minute, and with wall temperatures that are not equal to air temperatures. These supplementary data are included in nine numerical tables in Appendix A. It is possible to draw some tentative conclusions from these figures and tables, as follows:

- Data in Figure 6 show that proportional effects of the six processes for metabolic heat transfer are extremely variable at temperatures higher than about 30°C (86°F), but are comparatively stable at lower temperatures. Rates of heat transfer by radiation and convection do not differ greatly.
- Data in Figure 5 show that variations in humidity have a significant effect on the partition of metabolic heat losses into sensible and latent fractions at air temperatures of about 15°C to 27°C (60°F to 80°F). At higher temperatures, humidity has virtually no effect on the sensible/total or latent/total metabolic heat ratios, but has a sharply defined effect in determining limiting conditions for thermal equilibrium.
- Data in Figure 4 show that humidity has a strong effect on the ratio of wet to total skin areas in warm or hot environments.
- Data in Figure 4 also show that differences in temperature between clothing surfaces and air remain within the range of about 3°C to 6°C (4°F to 10°F). At a temperature of 30°C (86°F), the mean skin temperature is about 4°C (7°F) higher than air temperature. At a temperature of 40°C (104°F), the mean skin temperature is about 5°C (9°F) lower than air temperature. In a hotter environment, the air temperature increases at a much higher rate than skin temperatures because the skin is cooled by evaporation. These observations suggest that population density will not have a great effect on radiant heat transfer in the critical comfort range of 30°C (86°F) to 40°C (104°F). The effect of an increase in population density may be beneficial to thermal comfort in colder and hotter environments.

- Numerical data in Tables A-4, A-5, A-6, and A-7 of Appendix A are based on parameters that differ only with respect to relative air velocity and the associated values of coefficients for convection and evaporation, as shown in Table A-1. Numerical data in Tables A-4, A-8, and A-9 are based on parameters that differ only with respect to mean radiant temperature, as defined in Table A-1. A comparison among data from these tables indicates that the effects of an increase in population density on both relative air velocity and mean radiant temperature tend to lower the air temperature at which thermal equilibrium can be maintained without clothing and without evaporation of sweat. At any lower temperature, the amount of clothing required to maintain thermal equilibrium is also reduced by occupancy effects on either relative air velocity or mean radiant temperature. However, population density appears to have no significant effect on the ratio of latent to total heat transfer from clothed persons. In higher temperature ranges, which are characterized by active sweating and virtual nudity, increased occupancy tends to increase evaporative cooling requirements at air temperatures below 35°C (95°F), and to decrease these requirements at higher temperatures. The effects of changes in relative air velocity and mean radiant temperature on the latent/total heat ratio are shown graphically on Figure 9, which was constructed with data from Tables A-4, A-7, and A-8 in Appendix A. This figure also shows the effects of air velocity and radiant temperature on the limits for thermal equilibrium at two relative humidities, 50 and 100 percent. In Table A-8, mean radiant temperatures are equal to the temperatures of exposed skin or clothing, which implies complete suppression of radiative heat transfer. In Table A-5, heat/mass transfer coefficients are appropriate with a relative air velocity of about 20 feet/minute, which tends to be minimal for sedentary




FIGURE 9 EFFECTS OF AIR VELOCITY AND MEAN RADIANT TEMPERATURE ON METABOLIC HEAT TRANSFER

levels of physical activity. The metabolic data in Table A-9, which is based on a relative air velocity of about 30 feet per minute and a mean radiant temperature equal to the mean of environmental air and exposed skin or clothing temperatures, may be most representative for conditions likely to develop in shelters that are fully occupied by sedentary persons.

Section III, Shelter Ventilation, uses metabolic data developed in Section II (Figure 5) as the basis for a study of shelter ventilation, with special emphasis on systems that recirculate air in cold weather. The ventilation process lines on Figure 7 represent loci of conditions that would develop in sequence along the path of air moving through a shelter. For all of these lines, the direction of air movement is toward the line for 95°F dry-bulb temperature from either lower or higher initial temperatures. At a temperature of 95°F, only evaporative cooling is effective because air, wall, and skin temperatures are equal at that model temperature. If air is supplied to an occupied space at a temperature of 50°F, those process lines that originate along the 50°F temperature line show the band of environmental conditions that could develop along the air stream. The vertical bars across this band of process lines show the psychrometric conditions that would prevail with the designated rates of ventilation in air as it leaves the occupied space. Process lines associated with nonuniform or "varistate" environments are most realistic for ventilating systems that provide little or no air distribution.

If ventilating air enters a shelter directly from the atmosphere through a few openings, the environment near these points of entry will not differ greatly from the outside temperature. During winter weather part of the space may very cold. This objectionable situation can be avoided by one of three alternative methods, as follows:

- Provide reliable heating apparatus for warming the air before it enters the occupied space.
- Provide an extensive system of distribution ductwork and diffusion outlets.
- Use metabolic heat for tempering fresh air by arranging the ventilating system to recirculate part of the air that would otherwise be wasted.

Figure 8 relates parameters associated with partial recirculation of air, including mixed and fresh air flow rates, fresh air temperatures, final air temperatures, and changes in humidity ratio. This graphic information is based on a mixed air temperature of 50°F, which conforms to the prescribed minimum temperature for a shelter environment.

Recommendations

The following recommendations are made with regard to environmental problems in shelters:

- Concepts for shelter ventilating systems and components should be modified as necessary to provide for partial recirculation of air during cool and cold seasons.
- An evaluation should be made of parameters for partial recirculation of air during cold weather in shelters that have relatively large heat loads associated with lighting and heat transmission through shelter boundaries.
- Studies should be continued of interrelationships among population density, metabolic heat transfer, and the thermal environment in shelters to develop a more definitive correlation of significant parameters, including structural configuration and ambient effects, as well as metabolic and physiological factors.

REFERENCES

1. R. J. Baschiere, and M. Lokmanhekim, "Shelter Forced Ventilation Requirements Using Unconditioned Air," OCD Work Unit 1215A, General American Research Division, Niles, Illinois (February 1967).
2. Technical Standards for Fallout Shelters, Technical Memorandum 68-1, U.S. Office of Civil Defense (5 March 1969).
3. R. K. Pefley, E. T. Cull, and K. M. Sekins, "Monoman Calorimeter Project," Work Unit 1224 B, University of Santa Clara (January 1969).
4. F. C. Allen, "Ventilating and Mixing Processes in Nonuniform Shelter Environments," Final Report, OCD Work Unit 1236 A, Stanford Research Institute (January 1970), AD-708 574.
5. F. C. Houghten and C. P. Yagloglou, "Determining Lines of Equal Comfort," Trans. Am. Soc. Heating and Ventilating Engineers, Volume 29 (January 1923).
6. C. P. Yaglou, "A Method for Improving the Effective Temperature Index," Trans. Am. Soc. Heating and Ventilating Engineers, Volume 53 (1947).
7. A. H. Woodcock, J. J. Powers, and J. R. Breckenridge, "Man's Thermal Balance in Warm Environments," Quartermaster Research and Development Center. U.S. Army, Natick, Massachusetts (July 1956).
8. D.H.K. Lee and A. Henschel, "Evaluation of Thermal Environment in Shelters," Division of Occupational Health, Public Health Service, DHEW (August 1963).
9. C. M. Humphreys, A. Henschel, and D.H.K. Lee, "Sensible and Latent Heat Losses from Occupants of Survival Shelters," Division of Occupational Health, Public Health Service, DHEW (November 1965).
10. P. Kranz, "Calculating Human Comfort," J. Am. Soc. Heating, Refrigerating and Air Conditioning Engineers, Volume 6 (1964).
11. P. O. Fanger, "Calculation of Human Comfort, Introduction of a Basic Comfort Equation," Trans. ASHRAE, Volume 73, No. 2 (1967).

12. P. O. Fanger, R. G. Nevins, and P. E. McNall, "Predicted and Measured Heat Losses and Thermal Comfort Conditions for Human Beings," Thermal Problems in Biotechnology, American Society of Mechanical Engineers (1968).
13. Y. Nishi and K. Ibamoto, "Model Skin Temperature - An Index of Thermal Sensation in Cold, Warm and Humid Environments, Trans. ASHRAE, Volume 75, No. 2 (1969).
14. A. P. Gagge, J.A.J. Stolwijk, and Y. Nishi, "The Prediction of Thermal Comfort When Thermal Equilibrium is Maintained by Sweating," Trans. ASHRAE, Volume 75, No. 2 (1969).
15. C.E.A. Winslow and L. P. Herrington, Temperature and Human Life (Princeton University Press, Princeton, New Jersey, 1949).
16. F. C. Houghten, W. W. Teague, W. E. Miller, and W. P. Yant, "Heat and Moisture Losses from the Human Body and Their Relation to Air Conditioning Problems, Trans. Am. Soc. Heating and Ventilating Engineers, Volume 35, pp. 245-268 (1929).
17. C.E.A. Winslow, L. P. Herrington, and A. P. Gagge, "Physiological Reactions of the Human Body to Various Atmospheric Humidities," Am. J. Physiology, Volume 120, No. 2, pp. 288-299 (October 1937).
18. A. P. Gagge, "Standard Operative Temperature, a Single Measure of the Combined Effect of Radiant Temperature, of Ambient Air Temperature and of Air Movement on the Human Body," in Temperature, Its Measurement and Control in Science and Industry, pp. 544-552 (Reinhold Publishing Corporation, New York, New York, 1941).
19. Handbook of Respiration, Division of Biology and Agriculture, The National Academy of Sciences, The National Research Council (W. B. Saunders Company, Philadelphia and London, 1958).
20. Biological Handbooks: (1) Environmental Biology, (2) Metabolism, (3) Respiration and Circulation, Federation of American Societies for Experimental Biology, Bethesda, Maryland.
21. L. A. MacHattie, "Graphic Visualization of the Relations of Metabolic Fuels: Heat: O_2 : CO_2 : H_2O : Urine N," J. Appl. Physiology, Volume 15, No. 4, pp. 677-683 (1960).
22. Bioastronautics Data Book, p. 197 (Scientific and Technical Information Division, National Aeronautics and Space Administration, Washington, D.C., 1964).

23. J. B. de V. Weir, "New Methods for Calculating Metabolic Rate with Special Reference to Protein Metabolism," J. Physiology, Volume 109, pp. 1-9 (1949).
24. Smithsonian Physical Tables, Ninth Revised Edition, W. E. Forsythe, ed. (The Smithsonian Institution, Washington, D.C., 1956).
25. B. Issekutz and K. Rodahl, "Respiratory Quotient During Exercise," J. Appl. Physiology, Volume 16, No. 4, pp. 606-610 (1961).
26. C. G. Douglas and J. S. Haldane, "The Capacity of the Air Passages Under Varying Physiological Conditions," J. Physiology, Volume 45, p. 236 (1912).
27. P. K. Boyer and C. V. Bailey, "Concentration of Carbon Dioxide in Expired Air," Arch. Internal Medicine, Volume 69, pp. 773-788 (1942).
28. E. Asmussen and M. Nielsen, "Studies on the Regulation of Respiration in Heavy Work," Acta Physiologica Scandinavica, Volume 12, pp. 171-188 (1946).
29. F.D.K. Liddell, "Estimation of Energy Expenditure from Expired Air," J. Appl. Physiology, Volume 18, No. 1, pp. 25-29 (1963).
30. L. Hermansen and B. Saltin, "Oxygen Uptake During Maximal Treadmill and Bicycle Exercise," J. Appl. Physiology, Volume 26, No. 1, pp. 31-37 (1969).
31. A. Krogh, The Comparative Physiology of Respiratory Mechanisms, pp. 67-68 (University of Pennsylvania Press, Philadelphia, 1959).
32. M. Nielsen, "Untersuchungen über die Atemregulation beim Menschen besonders mit Hinblick auf die Art des chemischen Reizes," Skand. Arch. Physiol., Suppl. 10, 74, pp. 87-208 (1936).
33. J. S. Gray, Pulmonary Ventilation and Its Physiological Regulation, pp. 56-57 (Charles C. Thomas, Publisher, Springfield, Illinois, 1950).
34. H. W. Knipping and A. Moncrieff, "The Ventilation Equivalent for Oxygen," Quart. J. Medicine, Volume 25, pp. 17-30, Volume 1 (new series) (1932).
35. Philip Cole, "Some Aspects of Temperature, Moisture and Heat Relationships in the Upper Respiratory Tract," J. Laryngology and Otology, Volume 67, pp. 449-456 (1953).

36. _____, "Further Observations on the Conditioning of Respiratory Air," J. Laryngology and Otology, Volume 67, pp. 669-681 (1953).
37. _____, "Recordings of Respiratory Air Temperature," J. Laryngology and Otology, Volume 68, pp. 295-307 (1954).
38. _____, "Respiratory Mucosal Vascular Responses, Air Conditioning and Thermo Regulation," J. Laryngology and Otology, Volume 68, pp. 613-622 (1954).
39. Sven Ingelstedt, "Studies on the Conditioning of Air in the Respiratory Tract," Acta Oto-Laryngologica, Supplement 131 (1956).
40. L. E. Seeley, "Study of Changes in the Temperature and Water Vapor Content of Respired Air in the Nasal Cavity," Trans. Am. Soc. Heating and Ventilating Engineers, Volume 46, pp. 259-290 (1940).
41. P. Webb, "Air Temperatures in Respiratory Tracts of Resting Subjects in Cold," J. Appl. Physiology, Volume 4, pp. 378-382 (1951).
42. P. Webb and M. K. Neugebauer, "Recording Dielectric Hygrometer for Expired Air," Rev. Sci. Inst., Volume 25, No. 12 (December 1954).
43. G. E. Burch, "Study of Water and Heat Loss from the Respiratory Tract of Man," Arch. Internal Medicine, Volume 76, pp. 308-314 (1945).
44. _____, "Rate of Water and Heat Loss from the Respiratory Tract of Normal Subjects in a Subtropical Climate," Arch. Internal Medicine, Volume 76, pp. 315-327 (1945).
45. J. W. McCutchan and C. L. Taylor, "Respiratory Heat Exchange with Varying Temperature and Humidity of Inspired Air," Technical Report No. 6023, United States Air Force, Air Materiel Command, Wright-Patterson Air Force Base, Dayton, Ohio (October 1950).
46. P.R.B. Caldwell, D. M. Gomez, and H. W. Fritts, "Respiratory Heat Exchange in Normal Subjects and in Patients with Pulmonary Disease," J. Appl. Physiology, Volume 26, No. 1, pp. 82-88 (1963).
47. J. Hasan, M. J. Karvanen, and P. Piironen, "Physiological Effects of Extreme Heat, Special Review Part I," Am. Rev. Phys. Medicine, Volume 45, No. 6, pp. 296-314 (1966).

48. _____, "Physiological Effects of Extreme Heat, Special Review Part II," Am. Rev. Phys. Medicine, Volume 46, No. 2, pp. 1226-1246 (1967).
49. A. R. Lind, "The Influence of Inspired Air Temperature on Tolerance to Work in the Heat," Brit. J. Industrial Medicine, Volume 12, pp. 126-130 (1955).
50. D. F. Brebner, D. McK. Kerslake, and J. L. Waddell, "The Diffusion of Water Vapour through Human Skin," J. Physiology, Volume 132, pp. 225-231 (1956).
51. T. Inouye, F. K. Hick, S. E. Telser, and R. W. Keeton, "Effect of Relative Humidity on Heat Loss of Men Exposed to Environments of 80, 76, and 72 F," Trans. Am. Soc. Heating and Ventilating Engineers, Volume 59, pp. 329-346 (1953).
52. J. F. Hall and F. K. Klemm, "Insensible Weight Loss of Clothed Resting Subjects in Comfort Zone Temperatures," J. Appl. Physiology, Volume 18, No. 6, pp. 1188-1192 (1963).
53. P. Webb, L. N. Garlington, and M. J. Schwartz, "Insensible Weight Loss at High Skin Temperatures," J. Appl. Physiology, Volume 11, No. 1, pp. 41-44 (1957).
54. E. A. Pinson, "Evaporation from Human Skin with Sweat Glands Inactivated," Am. J. Physiology, Volume 137, pp. 492-503 (1942).
55. F. W. Sunderman, "Persons Lacking Sweat Glands; Hereditary Ectodermal Dysplasia of the Anhidrotic Type," Arch. Internal Medicine, Volume 67, pp. 846-854 (1941).
56. F. C. Hale, R. A. Westland, and C. L. Taylor, "Barometric and Vapor Pressure Influences on Insensible Weight Loss," J. Appl. Physiology, Volume 12, No. 1, pp. 20-28 (1958).
57. K. Buettner, "Diffusion of Water and Water Vapor Through Human Skin," J. Appl. Physiology, Volume 6, pp. 229-242 (1953).
58. C. L. Taylor and K. Buettner, "Influence of Evaporative Forces Upon Skin Temperature Dependency of Human Perspiration," J. Appl. Physiology, Volume 6, pp. 113-123 (1953).
59. A. P. Gagge, "A New Physiological Variable Associated with Sensible and Insensible Perspiration," Am. J. Physiology, Volume 120, No. 2, pp. 277-287 (1937).

60. W. V. Blockley, "Dehydration and Survivability in Warm Shelters," Work Unit 1224 A, Office of Civil Defense, Department of Defense, Washington, D.C. (June 1968).
61. Handbook of Fundamentals (American Society of Heating, Refrigerating and Air Conditioning Engineers, New York, 1972).
62. A. H. Woodcock, "Man's Thermal Balance and the Environmental Indices, Arid Zone Research," UNESCO (1964).
63. D. F. Brebner, D. McK. Kerslake, and J. L. Waddell, "The Relation Between the Coefficients for Heat Exchange by Convection and by Evaporation in Man," J. Physiology, Volume 141, pp. 164-168 (1958).
64. J. Clifford, D. McK. Kerslake, and J. L. Waddell, "The Effect of Wind Speed on Maximum Evaporative Capacity in Man," J. Physiology, Volume 147, pp. 253-259 (1959).
65. C.E.A. Winslow, A. P. Gagge, and L. P. Herrington, "The Influence of Air Movement Upon Heat Losses from the Clothed Human Body," Am. J. Physiology, Volume 127, pp. 505-518 (1939).
66. M. Nielsen and L. Pedersen, "Studies on the Heat Loss by Radiation and Convection from the Clothed Human Body," Acta Physiologica Scandinavica, Volume 27, pp. 272-294 (1952).
67. D. Mitchell, C. H. Wyndham, A. J. Vermeulen, T. Hodgson, A. R. Atkins, and H. S. Hofmeyr, "Radiant and Convective Heat Transfer of Nude Men in Dry Air," J. Appl. Physiology, Volume 26, No. 1, pp. 111-118 (1969).
68. A. Guibert and C. L. Taylor, "Radiation Area of the Human Body," J. Appl. Physiology, Volume 5, pp. 24-37 (1952).

BIBLIOGRAPHY

- Adachi, J., and S. Ito, "Insensible Perspiration Through the Skin and the Respiratory Passages, and Compensatory Changes in the Cutaneous Perspiration Due to Breathing Dry or Wet Air," J. Oriental Medicine, Vol. 21, pp. 103-104 (1931).
- Adolph, E. F., "The Initiation of Sweating in Response to Heat," Am. J. Physiology, Vol. 145, pp. 710-715 (1946).
- Andersen, K. L., and L. Hermansen, "Aerobic Work Capacity in Middle-aged Norwegian Men," J. Appl. Physiology, Vol. 20(3), pp. 432-436 (1963).
- Astrand, P. O., and Bengt Saltin, "Oxygen Uptake During the First Minutes of Heavy Muscular Exercise," J. Appl. Physiology, Vol. 16(6), pp. 971-976 (1961).
- _____, "Maximal Oxygen Uptake and Heart Rate in Various Types of Muscular Activity," J. Appl. Physiology, Vol. 16(6), pp. 977-981 (1961).
- Bell, C. R., R. F. Hellon, R. W. Hiorns, P. B. Nicol, and K. A. Provins, "Safe Exposure of Men to Severe Heat," J. Appl. Physiology, Vol. 20(2), pp. 288-292 (1965).
- Benedict, F. G., and H. F. Root, "Insensible Perspiration: Its Relation to Human Physiology and Pathology," Arch. Internal Medicine, Vol. 38, pp. 1-35 (1926).
- Berkson, J., and W. M. Boothby, "Studies of the Energy of Metabolism of Normal Individuals. A Comparison of the Estimation of Basal Metabolism from (1) A Linear Formula and (2) Surface Area," Am. J. Physiology, Vol. 116, pp. 485-491 (1936).
- _____, "Studies of the Energy of Metabolism of Normal Individuals," Am. J. Physiology, Vol. 121, pp. 669-683 (1938).
- Blockley, W. V., J. W. McCutchan, J. Lyman, and C. L. Taylor, "Human Tolerance for High Temperature Aircraft Environments," J. Aviation Medicine, Vol. 25, pp. 515-522 (1954).
- Blockley, W. V., "Human Sweat Response to Activity and Environment in the Compensable Zone of Thermal Stress: A Systematic Study," Crew Systems Division, Manned Spacecraft Center, National Aeronautics and Space Administration, Houston, Texas (December 1965).
- _____, "Quantitative Assessment of the Thermal Burden Imposed by Clothing," Environmental Research, Vol. 2, pp. 11-21 (1968).
- Boothby, W. M., J. Berkson, and H. L. Dunn, "Studies of the Energy of Metabolism of Normal Individuals: A Standard for Basal Metabolism with a Nomogram for Clinical Application," Am. J. Physiology, Vol. 116, pp. 468-484 (1936).
- Brebbia, D. R., R. F. Goldman, and E. R. Buskirk, "Water Vapor Loss from the Respiratory Tract During Outdoor Exercise in the Cold," J. Appl. Physiology, Vol. 11(2), pp. 219-222 (1957).
- Brebnor, D. F., and D. McK. Kerslake, "The Effect of Altering the Skin Temperature of the Legs on the Forearm Sweat Rate," J. Physiology, Vol. 137, pp. 363-369 (1961).
- Briscoe, W. A., R. E. Forster, and J. H. Comroe, "Alveolar Ventilation at Very Low Tidal Volumes," J. Appl. Physiology, Vol. 7, pp. 27-30 (1951).
- Bruck, E., "Water in Expired Air: Physiology and Measurement," J. Pediatrics, Vol. 60, pp. 869-881 (1962).
- Bruck, E., and D. Paa, "Water in Expired Air," J. Pediatrics, Vol. 66, pp. 365-371 (1965).
- Buchberg, H., and J. Naruishi, "On the Importance of Radiation Exchange in the Amelioration of Thermal Stress in Enclosures," Int. J. Biometeor., Vol. 11, No. 1, pp. 59-78 (1967).
- Budd, G. M., "Effects of Cold Exposure and Exercise in a Wet, Cold Antarctic Climate," J. Appl. Physiology, Vol. 20(3), pp. 417-422 (1965).
- Bulmor, M. G., and G. D. Forwell, "The Concentration of Sodium in Thermal Sweat," J. Physiology, Vol. 132, pp. 115-122 (1956).
- Burch, G. E., "A Method for Measuring Small Amounts of Weight Loss in Man," Am. J. Medical Sciences, Vol. 209, pp. 220-226 (1945).
- Burch, G. E., and N. P. DePasquale, "Hot Climates, Man and His Heart," Charles C. Thomas, Publisher, Springfield, Illinois (1962).

- Burch, G. E., and W. A. Sodeman, "Regional Relationships of Rate of Water Loss in Normal Adults in a Subtropical Climate," Am. J. Physiology, Vol. 138, pp. 603-609 (1913).
- Burch, G. E., and T. Winsor, "Rate of Insensible Perspiration (Diffusion of Water) Locally Through Living and Through Dead Human Skin," Arch. Internal Medicine, Vol. 73, pp. 137-141 (1914).
- _____, "The Relation of Total Insensible Loss of Weight to Water Loss from the Skin and Lungs of Human Subjects in a Subtropical Climate," Am. J. Medical Sciences, Vol. 209, pp. 226-231 (1915).
- Burton, A. C., and H. C. Bazett, "A Study of the Average Temperature of the Tissues, of the Exchanges of Heat, and Vasomotor Responses in Man by Means of a Bath Calorimeter," Am. J. Physiology, Vol. 117, pp. 36-51 (1936).
- Burton, A. C., and O. G. Edholm, "Man in a Cold Environment," Edward Arnold, Publisher, London (1955).
- Christie, R. V., and A. L. Loomis, "The Pressure of Aqueous Vapor in the Alveolar Air," J. Physiology, Vol. 77, pp. 35-48 (1933).
- Colin, J., and Y. Houdas, "Experimental Determination of Coefficient of Heat Exchanges by Convection of Human Body," J. Appl. Physiology, Vol. 22(1), pp. 31-38 (1967).
- Consolazio, C. F., L. O. Matoush, R. A. Nelson, J. B. Torres, and G. J. Isaac, "Environmental Temperature and Energy Expenditures," J. Appl. Physiology, Vol. 18(1), pp. 65-68 (1963).
- Craig, F. N., "The Physiological State at the Limit of Tolerance," Proceedings of Sixth International Congress on Tropical Medicine and Malaria, Lisbon, Portugal, Vol. 6, pp. 50-55 (1958).
- Crosbie, R. J., J. D. Hardy, and E. Fessenden, "Electrical Analog Simulation of Temperature Regulation in Man," IRE Transactions, Bio-Medical Electronics, Vol. BME-8, pp. 246-252 (1961).
- Davis, T.R.A., D. R. Johnston, F. C. Bell, W. Rawlings, and L. Lee, "Chamber Cold Acclimatization in Man," J. Appl. Physiology, Vol. 16(6), pp. 1011-1015 (1961).
- DuBois, E. F., "Basal Metabolism in Health and Disease," Lea and Febiger, Publisher (1921).
- Edholm, O. G., and A. L. Bacharach, "The Physiology of Human Survival," Academic Press, London, New York (1965).
- Edwards, M., and A. C. Burton, "Temperature Distribution Over the Human Head, Especially in the Cold," J. Appl. Physiology, Vol. 15(2), pp. 209-211 (1960).
- Eklon, B., C. J. Greenleaf, J. E. Greenleaf, and L. Hermansen, "Temperature Regulation During Exercise Dehydration in Man," Acta Physiol. Scand., Vol. 79, pp. 175-183 (1970).
- Erikson, H., J. Krog, K. L. Andersen, and P. F. Scholander, "The Critical Temperature in Naked Man," Acta Physiol. Scand., Vol. 37, pp. 35-39 (1956).
- Fahnestock, M. K., F. E. Boys, F. Sargent, and L. D. Siler, "Energy Costs, Comfort, and Physiological Responses to Physical Work in 95F-50 RH and 75F-15 RH Environments," ASHRAE Transactions, Vol. 73, Part 1 (1967).
- Fanger, P. O., "Thermal Comfort," Danish Technical Press, Copenhagen (1970).
- Fenn, W. O., "The Mechanism of Breathing," Scientific American, Vol. 202, pp. 138-148 (1960).
- Freeman, H., and B. A. Lengyel, "The Effects of High Humidity on Skin Temperature at Cool and Warm Conditions," J. Nutrition, Vol. 17, pp. 13-52 (1939).
- Gagge, A. P., and J. D. Hardy, "Thermal Radiation Exchange of the Human by Partitioned Calorimetry," J. Appl. Physiology, Vol. 23(2), pp. 248-258 (1967).
- Gagge, A. P., L. Herrington, and C.E.A. Winslow, "Thermal Interchanges Between the Human Body and Its Atmospheric Environment," Am. J. Hygiene, Vol. 26, No. 1, pp. 81-102 (1937).
- Gagge, A. P., G. M. Rapp, and J. D. Hardy, "Mean Radiant and Operative Temperature for High-Temperature Sources of Radiant Heat," ASHRAE Transactions, Vol. 70, pp. 119-124 (1964).
- Gagge, A. P., J.A.J. Stolwijk, and J. D. Hardy, "A Novel Approach to Measurement of Man's Heat Exchange with a Complex Radiant Environment," Aerospace Medicine, Vol. 36, No. 5 (1965).
- _____, "Comfort and Thermal Sensations and Associated Physiological Responses at Various Ambient Temperatures," Environmental Research, Vol. 1, pp. 1-20 (1967).
- Geschickter, E. H., P. A. Andrews, and R. W. Bullard, "Nocturnal Body Temperature Regulation in Man: A Rationale for Sweating in Sleep," J. Appl. Physiology, Vol. 21(2), pp. 623-630 (1966).
- Glassford, R. G., G.H.Y. Baycroft, A. W. Sedgwick, and R.B.J. Macnab, "Comparison of Maximal Oxygen Uptake Values Determined by Predicted and Actual Methods," J. Appl. Physiology, Vol. 20(3), pp. 509-513 (1965).
- Goldman, R. F., B. Green, and P. F. Iampietra, "Tolerance of Hot, Wet Environments by Resting Men," J. Appl. Physiology, Vol. 20(2), pp. 271-277 (1965).
- Green, I. D., and M. S. Nesarajah, "Water Vapor Pressure of End-tidal Air of Normals and Chronic Bronchitics," J. Appl. Physiology, Vol. 24(2), pp. 229-231 (1968).

- Hardy, J. D., "The Radiating Power of Human Skin in the Infra-Red," Am. J. Physiology, Vol. 10, pp. 151-162 (1939).
- Hardy, J. D., and E. F. DuBois, "basal Metabolism, Radiation, Convection and Vaporization at Temperatures of 22 to 33 C.," J. Nutrition, Vol. 15, pp. 177-197 (1938).
- Hendler, E., R. Crosbie, and J. D. Hardy, "Measurement of Heating of the Skin During Exposure to Infrared Radiation," J. Appl. Physiology, Vol. 12(2), pp. 177-185 (1958).
- Hermansen, Lars, and K. L. Andersen, "Aerobic Work Capacity in Young Norwegian Men and Women," J. Appl. Physiology, Vol. 20(3), pp. 125-131 (1965).
- Jerrington, L. P., C. E. Winslow, and A. P. Gagge, "The Relative Influence of Radiation and Convection Upon Vaso-motor Temperature Regulation," Am. J. Physiology, Vol. 129, pp. 153-163 (1937).
- Hertig, B. A., M. L. Riedesel, and H. S. Belding, "Sweating in Hot Baths," J. Appl. Physiology, Vol. 16(1), pp. 617-631 (1961).
- Hertzman, A. B., A. C. Randall, C. N. Peiss, and R. Seckendorf, "Regional Rates of Evaporation from the Skin at Various Environmental Temperatures," J. Appl. Physiology, Vol. 5, pp. 154-161 (1952).
- Houghton, F. C., W. A. Teague, W. E. Miller, and A. P. Vant, "Thermal Exchanges Between the Bodies of Men Working and the Atmospheric Environment," Am. J. Hygiene, Vol. 16, pp. 115-131 (1931).
- Iampietro, P. F., D. E. Bass, and E. R. Buskirk, "Heat Exchanges of Nude Men in the Cold: Effect of Humidity, Temperature and Windspeed," J. Appl. Physiology, Vol. 12(3), pp. 351-356 (1958).
- Iampietro, P. F., E. R. Buskirk, D. E. Bass, and B. F. Welch, "Effect of Food, Climate and Exercise on Rectal Temperature During the Day," J. Appl. Physiology, Vol. 11(3), pp. 349-352 (1957).
- Iampietro, P. F., and E. R. Buskirk, "Effects of high and low humidity on Heat Exchanges of Lightly Clothed Men," J. Appl. Physiology, Vol. 15(2), pp. 212-214 (1960).
- Ingestedt, S., and B. Lystad, "Secrets in the Humidifying Capacity of the Nose," Acta Oto-Laryngologica, Vol. 39, pp. 286-290 (1951).
- Isselutz, B., A. C. Birkhead, and K. Rodahl, "Use of Respiratory Quotients in Assessment of Aerobic Work Capacity," J. Appl. Physiology, Vol. 17(1), pp. 47-50 (1962).
- Johnston, M. W., and L. H. Newburgh, "Calculation of Heat Production from Insensible Loss of Weight," J. Clinical Investigation, Vol. 21, pp. 357-363 (1912).
- Kaufmann, A., R. Thüer, and G. Zollner, "Der Insensible Gewichtsverlust als Funktion der Umweltbedingungen," Pflügers Archiv Ges. Physiol., Vol. 261, pp. 189-198 (1955).
- Kerslake, D. McK., "Factors Concerned in the Regulation of Sweat Production in Man," J. Physiology, Vol. 127, pp. 280-296 (1955).
- _____, "Humidity and Heat Stress," Proceedings of Sixth International Congress on Tropical Medicine and Malaria, Lisbon, Portugal, Vol. 6, pp. 66-68 (1958).
- Kerslake, D. McK., and J. L. Waddell, "The Heat Exchanges of Wet Skin," J. Physiology, Vol. 111, pp. 150-163 (1958).
- Klocke, R. A., G. H. Gurtner, and L. E. Farhi, "Gas Transfer Across the Skin in Man," J. Appl. Physiology, Vol. 18(2), pp. 311-316 (1963).
- Kreider, M. B., and E. R. Buskirk, "Supplemental Feeding and Thermal Comfort During Sleep in the Cold," J. Appl. Physiology, Vol. 11(3), pp. 359-363 (1957).
- Kreider, M. B., E. R. Buskirk, and D. E. Bass, "Oxygen Consumption and Body Temperatures During the Night," J. Appl. Physiology, Vol. 12(3), pp. 361-366 (1958).
- Kreuzer, F., and P. Van L. Campagne, "Resting Pulmonary Diffusing Capacity for CO and O₂ at High Altitude," J. Appl. Physiology, Vol. 20(3), pp. 519-521 (1965).
- Kuno, Yas., "Human Perspiration," Charles C. Thomas, Publisher, Springfield, Illinois (1956).
- Ladell, J. S. S., "Physiological Observations on Men Working in Supposedly Limiting Environments in a West African Gold-Mine," British J. Industrial Medicine, Vol. 12, pp. 111-125 (1955).
- Lichten, I. J., "Osmotic Pressure of Human Sweat," J. Appl. Physiology, Vol. 11(3), pp. 122-124 (1957).
- Lind, A. R., "Physiological Effects of Continuous or Intermittent Work in the Heat," J. Appl. Physiology, Vol. 18(1), pp. 57-60 (1963).
- Lind, A. R., R. F. Hellon, J. S. Weiner, and R. M. Jones, "Tolerance of Men to Work in Hot Saturated Environments with Reference to Mines Rescue Operations," British J. Industrial Medicine, Vol. 12, pp. 296-303 (1955).
- Lind, A. R., and R. F. Hellon, "Assessment of Physiological Severity of Hot Climates," J. Appl. Physiology, Vol. 11(1), pp. 35-40 (1957).

- Lombard, W. P., "A Method of Recording Changes in Body Weight Which Occur Within Short Intervals of Time," J. Am. Medical Assoc., Vol. 17, pp. 1790-1793 (1906).
- Luft, U. C., D. Cardus, T. P. K. Lim, E. C. Anderson, and J. L. Hosarth, "Physical Performance in Relation to Body Size and Composition," Annals N.Y. Acad. Sciences, Vol. 110, pp. 795-808 (1965).
- Macpherson, R. K., "Physiological Responses to Hot Environments," Medical Research Council Special Report Series, No. 298, Her Majesty's Stationery Office, London (1960).
- McCutchan, J. W., and C. L. Taylor, "Respiratory Heat Exchange with Varying Temperature and Humidity of Inspired Air," J. Appl. Physiology, Vol. 1, pp. 121-135 (1951).
- McKarns, J. S., and R. S. Brief, "Nomographs Give Refined Estimate of Heat Stress Index," Heat, Piping, and Air Cond., Vol. 38, pp. 113-116 (1966).
- McNall, P. E., J. Jaan, F. H. Rohles, R. G. Netins, and W. Springer, "Thermal Comfort (Thermally Neutral) Conditions for Three Levels of Activity," ASHRAE Transactions, Vol. 73, Part 1 (1967).
- Margarita, R., P. Cerretelli, P. Agbero, and G. Sassi, "Energy Cost of Running," J. Appl. Physiology, Vol. 18(2), pp. 367-370 (1963).
- Marshall, L. H., and H. Specht, "Respiratory water Vapor at Simulated Altitude," Am. J. Physiology, Vol. 156(3), pp. 299-310 (1919).
- Michael, E. D., K. E. Hutton, and S. M. Horvath, "Cardiorespiratory Responses During Prolonged Exercise," J. Appl. Physiology, Vol. 16(6), pp. 997-1000 (1961).
- Milan, F. A., J. P. Hannon, and E. Kvonuk, "Temperature Regulation of Eskimos, Indians, and Caucasians in a Bath Calorimeter," J. Appl. Physiology, Vol. 18(2), pp. 378-382 (1963).
- Milic-Emili, G., J. M. Petit, and R. Derouane, "Mechanical Work of Breathing During Exercise in Trained and Untrained Subjects," J. Appl. Physiology, Vol. 17(1), pp. 15-16 (1962).
- Miller, A. T., and C. S. Bluth, "Lack of Insulating Effect of Body Fat During Exposure to Internal and External Heat Loads," J. Appl. Physiology, Vol. 12(1), pp. 17-19 (1958).
- Minard, D., H. S. Belding, and J. R. Kingston, "Prevention of Heat Casualties," J. Am. Medical Assoc., Vol. 165(11), pp. 1813-1818 (1957).
- Mura, U., "The Effect of Variations in Relative Humidity Upon Skin Temperature and Sense of Comfort," Am. J. Hygiene, Vol. 13, pp. 132-159 (1931).
- Nelson, N., L. W. Eichna, S. M. Horvath, W. B. Shelley, and T. A. Hatch, "Thermal Limits of Man at High Temperatures," Am. J. Physiology, Vol. 151, pp. 626-632 (1917).
- Newburgh, L. H., Editor, "Physiology of Heat Regulation and the Science of Clothing," W. B. Saunders Company, Philadelphia (1919).
- Newburgh, L. H., and M. A. Johnston, "The Insensible Loss of Water," Physiological Reviews, Vol. 22(1), pp. 1-18 (1912).
- Newburgh, L. H., F. H. Wiley, and F. H. Lashmet, "A Method for the Determination of Heat Production over Long Periods of Time," J. Clinical Investigation, Vol. 10, pp. 703-721 (1931).
- Nielsen, B., "Thermoregulation in Rest and Exercise," Acta Physiol. Scand., Supplement 323 (1969).
- Nishi, Y., and A. P. Gagge, "Moisture Permeation of Clothing - A Factor Covering Thermal Equilibrium and Comfort," ASHRAE Transactions, Vol. 76, Part 1 (1970).
- Phelps, E. B., and A. Auld, "Studies in Ventilation, I. Skin Temperature as Related to Atmospheric Temperature and Humidity," Am. J. Public Health, Vol. 21, pp. 959-970 (1931).
- Powell, R. W., and E. Griffiths, "The Evaporation of Water from Plane and Cylindrical Surfaces," Trans. Inst. Chemical Engineers, Vol. 13, pp. 175-198 (1935).
- Randall, W. C., C. N. Peiss, and R. O. Rawson, "Simultaneous Recruitment of Sweating and Perception of Warmth in Man," J. Appl. Physiology, Vol. 12(3), pp. 383-389 (1958).
- Robinson, S., S. D. Gerking, E. S. Turrell, and R. K. Kincaid, "Effect of Skin Temperature on Salt Concentration of Sweat," J. Appl. Physiology, Vol. 2, pp. 651-662 (1950).
- Robinson, S., E. S. Turrell, and S. D. Gerking, "Physiologically Equivalent Conditions of Air Temperature and Humidity," Am. J. Physiology, Vol. 113, pp. 21-32 (1915).
- Shephard, R. J., "A Critical Examination of the Douglas Bag Technique," J. Physiology, Vol. 127, pp. 515-524 (1955).
- Sibbons, J. L. H., "Assessment of Thermal Stress from Energy Balance Considerations," J. Appl. Physiology, Vol. 21(1), pp. 1207-1217 (1966).

- Spurr, G. B., B. K. Hatt, and S. M. Horvath, "Shivering, Oxygen Consumption and Body Temperatures in Acute Exposure of Man to 150 Different Cold Environments," J. Appl. Physiology, Vol. 11(1), pp. 58-61 (1957).
- Stolwijk, J. A. J., and J. D. Hardy, "Partitional Calorimetric Studies of Responses of Man to Thermal Transients," J. Appl. Physiology, Vol. 21(5), pp. 967-977 (1966).
- _____, "Temperature Regulation in Man--A Theoretical Study," Pflügers Archiv Ges. Physiol., Vol. 291, pp. 129-162 (1966).
- Stoll, A. M., "The Role of the Skin in Heat Transfer," ASME Transactions, J. Heat Transfer, pp. 239-242 (August 1960).
- Taylor, H. L., E. Buskirk, and A. Henschel, "Maximal Oxygen Intake as an Objective Measure of Cardio-Respiratory Performance," J. Appl. Physiology, Vol. 8, pp. 75-80 (1955).
- Teichner, A. H., "Assessment of Mean Body Surface Temperature," J. Appl. Physiology, Vol. 12(2), pp. 169-176 (1958).
- Thauer, R., G. Zollner, and A. Kaufmann, "Der Insensible Gewichtsverlust als Funktion der Umweltbedingungen," Pflügers Archiv Ges. Physiol., Vol. 260, pp. 1-23 (1951).
- Thauer, R., A. Kaufmann, and G. Zollner, "Der Insensible Gewichtsverlust als Funktion der Umweltbedingungen," Pflügers Archiv Ges. Physiol., Vol. 261, pp. 183-188 (1955).
- Thaysen, J. H., and I. L. Schwartz, "Fatigue of the Sweat Glands," J. Clinical Investigation, Vol. 34, pp. 1719-1725 (1955).
- Trolle, Carsten, "A Study of the Insensible Perspiration in Man and Its Nature," Skand. Archiv Physiologie, Vol. 76, pp. 223-246 (1937).
- van Beaumont, W., and R. A. Bullard, "Sweating: Direct Influence of Skin Temperature," Science, Vol. 117, No. 3061, pp. 1165-1167 (1960).
- Verzar, F., J. Keitt, and A. Pichet, "Temperatur und Feuchtigkeit der Luft in den Atemwegen," Pflügers Archiv Ges. Physiol., Vol. 257, pp. 100-116 (1953).
- Walker, J. F. C., and R. L. Wells, "Thermometry of Respirated Air," J. Appl. Physiology, Vol. 10, pp. 511-512 (1960).
- _____, "Heat and Water Exchange in the Respiratory Tract," Am. J. Medicine, Vol. 30, No. 2, pp. 259-267 (1961).
- Webb, P., "The Measurement of Respiratory Air Temperature," Review Scientific Instruments, Vol. 23, No. 3, pp. 232-231 (1952).
- _____, "Water Vapor as a Critical Component in Sealed Cables and Pressure Suits," Humidity and Moisture, Measurement and Control in Science and Industry, Vol. 2, Applications, Reinhold Publishing Corp. (1965).
- Weiner, J. S., and R. E. Van Heiningen, "Relation of Skin Temperature to Salt Concentration of General Body Secret," J. Appl. Physiology, Vol. 1, pp. 725-733 (1952).
- Wiley, F. H., and L. H. Newburgh, "The Relationship Between the Environment and the Basal Insensible Loss of Weight," J. Clinical Investigation, Vol. 10 (1931).
- Winslow, C. F. A., L. P. Herrington, and A. P. Gogge, "The Determination of Radiation and Convection Exchanges by Partitional Calorimetry," Am. J. Physiology, Vol. 116, pp. 669-684 (1936).
- _____, "A Method of Partitional Calorimetry," Am. J. Physiology, Vol. 116, pp. 641-655 (1936).
- _____, "The Reactions of the Clothed Human Body to Variations in Atmospheric Humidity," Am. J. Physiology, Vol. 121, pp. 692-704 (1938).
- Winslow, C. F. A., A. P. Gogge, and L. P. Herrington, "Heat Exchange and Regulation in Radiant Environments Above Low Air Temperature," Am. J. Physiology, Vol. 21, pp. 79-92 (1910).
- Winslow, C. F. A., and L. P. Herrington, "Temperature and Human Life," Princeton Univ. Press, Princeton, N.J. (1919).
- Wissler, F. H., "Steady-State Temperature Distribution in Man," J. Appl. Physiology, Vol. 16(1), pp. 731-740 (1961).
- Woodcock, A. H., "Moisture Permeability Index--A New Index for Describing Evaporative Heat Transfer Through Fabric Systems," Technical Report EP-39, Quartermaster Research and Engineering Center, Natick, Massachusetts (June 1961).
- Woodcock, A. H., J. J. Powers, and J. R. Breckenridge, "Man's Thermal Balance in Warm Environments," Technical Report EP-39, Environmental Protection Branch, Quartermaster Research and Development Center, Natick, Massachusetts (July 1956).
- Woodcock, A. H., and J. R. Breckenridge, "A New Method for Completely Describing Man's Thermal Environment," Humidity and Moisture, Measurement and Control in Science and Industry, Vol. 2, Applications, Reinhold Publishing Corp. (1965).

- Wyndham, C. H., W. M. Bouwer, M. G. Devine, H. L. Paterson, and D. K. C. MacDonald, "Examination of Use of Heat-Exchange Equations for Determining Changes in Body Temperature," J. Appl. Physiology, Vol. 5, pp. 299-307 (1952).
- Wyndham, C. H., N. B. Strydom, J. F. Morrison, J. Peter, C. G. Williams, G. A. G. Bredell, and A. Joffe, "Differences Between Ethnic Groups in Physical Working Capacity," J. Appl. Physiology, Vol. 18(2), pp. 361-366 (1963).
- Wyndham, C. H., R. Plotkin, and A. Munro, "Physiological Reactions to Cold of Men in the Antarctic," J. Appl. Physiology, Vol. 19(1), pp. 593-597 (1961).
- Wyndham, C. H., N. B. Strydom, A. Munro, R. K. MacPherson, B. Metz, G. Schall, and J. Schieber, "Heat Reactions of Caucasians in Temperate, in Hot, Dry, and in Hot, Humid Climates," J. Appl. Physiology, Vol. 13(1), pp. 607-612 (1961).
- Wyndham, C. H., "Role of Skin and of Core Temperatures in Man's Temperature Regulation," J. Appl. Physiology, Vol. 20(1), pp. 31-36 (1965).
- Wyndham, C. H., J. F. Morrison, and C. G. Williams, "Heat Reactions of Male and Female Caucasians," J. Appl. Physiology, Vol. 20(3), pp. 357-361 (1965).
- Yaglou, C. P., and A. Messer, "The Importance of Clothing in Air Conditioning," J. Am. Medical Assoc., Vol. 117, No. 15, pp. 1261-1262 (1911).
- Zöllner, G. P. Thauer, and W. Kaafmann, "Der Insensible Gewichtsverlust als Funktion der Umgebungsbedingungen," Pflügers Archiv Ges. Physiol., Vol. 260, pp. 261-273 (1955).

Appendix A

NUMERICAL TABULATION OF METABOLIC PARAMETERS

Some basic results of the study of processes for transfer of metabolic heat and moisture are compared graphically in Figures 4, 5, and 6 of Section II, Metabolic Parameters. In addition to the plotted data, computations were made for other conditions in the man/environment system. These supplementary results, as well as abridged tabulations of the plotted data, are shown in Tables A-1 through A-10 at the end of this appendix. Table A-1 is a key to identification of parameters that vary among the several tables in this group. Table A-3 represents the data from which all curves in Figures 4, 5, and 6 were plotted. Table A-4 represents supplementary values for the rows of dots on the figures. The computations for these supplementary values include a factor for the effect of clothing in attenuating vapor pressure differentials that cause diffusion through dry skin. Values of input parameters that remain constant in all tables, together with associated symbols used in the computer program, are as follows:

Barometric pressure, $P_8 = 1.0$ atmosphere

Body temperature, $T_7 = 37^{\circ}\text{C}$.

Metabolic rate, $M = 100$ kcal/hour

Total heat loss to environment, $M_0 = 100$ kcal/hour

Skin surface (DuBois area), $A = 2 \text{ m}^2$

Effective skin area, convection, $A_1 = 1.9$ sq meters

Effective skin area, radiation, $A_2 = 1.3$ sq meters

Radiation coefficient, $J_1 = 4.8$ (absolute surface temperatures, $^{\circ}\text{K}$, are divided by 100)

Pulmonary ventilation, $G = 0.6$ Kg/hour of inspired dry air.

Tables A-2 through A-10 each contain eight columns of data. The first column, headed RH%, shows the three values of relative humidity ($Y_2 = 0, 50, \text{ and } 100$ percent) for which computations were made at each value of air temperature. Each group of computations is identified by a subheading that includes the air temperature, $T^{\circ}\text{C}$, skin temperature, $T_3^{\circ}\text{C}$, and

the pressure of saturated water vapor, P3 mmHg, at skin temperature. Each of the other eight columns show two values of computed parameters for each value of relative humidity. These two parameters are identified by the upper and lower headings for each column. In column 2, LAHET is the latent heat loss, L kcal/hr, and SEHET is the sensible heat loss, S kcal/hr. In column 3, LHMIN is the minimum latent heat transfer, L0 kcal/hr, associated with respiration, L3 kcal/hr, vapor diffusion through dry skin, L7 kcal/hr, and a spontaneous sweat, L4 kcal/hr, associated with physical activity. For sedentary activities, L4 = 0. Also, in column 3, STORE is the rate of heat storage, X6 kcal/hr, which vanishes when thermal equilibrium is attainable in the environment. In column 4, LREQD is the aggregate latent heat loss, L6, required to maintain thermal equilibrium, except that an alternative quantity is printed in place of LREQD when clothing is worn. This alternative quantity is equal to the metabolic rate minus the sensible heat loss that would occur if clothing were not worn. The quantity RADHT is sensible heat transfer by radiation, R1, from exposed surfaces of skin or clothing. In column 5, LHMAX is the maximum value of latent heat loss, L9, when all skin surfaces are wet, except that the value printed for LHMAX is the same as the value for LHMIN in column 3 when clothing is worn. The quantity, CONSK, is sensible heat transfer by convection, C1, from exposed surfaces of skin or clothing. In column 6, LHRES is the latent heat transfer, L3, and CORES is the sensible heat loss, D3, associated with respiration. In column 7, LHDSK is the latent heat loss, L2, associated with vapor diffusion through dry skin, and PMMHG is the partial pressure of water vapor in the environmental air in millimeters of mercury. In column 8, LHWSK is the latent heat loss associated with evaporation of sweat, E5, at wet skin surfaces, and CLOSR is the thermal resistance of clothing, K2, in clo units. In column 9, WETLR is a ratio, R5, relating to the proportionate area of wet skin and is defined as the ratio of actual heat loss associated with evaporation of sweat from wet skin surfaces to the maximum perspiratory heat loss when skin surfaces are completely wet. The quantity, CLODT, is the temperature gradient from skin to exposed surfaces of clothing.

The BASIC program used for computing and tabulating metabolic data associated with the simultaneous effects of all heat-mass transfer processes is reproduced in Table A-10.

TABLE A-1
DATA FOR NUMERICAL TABLES OF METABOLIC PARAMETERS

TABLE NUMBER	A-2	A-3	A-4	A-5	A-6	A-7	A-8	A-9	A-10
SKIN TEMPERATURE, T ₃ , AT AIR TEMPERATURE, T, (CELSIUS) T ₃ =34 T ₃ =34+1.5*ATN(0.1967*(T-31))	X	X	X	X	X	X	X	X	X
ATTENUATION FACTOR, F ₃ , FOR VAPOR DIFFUSION THROUGH CLOTHED SKIN AREAS F ₃ =1.0 F ₃ =1/(1+0.1*K ₂) F ₃ =1/(1+0.2*K ₂)	X	X	X	X	X	X	X	X	X
MEAN RADIANT TEMPERATURE, T ₁ , IN OCCUPIED SPACE (CELSIUS) T ₁ =T T ₁ =T ₃ OR T ₁ =T ₂ T ₁ =(T ₃ +T)/2 OR T ₁ =(T ₂ +T)/2	X	X	X	X	X	X	X	X	X
CONVECTION COEFFICIENT, H ₁ , FOR EXPOSED SKIN OR CLOTHING KCAL/(HR*SQ M*°C)	4.0	4.0	4.0	3.4	5.0	7.0	4.0	4.0	4.0
EVAPORATION COEFFICIENT, E ₁ , FOR WET SKIN AREAS KCAL/(HR*SQ M*MMHG)	8.0	8.0	8.0	6.8	10.0	14.0	8.0	8.0	8.0
RELATIVE AIR VELOCITY, V ₁ CENTIMETERS/SECOND FEET/MINUTE	15 30	15 30	15 30	10 20	23 45	45 90	15 30	15 30	15 30

T₃=SKIN TEMPERATURE, T₂=CLOTHING TEMPERATURE, T=AIR TEMPERATURE (CELSIUS)
K₂=THERMAL RESISTANCE OF CLOTHING (CLO UNITS)

TABLE A-2

METABOLIC PARAMETERS, SET 1

RH%	LAHET SEHET	LHMIN STORE	LREOD RADHT	LHMAX C0NSK	LHRES C0RES	LHDSK PMMHG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +10.00 SKIN: 34.00 C 39.90 MMHG								
0	+35.5	+35.5	-239.5	+35.5	+8.93	+26.5	+0.0	+0.0000
	+64.5	+0.0	+26.6	+35.1	+2.80	+0.00	+3.520	+20.586
50	+31.5	+31.5	-239.6	+31.5	+8.02	+23.5	+0.0	+0.0000
	+68.5	+0.0	+28.3	+37.2	+2.93	+4.50	+3.269	+20.308
100	+27.5	+27.5	-239.7	+27.5	+7.12	+20.4	+0.0	+0.0000
	+72.5	+0.0	+30.0	+39.4	+3.05	+9.20	+3.045	+20.026
AIR TEMP: +20.00 SKIN: 34.00 C 39.90 MMHG								
0	+36.0	+36.0	-102.4	+36.0	+9.48	+26.5	+0.0	+0.0000
	+64.0	+0.0	+28.6	+33.9	+1.48	+0.00	+1.722	+10.196
50	+28.3	+28.3	-102.6	+28.3	+7.64	+20.7	+0.0	+0.0000
	+71.6	+0.0	+32.1	+37.9	+1.67	+8.77	+1.455	+9.647
100	+20.7	+20.7	-102.8	+20.7	+5.80	+14.9	+0.0	+0.0000
	+79.3	+0.0	+35.5	+41.9	+1.86	+17.53	+1.239	+9.095
AIR TEMP: +25.00 SKIN: 34.00 C 39.90 MMHG								
0	+36.3	+36.3	-31.5	+36.3	+9.76	+26.5	+0.0	+0.0000
	+63.7	+0.0	+29.6	+33.3	+0.81	+0.00	+0.832	+4.957
50	+25.9	+25.9	-31.7	+25.9	+7.23	+18.6	+0.0	+0.0000
	+74.1	+0.0	+34.4	+38.6	+1.05	+11.88	+0.608	+4.209
100	+15.4	+15.4	-32.0	+15.4	+4.67	+10.7	+0.0	+0.0000
	+84.6	+0.0	+39.3	+43.5	+1.28	+23.76	+0.438	+3.461
AIR TEMP: +27.00 SKIN: 34.00 C 39.90 MMHG								
0	+36.4	+36.4	-2.7	+36.4	+9.88	+26.5	+0.0	+0.0000
	+63.6	+0.0	+30.0	+33.1	+0.55	+0.00	+0.477	+2.849
50	+24.7	+24.7	-2.9	+24.7	+7.01	+17.6	+0.0	+0.0000
	+75.3	+0.0	+35.5	+39.0	+0.80	+13.37	+0.285	+2.010
100	+12.9	+12.9	-3.2	+12.9	+4.10	+8.5	+0.0	+0.0000
	+87.1	+0.0	+41.1	+45.0	+1.06	+26.74	+0.143	+1.167
AIR TEMP: +29.00 SKIN: 34.00 C 39.90 MMHG								
0	+36.5	+36.5	+26.4	+36.5	+10.00	+26.5	+0.0	+0.0000
	+63.4	+0.0	+30.4	+32.8	+0.28	+0.00	+0.123	+0.737
50	+26.2	+23.3	+26.2	+385.0	+6.76	+16.4	+3.0	+3.0079
	+73.8	+0.0	+35.3	+38.0	+0.56	+15.02	+0.000	+0.0000
100	+25.9	+10.0	+25.9	+153.3	+3.46	+5.8	+16.6	+0.1106
	+74.1	+0.0	+35.3	+38.0	+0.84	+30.04	+0.000	+0.0000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+55.8	+36.7	+55.8	+616.7	+10.12	+25.7	+20.0	+0.0330
	+44.2	+0.0	+1.4	+22.8	+0.01	+0.00	+0.000	+0.0000
50	+55.5	+21.8	+55.5	+356.9	+6.46	+13.8	+35.3	+0.1006
	+44.5	+0.0	+21.4	+22.8	+0.31	+16.85	+0.000	+0.0000
100	+55.2	+6.9	+55.2	+97.1	+2.74	+1.9	+50.5	+0.5359
	+44.8	+0.0	+21.4	+22.8	+0.62	+33.70	+0.000	+0.0000
AIR TEMP: +35.00 SKIN: 34.00 C 39.90 MMHG								
0	+115.4	+36.9	+115.4	+616.9	+10.36	+22.9	+82.1	+0.1353
	-15.4	+0.0	-7.3	-7.6	-0.52	+0.00	+0.000	+0.0000
50	+115.0	+18.3	+115.0	+291.7	+5.75	+8.1	+101.2	+0.3539
	-15.0	+0.0	-7.3	-7.6	-0.16	+21.09	+0.000	+0.0000
100	-33.6	-33.6	+114.7	-33.6	+1.02	+0.0	-34.6	+1.0000
	-14.7	+148.3	-7.3	-7.6	+0.20	+42.18	+0.000	+0.0000
AIR TEMP: +40.00 SKIN: 34.00 C 39.90 MMHG								
0	+191.5	+37.2	+191.5	+617.2	+10.67	+19.5	+161.3	+0.2660
	-91.5	+0.0	-44.7	-45.6	-1.19	+0.00	+0.000	+0.0000
50	+190.6	+12.7	+191.0	+190.6	+4.58	+0.0	+186.0	+1.0000
	-91.0	+0.5	-44.7	-45.6	-0.75	+27.67	+0.000	+0.0000
100	-236.3	-236.3	+190.5	-236.3	-1.74	+0.0	-234.6	+1.0000
	-90.6	+426.9	-44.7	-45.6	-0.29	+55.34	+0.000	+0.0000
AIR TEMP: +52.00 SKIN: 34.00 C 39.90 MMHG								
0	+381.7	+38.0	+381.7	+618.0	+11.45	+10.8	+359.4	+0.5926
	-281.7	+0.0	-142.1	-136.8	-2.79	+0.00	+0.000	+0.0000
50	-169.6	-169.6	+381.0	-169.6	+0.12	+0.0	-169.7	+1.0000
	-281.0	+550.6	-142.1	-136.8	-2.08	+51.07	+0.000	+0.0000

TABLE A-2 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX C0VSK	LHRES C0RES	LHDSK PMMHG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +0.00 SKIN: 34.00 C 39.90 MMHG								
0	+34.9	+34.9	-370.5	+34.9	+8.41	+26.5	+0.0	+0.0000
	+65.0	+0.1	+24.7	+36.2	+4.12	+0.00	+5.353	+30.896
50	+33.0	+33.0	-370.6	+33.0	+8.01	+25.0	+0.0	+0.0000
	+67.0	+0.0	+25.4	+37.3	+4.21	+2.29	+5.173	+30.763
100	+31.1	+31.1	-370.7	+31.1	+7.61	+23.5	+0.0	+0.0000
	+68.9	+0.0	+26.2	+38.4	+4.29	+4.58	+5.005	+30.632
AIR TEMP: +15.00 SKIN: 34.00 C 39.90 MMHG								
0	+35.7	+35.7	-171.7	+35.7	+9.20	+26.5	+0.0	+0.0000
	+64.2	+0.0	+27.6	+34.5	+2.14	+0.00	+2.617	+15.403
50	+30.2	+30.2	-171.9	+30.2	+7.90	+22.3	+0.0	+0.0000
	+69.8	+0.0	+30.0	+37.5	+2.29	+6.39	+2.346	+15.009
100	+24.6	+24.6	-172.0	+24.6	+6.59	+18.0	+0.0	+0.0000
	+75.4	+0.0	+32.5	+40.4	+2.45	+12.78	+2.115	+14.610
AIR TEMP: +23.00 SKIN: 34.00 C 39.90 MMHG								
0	+36.2	+36.2	-60.1	+36.2	+9.65	+26.5	+0.0	+0.0000
	+63.8	+0.0	+29.2	+33.5	+1.08	+0.00	+1.187	+7.055
50	+26.9	+26.9	-60.3	+26.9	+7.42	+19.5	+0.0	+0.0000
	+73.0	+0.0	+33.4	+38.3	+1.29	+10.53	+0.940	+6.393
100	+17.7	+17.7	-60.5	+17.7	+5.16	+12.5	+0.0	+0.0000
	+82.3	+0.0	+37.7	+43.1	+1.51	+21.07	+0.749	+5.730
AIR TEMP: +30.00 SKIN: 34.00 C 39.90 MMHG								
0	+41.1	+36.6	+41.1	+616.6	+10.06	+26.3	+4.7	+0.0077
	+58.9	+0.0	+28.4	+30.4	+0.15	+0.00	+0.000	+0.000
50	+40.8	+22.6	+40.8	+371.3	+6.62	+15.1	+19.1	+0.0523
	+59.2	+0.0	+28.4	+30.4	+0.43	+15.91	+0.000	+0.000
100	+40.5	+8.5	+40.5	+125.9	+3.11	+3.9	+33.5	+0.2727
	+59.5	+0.0	+28.4	+30.4	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.00 C 39.90 MMHG								
0	+85.5	+36.8	+85.5	+616.8	+10.24	+24.3	+50.9	+0.0839
	+14.5	+0.0	+7.2	+7.6	+0.25	+0.00	+0.000	+0.000
50	+85.1	+20.1	+85.1	+325.9	+6.13	+11.0	+68.0	+0.2126
	+14.9	+0.0	+7.2	+7.6	+0.07	+18.87	+0.000	+0.000
100	+34.9	+3.4	+84.8	+34.9	+1.92	+0.0	+33.0	+1.0000
	+15.2	+49.9	+7.2	+7.6	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 34.00 C 39.90 MMHG								
0	+145.6	+37.0	+145.6	+617.0	+10.48	+21.6	+113.6	+0.1872
	+45.6	+0.0	+22.0	+22.8	+0.78	+0.00	+0.000	+0.000
50	+145.2	+16.2	+145.2	+254.1	+5.33	+5.0	+134.9	+0.5423
	+45.2	+0.0	+22.0	+22.8	+0.40	+23.54	+0.000	+0.000
100	+109.0	+109.0	+144.8	+109.0	+0.00	+0.0	+109.0	+1.0000
	+44.8	+253.8	+22.0	+22.8	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 34.00 C 39.90 MMHG								
0	+269.4	+37.5	+269.4	+617.5	+10.99	+15.9	+242.5	+0.3998
	+169.4	+0.0	+83.9	+83.6	+1.85	+0.00	+0.000	+0.000
50	+63.2	+5.7	+268.9	+63.2	+3.05	+0.0	+60.1	+1.0000
	+168.9	+205.7	+83.9	+83.6	+1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 34.00 C 39.90 MMHG								
0	+349.2	+37.9	+349.2	+617.8	+11.31	+12.3	+325.6	+0.5368
	+249.2	+0.0	+125.1	+121.6	+2.52	+0.00	+0.000	+0.000
50	+95.8	+95.8	+348.6	+95.8	+1.06	+0.0	+96.9	+1.0000
	+248.6	+444.4	+125.1	+121.6	+1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 34.00 C 39.90 MMHG								
0	+514.8	+38.5	+514.8	+618.5	+12.00	+4.7	+498.0	+0.8211
	+414.8	+0.0	+213.3	+197.6	+3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 34.00 C 39.90 MMHG								
0	+619.2	+39.3	+686.6	+619.2	+12.71	+0.0	+606.5	+1.0000
	+588.6	+69.4	+309.8	+273.6	+5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 34.00 C 39.90 MMHG								
0	+620.0	+40.0	+871.3	+620.0	+13.47	+0.0	+606.5	+1.0000
	+771.3	+251.3	+415.2	+349.6	+6.57	+0.00	+0.000	+0.000

TABLE A-3

METABOLIC PARAMETERS, SET 2

RHX	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CØNSK	LHRES CØRES	LKDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+32.6	+32.6	-210.0	+32.6	+8.93	+23.7	+0.0	+0.0000
	+67.3	+0.0	+27.9	+36.6	+2.80	+0.00	+2.991	+18.289
50	+28.7	+28.7	-210.1	+28.7	+8.02	+20.7	+0.0	+0.0000
	+71.3	+0.0	+29.6	+38.8	+2.93	+4.60	+2.779	+18.004
100	+24.7	+24.7	-210.2	+24.7	+7.12	+17.6	+0.0	+0.0000
	+75.3	+0.0	+31.2	+41.0	+3.05	+9.20	+2.589	+17.718
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+33.6	+33.6	-77.2	+33.6	+9.48	+24.1	+0.0	+0.0000
	+66.4	+0.0	+29.7	+35.2	+1.48	+0.00	+1.334	+8.209
50	+25.9	+25.9	-77.4	+25.9	+7.64	+18.3	+0.0	+0.0000
	+74.0	+0.0	+33.2	+39.2	+1.67	+8.77	+1.116	+7.657
100	+18.3	+18.3	-77.6	+18.3	+5.80	+12.5	+0.0	+0.0000
	+81.7	+0.0	+36.7	+43.2	+1.86	+17.53	+0.938	+7.099
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+34.4	+34.4	-12.3	+34.4	+9.76	+24.7	+0.0	+0.0000
	+65.5	+0.0	+30.5	+34.3	+0.81	+0.00	+0.559	+3.430
50	+24.0	+24.0	-12.5	+24.0	+7.23	+16.8	+0.0	+0.0000
	+76.0	+0.0	+35.3	+39.6	+1.05	+11.88	+0.377	+2.680
100	+13.5	+13.5	-12.7	+13.5	+4.67	+8.9	+0.0	+0.0000
	+86.4	+0.0	+40.2	+44.9	+1.28	+23.76	+0.239	+1.927
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+35.0	+35.0	+12.1	+35.0	+9.88	+25.1	+0.0	+0.0000
	+65.0	+0.0	+30.7	+33.8	+0.55	+0.00	+0.274	+1.673
50	+23.2	+23.2	+11.9	+23.2	+7.01	+16.2	+0.0	+0.0000
	+76.8	+0.0	+36.2	+39.7	+0.80	+13.37	+0.115	+0.830
100	+11.6	+11.4	+11.6	+171.2	+4.10	+7.3	+0.2	+0.0013
	+88.4	+0.0	+41.7	+45.6	+1.06	+26.74	+0.000	+0.000
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+35.7	+35.7	+34.8	+35.7	+10.00	+25.7	+0.0	+0.0000
	+64.3	+0.0	+30.8	+33.2	+0.28	+0.00	+0.012	+0.071
50	+34.5	+22.5	+34.5	+366.2	+6.76	+15.2	+12.5	+0.0349
	+65.5	+0.0	+31.2	+33.7	+0.56	+15.02	+0.000	+0.000
100	+34.2	+9.2	+34.2	+134.6	+3.46	+4.6	+26.1	+0.1994
	+65.8	+0.0	+31.2	+33.7	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+55.8	+36.7	+55.8	+616.7	+10.12	+25.7	+20.0	+0.0330
	+44.2	+0.0	+21.4	+22.8	+0.01	+0.00	+0.000	+0.000
50	+55.5	+21.8	+55.5	+356.9	+6.46	+13.8	+35.3	+0.1006
	+44.5	+0.0	+21.4	+22.8	+0.31	+16.85	+0.000	+0.000
100	+55.2	+6.9	+55.2	+97.1	+2.74	+1.9	+50.5	+0.5359
	+44.8	+0.0	+21.4	+22.8	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+651.5	+10.36	+25.2	+65.0	+0.1013
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+326.3	+5.75	+10.3	+84.1	+0.2622
	-0.2	+0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.0000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+167.9	+39.6	+167.9	+672.9	+10.67	+23.1	+134.1	+0.2025
	-67.9	+0.0	-33.1	-33.6	-1.19	+0.00	+0.000	+0.000
50	+167.4	+15.2	+167.4	+246.2	+4.58	+3.6	+159.2	+0.6591
	-67.4	+0.0	-33.1	-33.6	-0.75	+27.67	+0.000	+0.000
100	-180.7	-180.7	+167.0	-180.7	-1.74	+0.0	-178.9	+1.0000
	-67.0	+347.7	-33.1	-33.6	-0.29	+55.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+351.9	+41.1	+351.9	+688.9	+11.45	+13.4	+325.0	+0.4797
	-251.9	+0.0	-127.5	-121.6	-2.79	+0.00	+0.000	+0.000
50	-98.7	-98.7	+351.2	-98.7	+0.12	+0.0	-98.8	+1.0000
	-251.2	+449.8	-127.5	-121.6	-2.08	+51.07	+0.000	+0.000

TABLE A-3 (CONCLUDED)

RH%	LAHET SENCT	LHMIN STORE	LREQD RADHT	LHMAX CONS	LHRES CORES	LHDSK PMMHG	LHWSK CLSR	WETLR CLDT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+32.0	+32.0	-339.4	+32.0	+8.41	+23.6	+0.0	+0.0000
	+38.0	+0.0	+25.9	+38.0	+4.12	+0.00	+4.707	+28.490
50	+30.1	+30.1	-339.4	+30.1	+8.01	+22.0	+0.0	+0.0000
	+69.9	+0.0	+26.7	+39.1	+4.21	+2.29	+4.553	+28.356
100	+28.1	+28.1	-339.5	+28.1	+7.61	+20.5	+0.0	+0.0000
	+71.8	+0.0	+27.4	+40.1	+4.29	+4.58	+4.409	+28.222
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+33.1	+33.1	-143.7	+33.1	+9.20	+23.9	+0.0	+0.0000
	+66.9	+0.0	+28.8	+35.9	+2.14	+0.00	+2.152	+13.213
50	+27.5	+27.5	-143.9	+27.5	+7.90	+19.6	+0.0	+0.0000
	+72.4	+0.0	+31.3	+38.9	+2.29	+6.39	+1.927	+12.814
100	+21.9	+21.9	-144.1	+21.9	+6.59	+15.4	+0.0	+0.0000
	+78.0	+0.0	+33.7	+41.9	+2.45	+12.78	+1.733	+12.411
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+34.0	+34.0	-37.8	+34.0	+9.65	+24.4	+0.0	+0.0000
	+65.9	+0.0	+30.2	+34.7	+1.08	+0.00	+0.861	+5.295
50	+24.8	+24.8	-38.0	+24.8	+7.42	+17.4	+0.0	+0.0000
	+75.2	+0.0	+34.5	+39.4	+1.29	+10.53	+0.661	+4.629
100	+15.5	+15.5	-38.2	+15.5	+5.16	+10.4	+0.0	+0.0000
	+84.4	+0.0	+38.7	+44.2	+1.51	+21.07	+0.504	+3.960
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+45.4	+36.2	+45.4	+606.8	+10.06	+25.7	+9.7	+0.0162
	+54.6	+0.0	+26.3	+28.2	+0.15	+0.00	+0.000	+0.000
50	+45.1	+22.1	+45.1	+361.5	+6.62	+14.5	+24.0	+0.0677
	+54.9	+0.0	+26.3	+28.2	+0.43	+15.91	+0.000	+0.000
100	+44.3	+8.1	+44.8	+116.1	+3.11	+3.3	+38.4	+0.3402
	+55.2	+0.0	+26.3	+28.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+77.1	+37.6	+77.1	+636.0	+10.24	+25.6	+41.3	+0.0660
	+22.9	+0.0	+11.3	+11.9	+0.25	+0.00	+0.000	+0.000
50	+76.8	+21.0	+76.8	+345.1	+5.13	+12.3	+58.4	+0.1722
	+23.2	+0.0	+11.3	+11.9	+0.07	+18.87	+0.000	+0.000
100	+54.2	+4.2	+76.2	+54.2	+1.92	+0.0	+52.2	+1.0000
	+23.6	+22.3	+11.3	+11.9	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+126.2	+39.0	+126.2	+662.4	+10.48	+24.5	+91.2	+0.1399
	-26.2	+0.0	-12.5	-12.9	+0.78	+0.00	+0.000	+0.000
50	+125.6	+18.2	+125.6	+299.5	+5.33	+7.9	+112.6	+0.3827
	-25.8	+0.0	-12.5	-12.9	+0.40	+23.54	+0.000	+0.000
100	-63.6	+63.6	+125.4	-63.6	+0.00	+0.0	-63.6	+1.0000
	-25.4	+189.1	-12.5	-12.9	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+242.1	+40.4	+242.1	+682.3	+10.99	+20.1	+210.9	+0.3142
	-142.1	+0.0	-70.6	-69.7	-1.85	+0.00	+0.000	+0.000
50	+127.9	+8.5	+241.5	+127.9	+3.05	+0.0	+124.9	+1.0000
	-141.5	+113.6	-70.6	-69.7	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+319.9	+40.9	+319.9	+687.4	+11.31	+16.8	+291.8	+0.4316
	-219.9	+0.0	-110.7	-106.7	-2.52	+0.00	+0.000	+0.000
50	-26.2	-26.2	+319.3	-26.2	+1.06	+0.0	-27.3	+1.0000
	-219.3	+345.5	-110.7	-106.7	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+483.5	+41.8	+483.5	+693.0	+12.00	+9.6	+461.9	+0.6783
	-383.5	+0.0	-198.0	-181.7	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+656.4	+42.6	+656.4	+696.2	+12.71	+1.8	+641.9	+0.9391
	-556.4	+0.0	-294.0	-257.2	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+698.5	+43.4	+698.5	+698.5	+13.47	+0.0	+685.0	+1.0000
	-738.5	+140.1	-399.1	-332.9	-6.57	+0.00	+0.000	+0.000

TABLE A-4

METABOLIC PARAMETERS, SET 3

RH% SEHET	LAHET	LHMIN STORE	LREQD RADHT	LHMAX CONSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+27.6	+32.6	-210.0	+32.6	+8.93	+18.7	+0.0	+0.0000
	+72.4	+0.0	+30.1	+39.5	+2.80	+0.00	+2.716	+17.914
50	+24.5	+28.7	-210.1	+28.7	+8.02	+16.4	+0.0	+0.0000
	+75.5	+0.0	+31.4	+41.2	+2.93	+4.60	+2.571	+17.689
100	+21.3	+24.7	-210.2	+24.7	+7.12	+14.2	+0.0	+0.0000
	+72.7	+0.0	+32.8	+42.9	+3.05	+9.20	+2.436	+17.461
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+30.9	+33.6	-77.2	+33.6	+9.48	+21.4	+0.0	+0.0000
	+69.1	+0.0	+31.0	+36.6	+1.48	+0.00	+1.250	+8.010
50	+24.2	+25.9	-77.4	+25.9	+7.64	+16.5	+0.0	+0.0000
	+75.8	+0.0	+34.0	+40.1	+1.67	+8.77	+1.071	+7.523
100	+17.2	+18.3	-77.6	+18.3	+5.80	+11.4	+0.0	+0.0000
	+82.7	+0.1	+37.2	+43.7	+1.86	+17.53	+0.916	+7.023
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+33.2	+34.4	-12.3	+34.4	+9.76	+23.4	+0.0	+0.0000
	+66.8	+0.0	+31.1	+34.9	+0.81	+0.00	+0.534	+3.337
50	+23.4	+24.0	-12.5	+24.0	+7.23	+16.2	+0.0	+0.0000
	+76.6	+0.0	+35.6	+39.9	+1.05	+11.88	+0.368	+2.635
100	+13.3	+13.5	-12.7	+13.5	+4.67	+8.7	+0.0	+0.0000
	+86.6	+0.0	+40.3	+45.0	+1.28	+23.76	+0.236	+1.912
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+34.3	+35.0	+12.1	+35.0	+9.88	+24.4	+0.0	+0.0000
	+65.7	+0.0	+31.0	+34.1	+0.55	+0.00	+0.263	+1.624
50	+23.0	+23.2	+11.9	+23.2	+7.01	+16.0	+0.0	+0.0000
	+76.9	+0.0	+36.3	+39.8	+0.80	+13.37	+0.113	+0.817
100	+11.6	+11.4	+11.6	+171.2	+4.10	+7.3	+0.2	+0.0013
	+88.4	+0.0	+41.7	+45.6	+1.06	+26.74	+0.000	+0.000
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+35.7	+35.7	+34.8	+35.7	+10.00	+25.7	+0.0	+0.0000
	+64.3	+0.0	+30.8	+33.2	+0.28	+0.00	+3.011	+0.066
50	+34.5	+22.5	+34.5	+366.2	+6.76	+15.2	+12.5	+0.0349
	+65.5	+0.0	+31.2	+33.7	+0.56	+15.02	+0.000	+0.000
100	+34.2	+9.2	+34.2	+134.6	+3.46	+4.6	+26.1	+0.1994
	+65.8	+0.0	+31.2	+33.7	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+55.8	+36.7	+55.8	+616.7	+10.12	+25.7	+20.0	+0.0330
	+44.2	+0.0	+21.4	+22.8	+0.01	+0.00	+0.000	+0.000
50	+55.5	+21.8	+55.5	+356.9	+6.46	+13.8	+35.3	+0.1006
	+44.5	+0.0	+21.4	+22.8	+0.31	+16.85	+0.000	+0.000
100	+55.2	+6.9	+55.2	+97.1	+2.74	+1.9	+50.5	+0.5359
	+44.8	+0.0	+21.4	+22.8	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+651.5	+10.36	+25.2	+65.0	+0.1013
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+326.3	+5.75	+10.3	+84.1	+0.2622
	-0.2	-0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.3000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+167.9	+39.6	+167.9	+672.9	+10.67	+23.1	+134.1	+0.2025
	-67.9	+0.0	-33.1	-33.6	-1.19	+0.00	+0.000	+0.000
50	+167.4	+15.2	+167.4	+246.2	+4.58	+3.6	+159.2	+0.6591
	-67.4	+0.0	-33.1	-33.6	-0.75	+27.67	+0.000	+0.000
100	-180.7	-180.7	+167.0	-180.7	-1.74	+0.0	-178.9	+1.0000
	-67.0	+347.7	-33.1	-33.6	-0.29	+55.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+351.9	+41.1	+351.9	+688.9	+11.45	+15.4	+325.0	+0.1797
	-251.9	+0.0	-127.5	-121.6	-2.79	+0.00	+0.000	+0.000
50	-98.7	-98.7	+351.2	-98.7	+0.12	+0.0	-98.8	+1.0000
	-251.2	+449.8	-127.5	-121.6	-2.08	+51.07	+0.000	+0.000

TABLE A-4 (CONCLUDED)

RH% SEHET	LAHET SEHET	LHMIN STØRE	LREQD RADHT	LHMAX CØVSØ	LHRES CØRES	LHDSØ PMMHG	LHWSØ CLØSR	WETLR CLØDT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+25.0	+32.0	-339.4	+32.0	+8.41	+16.5	+0.0	+0.0000
	+74.9	+0.0	+28.8	+42.1	+4.12	+0.00	+4.170	+27.982
50	+23.7	+30.1	-339.4	+30.1	+8.01	+15.7	+0.0	+0.0000
	+76.3	+0.1	+29.3	+42.8	+4.21	+2.29	+4.082	+27.889
100	+22.3	+28.1	-339.5	+28.1	+7.61	+14.7	+0.0	+0.0000
	+77.7	+0.0	+29.8	+43.6	+4.29	+4.58	+3.995	+27.792
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+29.1	+33.1	-143.7	+33.1	+9.20	+19.9	+0.0	+0.0000
	+70.8	+0.0	+30.6	+38.1	+2.14	+0.00	+1.984	+12.921
50	+24.5	+27.5	-143.9	+27.5	+7.90	+16.6	+0.0	+0.0000
	+75.5	+0.0	+32.6	+40.6	+2.29	+6.39	+1.815	+12.588
100	+19.8	+21.9	-144.1	+21.9	+6.59	+13.2	+0.0	+0.0000
	+80.2	+0.0	+34.7	+43.1	+2.45	+12.78	+1.662	+12.245
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+32.2	+34.0	-37.8	+34.0	+9.65	+22.5	+0.0	+0.0000
	+67.8	+0.0	+31.1	+35.6	+1.08	+0.00	+0.816	+5.158
50	+23.8	+24.8	-38.0	+24.8	+7.42	+16.3	+0.0	+0.0000
	+76.2	+0.0	+35.0	+40.0	+1.29	+10.53	+0.641	+4.549
100	+15.1	+15.5	-38.2	+15.5	+5.16	+9.9	+0.0	+0.0000
	+84.9	+0.0	+39.0	+44.4	+1.51	+21.07	+0.497	+3.925
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+45.4	+36.2	+45.4	+606.8	+10.06	+25.7	+9.7	+0.0162
	+54.6	+0.0	+26.3	+28.2	+0.15	+0.00	+0.000	+0.000
50	+45.1	+22.1	+45.1	+361.5	+6.62	+14.5	+24.0	+0.0677
	+54.9	+0.0	+26.3	+28.2	+0.43	+15.91	+0.000	+0.000
100	+44.8	+8.1	+44.8	+116.1	+3.11	+3.3	+38.4	+0.3402
	+55.2	+0.0	+26.3	+28.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+77.1	+37.6	+77.1	+636.0	+10.24	+25.6	+41.3	+0.0660
	+22.9	+0.0	+11.3	+11.9	+0.25	+0.00	+0.300	+0.000
50	+76.8	+21.0	+76.8	+345.1	+6.13	+12.3	+58.4	+0.1722
	+23.2	+0.0	+11.3	+11.9	+0.07	+18.87	+0.000	+0.000
100	+54.2	+4.2	+76.4	+54.2	+1.92	+0.0	+52.2	+1.0000
	+23.6	+22.3	+11.3	+11.9	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+126.2	+39.0	+126.2	+662.4	+10.48	+24.5	+91.2	+0.1399
	+26.2	+0.0	+12.5	+12.9	+0.78	+0.00	+0.000	+0.000
50	+125.8	+18.2	+125.8	+299.5	+5.33	+7.9	+112.6	+0.3827
	+25.8	+0.0	+12.5	+12.9	+0.40	+23.54	+0.000	+0.000
100	+63.6	+63.6	+125.4	+63.6	+0.00	+0.0	+63.6	+1.0000
	+25.4	+189.1	+12.5	+12.9	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+242.1	+40.4	+242.1	+682.3	+10.99	+20.1	+210.9	+0.3142
	+142.1	+0.0	+70.6	+69.7	+1.85	+0.00	+0.000	+0.000
50	+127.9	+8.5	+241.5	+127.9	+3.05	+0.0	+124.9	+1.0030
	+141.5	+113.6	+70.6	+69.7	+1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+319.9	+40.9	+319.9	+687.4	+11.31	+16.8	+291.8	+0.4316
	+219.9	+0.0	+110.7	+106.7	+2.52	+0.00	+0.000	+0.000
50	+26.2	+26.2	+319.3	+26.2	+1.06	+0.0	+27.3	+1.0000
	+219.3	+345.5	+110.7	+106.7	+1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+483.5	+41.8	+483.5	+693.0	+12.00	+9.6	+461.9	+0.6783
	+383.5	+0.0	+198.0	+181.7	+3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+656.4	+42.6	+656.4	+696.2	+12.71	+1.8	+641.9	+0.9391
	+556.4	+0.0	+294.0	+257.2	+5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+698.5	+43.4	+698.5	+698.5	+13.47	+0.0	+685.0	+1.0000
	+738.5	+140.1	+399.1	+332.9	+6.57	+0.00	+0.000	+0.000

TABLE A-5
METABOLIC PARAMETERS, SET 4

RH%	LANET SENET	LHMIN STØRE	LREQD RADHT	LHMAX CØNSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+27.7	+32.6	-184.9	+32.6	+8.93	+18.7	+0.0	+0.0000
	+72.3	+0.0	+32.9	+36.6	+2.80	+0.00	+2.660	+17.523
50	+24.5	+28.7	-185.0	+28.7	+8.02	+16.5	+0.0	+0.0000
	+75.4	+0.0	+34.3	+38.2	+2.93	+4.60	+2.514	+17.278
100	+21.3	+24.7	-185.1	+24.7	+7.12	+14.2	+0.0	+0.0000
	+78.6	+0.0	+35.8	+39.8	+3.05	+9.20	+2.377	+17.026
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+31.0	+33.6	-63.2	+33.6	+9.48	+21.5	+0.0	+0.0000
	+69.0	+0.0	+33.7	+33.8	+1.48	+0.00	+1.191	+7.618
50	+24.3	+25.9	-63.4	+25.9	+7.64	+16.5	+0.0	+0.0000
	+75.7	+0.0	+37.0	+37.0	+1.67	+8.77	+1.010	+7.087
100	+17.3	+18.3	-63.6	+18.3	+5.80	+11.5	+0.0	+0.0000
	+82.7	+0.0	+40.5	+40.4	+1.36	+17.53	+0.853	+6.535
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+33.3	+34.4	-3.5	+34.4	+9.76	+23.6	+0.0	+0.0000
	+66.7	+0.0	+33.7	+32.1	+0.81	+0.00	+0.472	+2.946
50	+23.5	+24.0	-3.7	+24.0	+7.23	+16.3	+0.0	+0.0000
	+76.5	+0.0	+38.7	+36.7	+1.05	+11.88	+0.305	+2.178
100	+13.4	+13.5	-3.9	+13.5	+4.67	+8.7	+0.0	+0.0000
	+86.6	+0.0	+43.8	+41.5	+1.28	+23.76	+0.171	+1.785
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+34.5	+35.0	+19.0	+35.0	+9.88	+24.6	+0.0	+0.0000
	+65.5	+0.0	+33.6	+31.4	+0.55	+0.00	+0.201	+1.238
50	+23.1	+23.2	+18.7	+23.2	+7.01	+16.1	+0.0	+0.0000
	+76.8	+0.0	+39.4	+36.6	+0.80	+13.37	+0.049	+0.355
100	+18.5	+11.4	+18.5	+146.2	+4.10	+6.9	+7.4	+0.0523
	+81.5	+0.0	+41.7	+38.8	+1.06	+26.74	+0.000	+0.000
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+39.8	+35.7	+39.8	+509.6	+10.00	+25.5	+4.3	+0.0087
	+60.2	+0.0	+31.2	+28.7	+0.28	+0.00	+0.000	+0.000
50	+39.5	+22.5	+39.5	+312.3	+6.76	+14.8	+18.0	+0.0589
	+60.5	+0.0	+31.2	+28.7	+0.56	+15.02	+0.000	+0.000
100	+39.3	+9.2	+39.3	+114.9	+3.46	+4.1	+31.7	+0.2844
	+60.7	+0.0	+31.2	+28.7	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+59.2	+36.7	+59.2	+525.7	+10.12	+25.3	+23.8	+0.0462
	+40.8	+0.0	+21.4	+19.4	+0.01	+0.00	+0.000	+0.000
50	+58.9	+21.8	+58.9	+304.3	+6.46	+13.3	+39.1	+0.1314
	+41.1	+0.0	+21.4	+19.4	+0.31	+16.85	+0.000	+0.000
100	+58.6	+6.9	+58.6	+82.9	+2.74	+1.3	+54.6	+0.6806
	+41.4	+0.0	+21.4	+19.4	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+555.3	+10.36	+24.7	+65.5	+0.1202
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+278.2	+5.75	+9.7	+84.7	+0.3110
	-0.2	+0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.0000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+162.6	+39.6	+162.8	+573.5	+10.67	+22.3	+129.9	+0.2308
	-62.8	+0.0	-33.1	-28.5	-1.19	+0.00	+0.000	+0.000
50	+162.4	+15.2	+162.4	+210.0	+4.58	+2.6	+155.2	+0.7559
	-62.4	+0.0	-33.1	-28.5	-0.75	+27.67	+0.000	+0.000
100	-153.9	-153.9	+161.9	-153.9	-1.74	+0.0	-152.1	+1.0000
	-61.9	+315.8	-33.1	-28.5	-0.29	+55.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+333.6	+41.1	+333.6	+587.3	+11.45	+13.8	+308.4	+0.5356
	-233.6	+0.0	-127.5	-103.4	-2.79	+0.00	+0.000	+0.000
50	-83.9	-83.9	+332.9	-83.9	+0.12	+0.0	-84.0	+1.0000
	-232.9	+416.8	-127.5	-103.4	-2.08	+51.07	+0.000	+0.000

TABLE A-5 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX C0VSX	LHRES C0RES	LHDSK PMMHG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+25.1	+32.0	-303.0	+32.0	+8.41	+16.7	+0.0	+0.0000
	+74.9	+0.0	+31.6	+39.2	+4.12	+0.00	+4.116	+27.593
50	+23.7	+30.1	-303.1	+30.1	+8.01	+15.7	+0.0	+0.0000
	+76.2	+0.0	+32.2	+39.9	+4.21	+2.29	+4.026	+27.489
100	+22.3	+28.1	-303.2	+28.1	+7.61	+14.7	+0.0	+0.0000
	+77.7	+0.0	+32.8	+40.6	+4.29	+4.58	+3.939	+27.379
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+29.2	+33.1	-124.2	+33.1	+9.20	+20.0	+0.0	+0.0000
	+70.8	+0.0	+33.4	+35.3	+2.14	+0.00	+1.926	+12.528
50	+24.6	+27.5	-124.4	+27.5	+7.90	+16.7	+0.0	+0.0000
	+75.4	+0.0	+35.6	+37.5	+2.29	+6.39	+1.756	+12.165
100	+19.8	+21.9	-124.6	+21.9	+6.59	+13.2	+0.0	+0.0000
	+80.2	+0.0	+37.9	+39.8	+2.45	+12.78	+1.601	+11.789
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+32.3	+34.0	-27.0	+34.0	+9.65	+22.7	+0.0	+0.0000
	+67.6	+0.0	+33.7	+32.8	+1.08	+0.00	+0.756	+4.769
50	+23.8	+24.8	-27.2	+24.8	+7.42	+16.4	+0.0	+0.0000
	+76.1	+0.0	+38.0	+36.8	+1.29	+10.53	+0.579	+4.103
100	+15.1	+15.5	-27.4	+15.5	+5.16	+9.9	+0.0	+0.0000
	+84.9	+0.0	+42.4	+41.0	+1.51	+21.07	+0.432	+3.413
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+49.6	+36.2	+49.6	+517.3	+10.06	+25.4	+14.2	+0.0280
	+50.4	+0.0	+26.3	+24.0	+0.15	+0.00	+0.000	+0.000
50	+49.3	+22.1	+49.3	+308.3	+6.62	+14.1	+28.7	+0.0951
	+50.7	+0.0	+26.3	+24.0	+0.43	+15.91	+0.000	+0.000
100	+49.0	+8.1	+49.0	+99.2	+3.11	+2.7	+43.2	+0.4499
	+51.0	+0.0	+26.3	+4.0	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+78.9	+37.6	+78.9	+542.2	+10.24	+25.1	+43.5	+0.0818
	+21.1	+0.0	+11.3	+10.1	+0.25	+0.00	+0.000	+0.000
50	+78.6	+21.0	+78.6	+294.3	+6.13	+11.7	+60.7	+0.2107
	+21.4	+0.0	+11.3	+10.1	+0.07	+18.87	+0.000	+0.000
100	+46.3	+4.2	+78.2	+46.3	+1.92	+0.0	+44.4	+1.0000
	+21.8	+31.9	+11.3	+10.1	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+124.3	+39.0	+124.3	+564.6	+10.48	+23.9	+89.9	+0.1623
	+24.3	+0.0	-12.5	-11.0	+0.78	+0.00	+0.000	+0.000
50	+123.9	+18.2	+123.9	+255.4	+5.33	+7.1	+111.5	+0.4458
	+23.9	+0.0	-12.5	-11.0	+0.40	+23.54	+0.000	+0.000
100	+54.1	+54.1	+123.5	+54.1	+0.00	+0.0	+54.1	+1.0000
	+23.5	+177.6	-12.5	-11.0	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+231.6	+40.4	+231.6	+581.6	+10.99	+19.0	+201.6	+0.3534
	+131.6	+0.0	-70.6	-59.2	-1.85	+0.00	+0.000	+0.000
50	+109.1	+8.5	+231.1	+109.2	+3.05	+0.0	+106.2	+1.0000
	+131.1	+121.9	-70.6	-59.2	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+303.9	+40.9	+303.9	+586.0	+11.31	+15.3	+277.3	+0.4825
	+203.9	+0.0	-110.7	-90.7	-2.52	+0.00	+0.000	+0.000
50	+22.1	+22.1	+303.3	-22.1	+1.06	+0.0	+23.2	+1.0000
	+203.3	+325.4	-110.7	-90.7	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+450.3	+41.8	+456.3	+590.9	+12.00	+7.3	+437.0	+0.7543
	+356.3	+0.0	-198.0	-154.4	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+593.7	+42.6	+617.8	+593.7	+12.71	+0.0	+581.0	+1.0000
	+517.8	+24.1	-294.0	-218.6	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+595.7	+40.4	+788.6	+595.7	+13.47	+0.0	+582.2	+1.0000
	+61.6	+192.9	-399.1	-282.9	-6.57	+0.00	+0.000	+0.000

TABLE A-6
METABOLIC PARAMETERS, SET 5

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CØNSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+27.5	+32.6	-251.8	+32.6	+8.93	+18.5	+0.0	+0.0000
	+72.5	+0.0	+26.3	+43.3	+2.80	+0.00	+2.791	+18.433
50	+24.4	+28.7	-251.9	+28.7	+8.02	+16.3	+0.0	+0.0000
	+75.6	+0.0	+27.5	+45.2	+2.93	+4.60	+2.647	+18.238
100	+21.2	+24.7	-252.0	+24.7	+7.12	+14.1	+0.0	+0.0000
	+78.8	+0.0	+28.7	+47.1	+3.05	+9.20	+2.514	+18.042
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+30.8	+33.6	-100.6	+33.6	+9.48	+21.3	+0.0	+0.0000
	+69.2	+0.0	+27.3	+40.4	+1.48	+0.00	+1.330	+8.535
50	+24.0	+25.9	-100.8	+25.9	+7.64	+16.4	+0.0	+0.0000
	+75.9	+0.0	+30.0	+44.3	+1.67	+8.77	+1.152	+8.111
100	+17.1	+18.3	-100.9	+18.3	+5.80	+11.3	+0.0	+0.0000
	+82.9	+0.0	+32.7	+48.3	+1.86	+17.53	+1.000	+7.672
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+33.0	+34.4	-26.9	+34.4	+9.76	+23.2	+0.0	+0.0000
	+67.0	+0.0	+27.5	+38.7	+0.81	+0.00	+0.616	+3.861
50	+23.3	+24.0	-27.1	+24.0	+7.23	+16.0	+0.0	+0.0000
	+76.7	+0.0	+31.5	+44.2	+1.05	+11.88	+0.453	+3.249
100	+13.3	+13.5	-27.3	+13.5	+4.67	+8.6	+0.0	+0.0000
	+86.7	+0.0	+35.6	+49.8	+1.28	+23.76	+0.323	+2.617
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+34.1	+35.0	+0.7	+35.0	+9.88	+24.3	+0.0	+0.0000
	+65.8	+0.0	+27.4	+37.9	+0.55	+0.00	+0.347	+2.148
50	+22.9	+23.2	+0.5	+23.2	+7.01	+15.9	+0.0	+0.0000
	+77.1	+0.0	+32.1	+44.2	+0.80	+13.37	+0.199	+1.440
100	+11.3	+11.4	+0.2	+11.4	+4.10	+7.2	+0.0	+0.0000
	+88.6	+0.0	+36.9	+50.6	+1.06	+26.74	+0.086	+0.717
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+35.5	+35.7	+26.3	+35.7	+10.00	+25.5	+0.0	+0.0000
	+64.5	+0.0	+27.3	+36.9	+0.28	+0.00	+0.096	+0.586
50	+26.0	+22.5	+27.0	+456.1	+6.76	+15.6	+3.7	+0.0082
	+74.0	+0.0	+31.2	+42.2	+0.56	+15.02	+0.000	+0.000
100	+25.8	+9.2	+25.8	+167.4	+3.46	+5.1	+17.2	+0.1048
	+74.2	+0.0	+31.2	+42.2	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+50.1	+36.7	+50.1	+768.3	+10.12	+26.0	+13.9	+0.0184
	+49.9	+0.0	+21.4	+28.5	+0.01	+0.00	+0.000	+0.000
50	+49.8	+21.8	+49.8	+444.5	+6.46	+14.3	+29.0	+0.0663
	+50.2	+0.0	+21.4	+28.5	+0.31	+16.85	+0.000	+0.000
100	+49.5	+6.9	+49.5	+120.6	+2.74	+2.6	+44.2	+0.3747
	+50.5	+0.0	+21.4	+28.5	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+811.8	+10.36	+25.8	+64.4	+0.0803
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+406.5	+5.75	+11.1	+83.3	+0.2079
	-0.2	-0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.0000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+176.3	+39.6	+176.3	+838.4	+10.67	+24.0	+141.6	+0.1710
	-76.3	-0.0	-33.1	-41.9	-1.19	+0.00	+0.000	+0.000
50	+175.8	+15.2	+175.8	+306.6	+4.58	+4.7	+166.5	+0.5513
	-75.8	+0.0	-33.1	-41.9	-0.75	+27.67	+0.000	+0.000
100	-225.4	-225.4	+175.4	-225.4	-1.74	+0.0	-223.7	+1.0000
	-75.4	+400.8	-33.1	-41.9	-0.29	+5.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+382.3	+41.1	+382.3	+858.3	+11.45	+17.3	+353.6	+0.4175
	-282.3	+0.0	-127.5	-152.0	-2.79	+0.00	+0.000	+0.000
50	-123.4	-123.4	+381.6	-123.4	+0.12	+0.0	-123.5	+1.0000
	-281.6	+504.9	-127.5	-152.0	-2.08	+51.07	+0.000	+0.000

TABLE A-6 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CØNSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+25.0	+32.0	-399.9	+32.0	+8.41	+16.5	+0.0	+0.0000
	+75.0	+0.0	+25.0	+45.9	+4.12	+0.00	+4.242	+28.497
50	+23.6	+30.1	-400.0	+30.1	+8.01	+15.6	+0.0	+0.0000
	+76.4	+0.0	+25.5	+46.7	+4.21	+2.29	+4.154	+28.414
100	+22.2	+28.1	-400.1	+28.1	+7.61	+14.6	+0.0	+0.0000
	+77.8	+0.0	+26.0	+47.5	+4.29	+4.58	+4.068	+28.331
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+29.0	+33.1	-176.2	+33.1	+9.20	+19.8	+0.0	+0.0000
	+71.0	+0.0	+26.9	+42.0	+2.14	+0.00	+2.060	+13.442
50	+24.4	+27.5	-176.4	+27.5	+7.90	+16.5	+0.0	+0.0000
	+75.6	+0.0	+28.7	+44.7	+2.29	+6.39	+1.894	+13.153
100	+19.7	+21.9	-176.6	+21.9	+6.59	+13.1	+0.0	+0.0000
	+80.3	+0.0	+30.5	+47.4	+2.45	+12.78	+1.743	+12.858
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+32.0	+34.0	-55.8	+34.0	+9.65	+22.4	+0.0	+0.0000
	+67.9	+0.0	+27.4	+39.4	+1.08	+0.00	+0.897	+5.684
50	+23.6	+24.8	-56.0	+24.8	+7.42	+16.2	+0.0	+0.0000
	+76.3	+0.0	+30.8	+44.2	+1.29	+10.53	+0.725	+5.154
100	+15.0	+15.5	-56.3	+15.5	+5.16	+9.8	+0.0	+0.0000
	+85.0	+0.0	+34.4	+49.1	+1.51	+21.07	+0.582	+4.605
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+38.4	+36.2	+38.4	+756.0	+10.06	+26.0	+2.3	+0.0030
	+61.6	+0.0	+26.3	+35.2	+0.15	+0.00	+0.000	+0.000
50	+38.1	+22.1	+38.1	+450.2	+6.62	+14.9	+16.5	+0.0372
	+61.9	+0.0	+26.3	+35.2	+0.43	+15.91	+0.000	+0.000
100	+37.8	+8.1	+37.8	+144.4	+3.11	+3.9	+30.8	+0.2180
	+62.2	+0.0	+26.3	+35.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+74.1	+37.6	+74.1	+792.5	+10.24	+26.1	+37.8	+0.0484
	+25.9	+0.0	+11.3	+14.8	-0.25	+0.00	+0.000	+0.000
50	+73.8	+21.0	+73.8	+429.9	+6.13	+12.9	+54.8	+0.1292
	+26.2	+0.0	+11.3	+14.8	+0.07	+18.87	+0.000	+0.000
100	+67.2	+4.2	+73.5	+67.2	+1.92	+0.0	+65.3	+1.0000
	+26.5	+6.2	+11.3	+14.8	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+129.5	+39.0	+129.5	+825.4	+10.48	+25.2	+93.7	+0.1150
	-29.5	+0.0	-12.5	-16.1	-0.16	+0.00	+0.000	+0.000
50	+129.1	+18.2	+129.1	+373.0	+5.33	+8.8	+114.9	+0.3125
	-29.1	+0.0	-12.5	-16.1	-0.40	+23.54	+0.000	+0.000
100	-79.5	-79.5	+128.7	-79.5	+0.00	+0.0	-79.5	+1.0000
	-28.7	+208.2	-12.5	-16.1	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+259.5	+40.4	+259.5	+850.1	+10.99	+21.4	+227.1	+0.2706
	-159.5	+0.0	-70.6	-87.1	-1.85	+0.00	+0.000	+0.000
50	+159.2	+8.5	+259.0	+159.2	+3.05	+0.0	+156.1	+1.0000
	-159.0	+99.8	-70.6	-87.1	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+346.6	+40.9	+346.6	+856.5	+11.31	+18.5	+316.8	+0.3748
	-246.6	+0.0	-110.7	-133.3	-2.52	+0.00	+0.000	+0.000
50	-33.0	-33.0	+346.0	-33.0	+1.06	+0.0	-34.1	+1.0000
	-246.0	+379.0	-110.7	-133.3	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.91 MMHG								
0	+528.9	+41.8	+528.9	+863.3	+12.00	+12.1	+504.8	+0.5930
	-428.9	+0.0	-178.0	-227.1	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+720.7	+42.6	+720.7	+867.1	+12.71	+5.3	+702.7	+0.8224
	-620.7	+0.0	-294.0	-321.5	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+869.7	+43.4	+921.7	+869.7	+13.47	+0.0	+856.2	+1.0000
	-821.7	+52.0	-399.1	-416.1	-6.57	+0.00	+0.000	+0.000

TABLE A-7
METABOLIC PARAMETERS, SET 6

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LIMAX CNSK	LHRES CORES	LHDSK PMMHG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+27.3	+32.6	-335.4	+32.6	+8.93	+18.4	+0.0	+0.0000
	+72.6	+0.0	+21.1	+48.8	+2.80	+0.00	+2.894	+19.157
50	+24.2	+28.7	-335.5	+28.7	+8.02	+16.2	+0.0	+0.0000
	+75.8	+0.0	+22.0	+50.8	+2.93	+4.60	+2.753	+19.003
100	+21.1	+24.7	-335.6	+24.7	+7.12	+13.9	+0.0	+0.0000
	+78.9	+0.0	+22.9	+52.9	+3.05	+9.20	+2.622	+18.846
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+30.6	+33.6	-147.3	+33.6	+9.48	+21.1	+0.0	+0.0000
	+69.4	+0.1	+22.0	+45.9	+1.48	+0.00	+1.441	+9.278
50	+23.9	+25.9	-147.5	+25.9	+7.64	+16.2	+0.0	+0.0000
	+76.1	+0.0	+24.2	+50.3	+1.67	+8.77	+1.267	+8.938
100	+17.0	+18.3	-147.7	+18.3	+5.80	+11.2	+0.0	+0.0000
	+83.0	+0.0	+26.4	+54.7	+1.86	+17.53	+1.118	+8.591
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+32.8	+34.4	-56.1	+34.4	+9.76	+23.0	+0.0	+0.0000
	+67.2	+0.0	+22.3	+44.1	+0.81	+0.00	+0.732	+4.607
50	+23.1	+24.0	-56.4	+24.0	+7.23	+15.9	+0.0	+0.0000
	+76.9	+0.1	+25.5	+50.3	+1.05	+11.88	+0.573	+4.120
100	+13.2	+13.5	-56.6	+13.5	+4.67	+8.5	+0.0	+0.0000
	+86.8	+0.1	+28.8	+56.7	+1.28	+23.76	+0.446	+3.617
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+33.9	+35.0	-22.1	+35.0	+9.88	+24.0	+0.0	+0.0000
	+66.1	+0.0	+22.3	+43.3	+0.55	+0.00	+0.465	+2.892
50	+22.7	+23.2	-22.3	+23.2	+7.01	+15.7	+0.0	+0.0000
	+77.3	+0.0	+26.1	+50.4	+0.80	+13.37	+0.321	+2.328
100	+11.3	+11.4	-22.6	+11.4	+4.10	+7.2	+0.0	+0.0000
	+88.7	+0.0	+29.9	+57.7	+1.06	+26.74	+0.210	+1.748
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+35.2	+35.7	+9.5	+35.7	+10.00	+25.2	+0.0	+0.0000
	+64.8	+0.0	+22.2	+42.3	+0.28	+0.00	+0.217	+1.326
50	+22.3	+22.5	+9.2	+22.5	+6.76	+15.6	+0.0	+0.0000
	+77.7	+0.0	+26.6	+50.5	+0.56	+15.02	+0.093	+0.678
100	+9.2	+9.2	+8.9	+9.2	+3.46	+5.7	+0.0	+0.0000
	+90.8	+0.0	+31.1	+58.8	+0.84	+30.04	+0.002	+0.017
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+38.7	+36.7	+38.7	+1071.6	+10.12	+26.5	+2.1	+0.0020
	+61.3	+0.0	+21.4	+39.9	+0.01	+0.00	+0.000	+0.000
50	+38.4	+21.8	+38.4	+619.7	+6.46	+14.9	+17.0	+0.0276
	+61.6	+0.0	+21.4	+39.9	+0.31	+16.85	+0.000	+0.000
100	+38.1	+6.9	+38.1	+167.8	+2.74	+3.3	+32.0	+0.1941
	+61.9	+0.0	+21.4	+39.9	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
	+100.5	+38.4	+100.5	+1132.4	+10.36	+26.5	+63.7	+0.0568
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+15.8	+100.2	+566.8	+5.75	+12.0	+82.4	+0.1470
	-0.2	-0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.0000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+193.0	+39.6	+193.0	+1169.5	+10.67	+25.0	+157.3	+0.1358
	-93.0	+0.0	-33.1	-58.7	-1.19	+0.00	+0.000	+0.000
50	+192.6	+15.2	+192.6	+427.4	+4.58	+6.0	+182.0	+0.4304
	-92.6	+0.0	-33.1	-58.7	-0.75	+27.67	+0.000	+0.000
100	-314.9	-314.9	+192.1	-314.9	-1.74	+0.0	-313.2	+1.0000
	-92.1	+507.1	-33.1	-58.7	-0.29	+55.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+443.1	+41.1	+443.1	+1197.0	+11.45	+19.3	+412.3	+0.3478
	-343.1	+0.0	-127.5	-212.8	-2.79	+0.00	+0.000	+0.000
50	-172.8	-172.8	+442.4	-172.8	+0.12	+0.0	-172.9	+1.0000
	-342.4	+615.1	-127.5	-212.8	-2.08	+51.07	+0.000	+0.000

TABLE A-7 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CONS	LHRES CORES	LHDSK PMMHG	LHWSK CLSR	WTLR CLDT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+24.8	+32.0	-521.1	+32.0	+8.41	+16.4	+0.0	+0.0000
	+75.1	+0.1	+19.8	+51.1	+4.12	+0.00	+4.340	+29.207
50	+23.5	+30.1	-521.2	+30.1	+8.01	+15.5	+0.0	+0.0000
	+76.4	+0.1	+20.2	+52.0	+4.21	+2.29	+4.254	+29.143
100	+22.1	+28.1	-521.3	+28.1	+7.61	+14.5	+0.0	+0.0000
	+77.9	+0.0	+20.6	+53.0	+4.29	+4.58	+4.169	+29.076
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+28.8	+33.1	-241.2	+33.1	+9.20	+19.6	+0.0	+0.0000
	+71.2	+0.0	+21.6	+47.4	+2.14	+0.00	+2.167	+14.175
50	+24.2	+27.5	-241.4	+27.5	+7.90	+16.3	+0.0	+0.0000
	+75.7	+0.1	+23.0	+50.4	+2.29	+6.39	+2.004	+13.948
100	+19.5	+21.9	-241.6	+21.9	+6.59	+13.0	+0.0	+0.0000
	+80.4	+0.0	+24.5	+53.5	+2.45	+12.78	+1.855	+13.712
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+31.8	+34.0	-91.9	+34.0	+9.65	+22.1	+0.0	+0.0000
	+68.2	+0.0	+22.2	+44.9	+1.08	+0.00	+1.011	+6.427
50	+23.4	+24.8	-92.1	+24.8	+7.42	+16.0	+0.0	+0.0000
	+76.5	+0.0	+25.0	+50.3	+1.29	+10.53	+0.842	+6.005
100	+14.9	+15.5	-92.3	+15.5	+5.16	+9.7	+0.0	+0.0000
	+75.1	+0.0	+27.8	+55.8	+1.51	+21.07	+0.703	+5.571
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+35.9	+36.2	+24.3	+36.2	+10.06	+25.9	+0.0	+0.0000
	+64.1	+0.0	+22.2	+41.7	+0.15	+0.00	+0.099	+0.600
50	+24.0	+22.1	+24.0	+627.7	+6.62	+15.5	+1.9	+0.0030
	+76.0	+0.0	+26.3	+49.3	+0.43	+15.91	+0.000	+0.000
100	+23.7	+8.1	+23.7	+200.9	+3.11	+4.5	+16.0	+0.0810
	+76.3	+0.0	+26.3	+49.3	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+68.2	+37.6	+68.2	+1105.4	+10.24	+26.6	+31.4	+0.0286
	+31.8	+0.0	+11.3	+20.8	-0.25	+0.00	+0.000	+0.000
50	+67.9	+21.0	+67.9	+599.4	+6.13	+13.6	+48.1	+0.0811
	+32.1	+0.0	+11.3	+20.8	+0.07	+18.87	+0.000	+0.000
100	+67.5	+4.2	+67.5	+93.4	+1.92	+0.7	+65.0	+0.7104
	+32.5	+0.0	+11.3	+20.8	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+135.9	+39.0	+135.9	+1151.4	+10.48	+26.0	+99.4	+0.0871
	-35.9	+0.0	-12.5	-22.6	-0.78	+0.00	+0.000	+0.000
50	+135.5	+18.2	+135.5	+520.1	+5.33	+9.9	+120.3	+0.2338
	-35.5	+0.0	-12.5	-22.6	-0.40	+23.54	+0.000	+0.000
100	-111.3	-111.3	+135.1	-111.3	+0.00	+0.0	-111.3	+1.0900
	-35.1	+246.5	-12.5	-22.6	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+294.3	+40.4	+294.3	+1185.8	+10.99	+22.9	+260.5	+0.2217
	-194.3	+0.0	-70.6	-121.9	-1.85	+0.00	+0.000	+0.000
50	+221.6	+8.5	+293.8	+221.6	+3.05	+0.0	+218.6	+1.0000
	-193.8	+72.2	-70.6	-121.9	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+399.9	+40.9	+399.9	+1194.6	+11.31	+20.4	+368.3	+0.3112
	-299.9	+0.0	-110.7	-186.7	-2.52	+0.00	+0.000	+0.000
50	-46.7	-46.7	+399.3	-46.7	+1.06	+0.0	-47.7	+1.0000
	-299.3	+446.0	-110.7	-186.7	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+619.8	+41.8	+619.8	+1203.8	+12.00	+15.0	+592.8	+0.4974
	-519.8	+0.0	-198.0	-317.9	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+849.3	+42.6	+849.3	+1208.9	+12.71	+9.2	+827.4	+0.6917
	-749.3	+0.0	-294.0	-450.0	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+1088.2	+43.4	+1088.2	+1212.2	+13.47	+3.2	+1071.5	+0.8939
	-988.2	+0.0	-399.1	-582.5	-6.57	+0.00	+0.000	+0.000

TABLE A-8

METABOLIC PARAMETERS, SET 7

RH#	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CONSK	LHRES CORES	LHDSK PMMHG	LHWSK CLORS	WETLR CLODT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+28.3	+32.6	-70.0	+32.6	+8.93	+19.4	+0.0	+0.0000
	+71.7	+0.0	+0.0	+68.9	+2.80	+0.00	+2.236	+14.594
50	+25.1	+28.7	-70.1	+28.7	+8.02	+17.1	+0.0	+0.0000
	+74.9	+0.0	+0.0	+71.9	+2.93	+4.60	+2.078	+14.164
100	+21.9	+24.7	-70.3	+24.7	+7.12	+14.8	+0.0	+0.0000
	+78.1	+0.0	+0.0	+75.1	+3.05	+9.20	+1.929	+13.721
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+32.1	+33.6	+5.1	+33.6	+9.48	+22.6	+0.0	+0.0000
	+67.9	+0.0	+0.0	+66.4	+1.48	+0.00	+0.650	+4.091
50	+25.2	+25.9	+4.9	+25.9	+7.64	+17.5	+0.0	+0.0000
	+74.8	+0.0	+0.0	+73.2	+1.67	+8.77	+0.443	+3.074
100	+17.9	+18.3	+4.7	+18.3	+5.80	+12.1	+0.0	+0.0000
	+82.0	+0.0	+0.0	+80.2	+1.86	+17.53	+0.265	+2.015
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+40.7	+34.4	+40.7	+573.7	+9.76	+24.4	+6.5	+0.0116
	+59.3	+0.0	+0.0	+58.5	+0.81	+0.00	+0.000	+0.000
50	+40.4	+24.0	+40.4	+390.6	+7.23	+16.0	+17.2	+0.0449
	+59.6	+0.0	+0.0	+58.5	+1.05	+11.88	+0.000	+0.000
100	+40.2	+13.5	+40.2	+207.5	+4.67	+7.7	+27.9	+0.1375
	+59.8	+0.0	+0.0	+58.5	+1.28	+23.76	+0.000	+0.000
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+53.9	+35.0	+53.9	+583.4	+9.88	+24.2	+19.7	+0.0344
	+46.1	+0.0	+0.0	+45.6	+0.55	+0.00	+0.000	+0.000
50	+53.6	+23.2	+53.6	+377.3	+7.01	+14.8	+31.8	+0.0858
	+46.4	+0.0	+0.0	+45.6	+0.80	+13.37	+0.000	+0.000
100	+53.3	+11.4	+53.3	+171.2	+4.10	+5.4	+43.8	+0.2624
	+46.7	+0.0	+0.0	+45.6	+1.06	+26.74	+0.000	+0.000
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+66.0	+35.7	+66.0	+597.8	+10.00	+24.3	+31.7	+0.0539
	+34.0	+0.0	+0.0	+33.7	+0.28	+0.00	+0.000	+0.000
50	+65.7	+22.5	+65.7	+366.2	+6.76	+13.7	+45.2	+0.1258
	+34.2	+0.0	+0.0	+33.7	+0.56	+15.02	+0.000	+0.000
100	+65.4	+9.2	+65.4	+134.6	+3.46	+3.2	+58.8	+0.4485
	+34.6	+0.0	+0.0	+33.7	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+77.2	+36.7	+77.2	+616.7	+10.12	+24.7	+42.4	+0.0699
	+22.8	+0.0	+0.0	+22.8	+0.01	+0.00	+0.000	+0.000
50	+76.9	+21.8	+76.9	+356.9	+6.45	+12.8	+57.6	+0.1644
	+23.1	+0.0	+0.0	+22.8	+0.31	+16.85	+0.000	+0.000
100	+76.6	+6.9	+76.6	+97.1	+2.74	+0.9	+72.9	+0.7730
	+23.4	+0.0	+0.0	+22.8	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+651.5	+10.36	+25.2	+65.0	+0.1013
	+0.5	+0.0	+0.0	+0.0	+0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+326.3	+5.75	+10.3	+84.1	+0.2622
	+0.2	+0.0	+0.0	+0.0	+0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	+0.0	+1.0000
	+0.2	+98.8	+0.0	+0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+134.7	+39.6	+134.7	+672.9	+10.67	+24.6	+99.5	+0.1502
	+34.7	+0.0	+0.0	+33.6	+1.19	+0.00	+0.000	+0.000
50	+134.3	+15.2	+134.3	+246.2	+4.58	+5.1	+124.6	+0.5157
	+34.3	+0.0	+0.0	+33.6	+0.75	+27.67	+0.000	+0.000
100	+180.7	+180.7	+133.8	+180.7	+1.74	+0.0	+178.9	+1.0000
	+33.8	+314.5	+0.0	+33.6	+0.29	+53.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+224.4	+41.1	+224.4	+688.9	+11.45	+21.3	+191.7	+0.2830
	+124.4	+0.0	+0.0	+121.6	+2.79	+0.00	+0.000	+0.000
50	+98.7	+98.7	+223.7	+98.7	+0.12	+0.0	+98.8	+1.0000
	+123.7	+322.4	+0.0	+121.6	+2.08	+51.07	+0.000	+0.000

TABLE A-8 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CØVSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+25.5	+32.0	-146.5	+32.0	+8.41	+17.1	+0.0	+0.0000
	+74.4	+0.0	+0.0	+70.3	+4.12	+0.00	+3.776	+25.171
50	+24.1	+30.1	-146.6	+30.1	+8.01	+16.1	+0.0	+0.0000
	+75.9	+0.0	+0.0	+71.6	+4.21	+2.29	+3.682	+24.997
100	+22.7	+28.1	-146.6	+28.1	+7.61	+15.1	+0.0	+0.0000
	+77.3	+0.0	+0.0	+73.0	+4.29	+4.58	+3.589	+24.821
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+30.0	+33.1	-32.1	+33.1	+9.20	+20.8	+0.0	+0.0000
	+76.0	+0.0	+0.0	+67.8	+2.14	+0.00	+1.449	+9.311
50	+25.3	+27.5	-32.3	+27.5	+7.90	+17.4	+0.0	+0.0000
	+74.7	+0.0	+0.0	+72.4	+2.29	+6.39	+1.261	+8.647
100	+20.4	+21.9	-32.5	+21.9	+6.59	+13.8	+0.0	+0.0000
	+79.5	+0.0	+0.0	+77.1	+2.45	+12.78	+1.089	+7.958
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+33.6	+34.0	+26.8	+34.0	+9.65	+24.0	+0.0	+0.0000
	+66.4	+0.0	+0.0	+65.3	+1.08	+0.00	+0.169	+1.045
50	+26.6	+24.8	+26.6	+404.7	+7.42	+17.3	+1.8	+0.0046
	+73.4	+0.0	+0.0	+72.1	+1.29	+10.53	+0.000	+0.000
100	+26.3	+15.5	+26.3	+242.4	+5.16	+9.9	+11.3	+0.0476
	+73.7	+0.0	+0.0	+72.1	+1.51	+21.07	+0.000	+0.000
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+71.7	+36.2	+71.7	+606.8	+10.06	+24.5	+37.1	+0.0622
	+28.3	+0.0	+0.0	+28.2	+0.15	+0.00	+0.000	+0.000
50	+71.4	+22.1	+71.4	+361.5	+6.62	+13.3	+51.5	+0.1451
	+28.6	+0.0	+0.0	+28.2	+0.43	+15.91	+0.000	+0.000
100	+71.1	+8.1	+71.1	+116.1	+3.11	+2.1	+65.9	+0.5833
	+28.9	+0.0	+0.0	+28.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+88.4	+37.6	+88.4	+636.0	+10.24	+25.1	+53.1	+0.0848
	+11.6	+0.0	+0.0	+11.9	+0.25	+0.00	+0.000	+0.000
50	+88.1	+21.0	+88.1	+345.1	+6.13	+11.8	+70.2	+0.2070
	+11.9	+0.0	+0.0	+11.9	+0.07	+18.87	+0.000	+0.000
100	+54.2	+4.2	+87.7	+54.2	+1.92	+0.0	+52.2	+1.0000
	+12.3	+33.5	+0.0	+11.9	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+113.7	+39.0	+113.7	+662.4	+10.48	+25.1	+78.1	+0.1198
	+13.7	+0.0	+0.0	+12.9	+0.78	+0.00	+0.000	+0.000
50	+113.3	+18.2	+113.3	+299.5	+5.33	+8.5	+99.5	+0.3381
	+13.3	+0.0	+0.0	+12.9	+0.40	+23.54	+0.000	+0.000
100	+63.6	+63.6	+112.9	+63.6	+0.00	+0.0	+63.6	+1.0000
	+12.9	+176.5	+0.0	+12.9	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+171.5	+40.4	+171.5	+682.3	+10.99	+23.4	+137.2	+0.2043
	+71.5	+0.0	+0.0	+69.7	+1.85	+0.00	+0.000	+0.000
50	+127.9	+8.5	+171.0	+127.9	+3.05	+0.0	+124.9	+1.0000
	+71.0	+43.0	+0.0	+69.7	+1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+209.2	+40.9	+209.2	+687.4	+11.31	+21.9	+176.0	+0.2603
	+109.2	+0.0	+0.0	+106.7	+2.52	+0.00	+0.000	+0.000
50	+26.2	+26.2	+208.5	+26.2	+1.06	+0.0	+27.3	+1.0000
	+108.5	+234.8	+0.0	+106.7	+1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+285.5	+41.8	+285.5	+693.0	+12.00	+18.6	+254.9	+0.3743
	+185.5	+0.0	+0.0	+181.7	+3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+362.4	+42.6	+362.4	+696.2	+12.71	+15.3	+334.4	+0.4892
	+262.4	+0.0	+0.0	+257.2	+5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+439.4	+43.4	+439.4	+698.5	+13.47	+11.9	+414.1	+0.6046
	+339.4	+0.0	+0.0	+332.9	+6.57	+0.00	+0.000	+0.000

TABLE A-9

METABOLIC PARAMETERS, SET 8

RHZ	LAHET SEHET	LHMIN STØRE	LREQD RADHT	LHMAX CØNSK	LHRES CØRES	LHDSK PMMHG	LHWSK CLØSR	WETLR CLØDT
AIR TEMP: +10.00 SKIN: 32.00 C 35.67 MMHG								
0	+27.8	+32.6	-143.7	+32.6	+8.93	+18.9	+0.0	+0.0000
	+72.2	+0.0	+19.4	+50.0	+2.80	+0.00	+2.551	+16.763
50	+24.7	+28.7	-144.0	+28.7	+8.02	+16.7	+0.0	+0.0000
	+75.3	+0.0	+20.3	+52.1	+2.93	+4.60	+2.402	+16.476
100	+21.5	+24.7	-144.2	+24.7	+7.12	+14.4	+0.0	+0.0000
	+78.5	+0.0	+21.2	+54.3	+3.05	+9.20	+2.262	+16.175
AIR TEMP: +20.00 SKIN: 32.29 C 36.26 MMHG								
0	+31.3	+33.6	-37.3	+33.6	+9.48	+21.8	+0.0	+0.0000
	+68.7	+0.0	+20.3	+46.9	+1.48	+0.00	+1.053	+6.705
50	+24.5	+25.9	-37.5	+25.9	+7.64	+16.8	+0.0	+0.0000
	+75.5	+0.0	+22.3	+51.5	+1.67	+8.77	+0.866	+6.038
100	+17.4	+18.3	-37.7	+18.3	+5.80	+11.6	+0.0	+0.0000
	+82.5	+0.0	+24.5	+56.2	+1.86	+17.53	+0.705	+5.387
AIR TEMP: +25.00 SKIN: 32.70 C 37.10 MMHG								
0	+33.7	+34.4	+13.7	+34.4	+9.75	+23.9	+0.0	+0.0000
	+66.3	+0.0	+20.5	+45.0	+0.81	+0.00	+0.315	+1.954
50	+23.8	+24.0	+10.5	+24.0	+7.23	+16.5	+0.0	+0.0000
	+76.2	+0.0	+23.6	+51.6	+1.05	+11.88	+0.142	+1.009
100	+13.5	+13.5	+13.2	+13.5	+4.67	+8.9	+0.0	+0.0000
	+86.4	+0.0	+26.9	+58.3	+1.28	+23.76	+0.004	+0.032
AIR TEMP: +27.00 SKIN: 33.00 C 37.73 MMHG								
0	+34.9	+35.0	+32.7	+35.0	+9.88	+25.0	+0.0	+0.0000
	+65.1	+0.0	+20.4	+44.1	+0.55	+0.00	+0.036	+0.218
50	+32.4	+23.2	+32.4	+37.3	+7.01	+15.8	+9.6	+0.0260
	+67.6	+0.0	+21.2	+45.6	+0.80	+13.37	+0.000	+0.000
100	+32.2	+11.4	+32.2	+171.2	+4.10	+6.4	+21.7	+0.1299
	+67.8	+0.0	+21.2	+45.6	+1.06	+26.74	+0.000	+0.000
AIR TEMP: +29.00 SKIN: 33.44 C 38.67 MMHG								
0	+50.2	+35.7	+50.2	+597.8	+10.00	+25.1	+15.2	+0.0258
	+49.8	+0.0	+15.8	+33.7	+0.28	+0.00	+0.000	+0.000
50	+49.9	+22.5	+49.9	+366.2	+6.76	+14.5	+28.7	+0.0798
	+50.1	+0.0	+15.8	+33.7	+0.56	+15.02	+0.000	+0.000
100	+49.6	+9.2	+49.6	+134.6	+3.46	+3.9	+42.3	+0.3226
	+50.4	+0.0	+15.8	+33.7	+0.84	+30.04	+0.000	+0.000
AIR TEMP: +31.00 SKIN: 34.00 C 39.90 MMHG								
0	+66.4	+36.7	+66.4	+616.7	+10.12	+25.2	+31.1	+0.0513
	+33.6	+0.0	+10.8	+22.8	+0.01	+0.00	+0.000	+0.000
50	+66.1	+21.8	+66.1	+356.9	+6.46	+13.3	+46.3	+0.1323
	+33.9	+0.0	+10.8	+22.8	+0.31	+16.85	+0.000	+0.000
100	+65.8	+6.9	+65.8	+97.1	+2.74	+1.4	+61.6	+0.6536
	+34.2	+0.0	+10.8	+22.8	+0.62	+33.70	+0.000	+0.000
AIR TEMP: +35.00 SKIN: 35.00 C 42.18 MMHG								
0	+100.5	+38.4	+100.5	+651.5	+10.36	+25.2	+65.0	+0.1013
	-0.5	+0.0	-0.0	-0.0	-0.52	+0.00	+0.000	+0.000
50	+100.2	+19.8	+100.2	+326.3	+5.75	+10.3	+84.1	+0.2622
	-0.2	+0.0	-0.0	-0.0	-0.16	+21.09	+0.000	+0.000
100	+1.0	+1.0	+99.8	+1.0	+1.02	+0.0	-0.0	+1.0000
	+0.2	+98.8	-0.0	-0.0	+0.20	+42.18	+0.000	+0.000
AIR TEMP: +40.00 SKIN: 35.58 C 43.56 MMHG								
0	+151.1	+39.6	+151.1	+672.9	+10.67	+23.9	+116.6	+0.1761
	-51.1	+0.0	-16.4	-33.6	-1.19	+0.00	+0.000	+0.000
50	+150.7	+15.2	+150.7	+246.2	+4.58	+4.4	+141.7	+0.5866
	-50.7	+0.0	-16.4	-33.6	-0.75	+27.67	+0.000	+0.000
100	-180.7	-180.7	+150.2	-180.7	-1.74	+0.0	-178.9	+1.0000
	-50.2	+330.9	-16.4	-33.6	-0.29	+55.34	+0.000	+0.000
AIR TEMP: +52.00 SKIN: 36.00 C 44.57 MMHG								
0	+285.7	+41.1	+285.7	+688.9	+11.45	+18.4	+255.8	+0.3776
	-185.7	+0.0	-61.3	-121.6	-2.79	+0.00	+0.000	+0.000
50	-98.7	-98.7	+285.0	-98.7	+0.12	+0.0	-98.8	+1.0000
	-185.0	+383.7	-61.3	-121.6	-2.08	+51.07	+0.000	+0.000

TABLE A-9 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREQD RADHT	LHMAX CANSK	LHRES CORES	LHDSK PMHMG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +3.00 SKIN: 31.89 C 35.44 MMHG								
0	+25.2	+32.0	-250.9	+32.0	+8.41	+16.8	+0.0	+0.0000
	+74.8	+0.0	+18.3	+52.4	+4.12	+0.00	+4.029	+26.775
50	+23.8	+30.1	-251.0	+30.1	+8.01	+15.8	+0.0	+0.0000
	+76.2	+0.0	+18.6	+53.3	+4.21	+2.29	+3.938	+26.852
100	+22.4	+28.1	-251.0	+28.1	+7.61	+14.8	+0.0	+0.0000
	+77.5	+0.0	+18.9	+54.3	+4.29	+4.58	+3.851	+26.731
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+29.4	+33.1	-90.4	+33.1	+9.20	+20.2	+0.0	+0.0000
	+70.6	+0.0	+19.9	+48.5	+2.14	+0.00	+1.804	+11.696
50	+24.8	+27.5	-90.5	+27.5	+7.90	+16.9	+0.0	+0.0000
	+75.2	+0.0	+21.2	+51.7	+2.29	+6.39	+1.629	+11.257
100	+20.0	+21.9	-90.7	+21.9	+6.59	+13.4	+0.0	+0.0000
	+80.0	+0.0	+22.6	+54.9	+2.45	+12.78	+1.471	+10.808
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+32.6	+34.0	-6.3	+34.0	+9.65	+23.0	+0.0	+0.0000
	+67.3	+0.0	+20.4	+45.8	+1.08	+0.00	+0.606	+3.805
50	+24.1	+24.8	-6.5	+24.8	+7.42	+16.7	+0.0	+0.0000
	+75.9	+0.0	+23.1	+51.5	+1.29	+10.53	+0.423	+2.989
100	+15.3	+15.5	-6.7	+15.5	+5.16	+10.1	+0.0	+0.0000
	+84.7	+0.0	+25.8	+57.3	+1.51	+21.07	+0.272	+2.148
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+58.4	+36.2	+58.4	+606.8	+10.06	+25.1	+23.3	+0.0390
	+41.6	+0.0	+13.3	+28.2	+0.15	+0.00	+0.000	+0.030
50	+58.1	+22.1	+58.1	+361.5	+1.62	+13.9	+37.6	+0.1060
	+41.9	+0.0	+13.3	+28.2	+0.43	+15.91	+0.000	+0.000
100	+57.8	+8.1	+57.8	+116.1	+3.11	+2.7	+52.1	+0.4606
	+42.2	+0.0	+13.3	+28.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+82.7	+37.6	+82.7	+636.0	+10.24	+25.3	+47.2	+0.0754
	+17.3	+0.0	+5.7	+11.9	-0.25	+0.00	+0.000	+0.000
50	+82.4	+21.0	+82.4	+345.1	+6.13	+12.0	+64.2	+0.1895
	+17.6	+0.0	+5.7	+11.9	+0.07	+18.87	+0.000	+0.000
100	+54.2	+4.2	+82.1	+54.2	+1.92	+0.0	+52.2	+1.0000
	+17.9	+27.9	+5.7	+11.9	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.89 MMHG								
0	+119.9	+39.0	+119.9	+662.4	+10.48	+24.8	+84.6	+0.1298
	-19.9	+0.0	-6.2	-12.9	-0.78	+0.00	+0.000	+0.000
50	+119.6	+18.2	+119.6	+299.5	+5.33	+8.2	+106.0	+0.3603
	-19.6	+0.0	-6.2	-12.9	-0.40	+23.54	+0.000	+0.000
100	-63.6	-63.6	+119.2	-63.6	+0.00	+0.0	-63.6	+1.0000
	-19.2	+182.8	-6.2	-12.9	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+206.0	+40.4	+206.0	+682.3	+10.99	+21.8	+173.2	+0.2581
	-106.0	+0.0	-34.5	-69.7	-1.85	+0.00	+0.000	+0.000
50	+127.9	+8.5	+205.5	+127.9	+3.05	+0.0	+124.9	+1.0000
	-105.5	+77.6	-34.5	-69.7	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+262.7	+40.9	+262.7	+687.4	+11.31	+19.4	+232.0	+0.3431
	-162.7	+0.0	-53.5	-106.7	-2.52	+0.00	+0.000	+0.000
50	-26.2	-26.2	+262.1	-26.2	+1.06	+0.0	-27.3	+1.0000
	-162.1	+288.3	-53.5	-106.7	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+379.0	+41.8	+379.0	+693.0	+12.00	+14.4	+352.6	+0.5178
	-279.0	+0.0	-93.5	-181.7	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+498.0	+42.6	+498.0	+696.2	+12.71	+9.1	+476.2	+0.6967
	-398.0	+0.0	-135.6	-257.2	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+619.3	+43.4	+619.3	+698.5	+13.47	+3.6	+602.2	+0.8791
	-519.3	+0.0	-179.8	-332.9	-6.57	+0.00	+0.000	+0.000

TABLE A-10 (CONCLUDED)

RH%	LAHET SEHET	LHMIN STORE	LREGD RADHT	LHMAX C0NSK	LHRES C0RES	LHDSK PMMHG	LHWSK CL0SR	WETLR CL0DT
AIR TEMP: +0.00 SKIN: 31.89 C 35.44 MMHG								
0	+21.6	+32.0	-339.4	+32.0	+8.41	+13.2	+0.0	+0.0000
	+78.4	+0.0	+30.2	+44.1	+4.12	+0.00	+3.940	+27.727
50	+20.4	+30.1	-339.4	+30.1	+8.01	+12.4	+0.0	+0.0000
	+79.6	+0.0	+30.6	+44.7	+4.21	+2.29	+3.873	+27.647
100	+19.3	+28.1	-339.5	+28.1	+7.61	+11.7	+6.0	+0.0000
	+80.7	+0.0	+31.1	+45.3	+4.29	+4.58	+3.807	+27.567
AIR TEMP: +15.00 SKIN: 32.11 C 35.88 MMHG								
0	+26.5	+33.1	-143.7	+33.1	+9.20	+17.3	+0.0	+0.0000
	+73.4	+0.0	+31.8	+39.5	+2.14	+0.00	+1.884	+12.730
50	+22.4	+27.5	-143.9	+27.5	+7.90	+14.5	+0.0	+0.0000
	+77.6	+0.0	+33.6	+41.7	+2.29	+6.39	+1.744	+12.434
100	+18.2	+21.9	-144.1	+21.9	+6.59	+11.6	+0.0	+0.0000
	+81.8	+0.0	+35.4	+43.9	+2.45	+12.78	+1.614	+12.131
AIR TEMP: +23.00 SKIN: 32.49 C 36.67 MMHG								
0	+30.7	+34.0	-37.8	+34.0	+9.65	+21.1	+0.0	+0.0000
	+69.3	+0.0	+31.8	+36.4	+1.08	+0.00	+0.782	+5.050
50	+22.9	+24.8	-38.0	+24.8	+7.42	+15.5	+0.0	+0.0000
	+77.1	+0.0	+35.4	+40.4	+1.29	+10.53	+0.625	+4.487
100	+14.6	+15.5	-35.2	+15.5	+5.16	+9.5	+0.0	+0.0000
	+85.4	+0.0	+39.2	+44.7	+1.51	+21.07	+0.490	+3.891
AIR TEMP: +30.00 SKIN: 33.71 C 39.26 MMHG								
0	+45.4	+36.2	+45.4	+606.8	+10.06	+25.7	+9.7	+0.0162
	+54.6	+0.0	+26.3	+28.2	+0.15	+0.00	+0.000	+0.000
50	+45.1	+22.1	+45.1	+361.5	+6.62	+14.5	+24.0	+0.0677
	+54.9	+0.0	+26.3	+28.2	+0.43	+15.91	+0.000	+0.000
100	+44.8	+8.1	+44.8	+116.1	+3.11	+3.3	+38.4	+0.3402
	+55.2	+0.0	+26.3	+28.2	+0.73	+31.83	+0.000	+0.000
AIR TEMP: +33.00 SKIN: 34.56 C 41.17 MMHG								
0	+77.1	+37.6	+77.1	+636.0	+10.24	+25.6	+41.3	+0.0660
	+22.9	+0.0	+11.3	+11.9	-0.25	+0.00	+0.000	+0.000
50	+76.8	+21.0	+76.8	+345.1	+6.13	+12.3	+58.4	+0.1722
	+23.2	+0.0	+11.3	+11.9	+0.07	+18.87	+0.000	+0.000
100	+54.2	+4.2	+76.4	+54.2	+1.92	0.0	+52.2	+1.0000
	+23.6	+22.3	+11.3	+11.9	+0.41	+37.73	+0.000	+0.000
AIR TEMP: +37.00 SKIN: 35.30 C 42.99 MMHG								
0	+126.2	+39.0	+126.2	+662.4	+10.48	+24.5	+91.2	+0.1399
	-26.2	+0.0	-12.5	-12.9	-0.78	+0.00	+0.000	+0.000
50	+125.8	+18.2	+125.8	+299.5	+5.33	+7.9	+112.6	+0.3827
	-25.8	+0.0	-12.5	-12.9	-0.40	+23.54	+0.000	+0.000
100	-63.6	-63.6	+125.4	-63.6	+0.00	+0.0	-63.6	+1.0000
	-25.4	+189.1	-12.5	-12.9	+0.00	+47.08	+0.000	+0.000
AIR TEMP: +45.00 SKIN: 35.83 C 44.17 MMHG								
0	+242.1	+40.4	+242.1	+682.3	+10.99	+20.1	+210.9	+0.3142
	-142.1	+0.0	-70.6	-69.7	-1.85	+0.00	+0.000	+0.000
50	+127.9	+8.5	+241.5	+127.9	+3.05	+0.0	+124.9	+1.0000
	-141.5	+113.6	-70.6	-69.7	-1.32	+35.95	+0.000	+0.000
AIR TEMP: +50.00 SKIN: 35.96 C 44.48 MMHG								
0	+319.9	+40.9	+319.9	+687.4	+11.31	+16.8	+291.8	+0.4316
	-219.9	+0.0	-110.7	-106.7	-2.52	+0.00	+0.000	+0.000
50	-26.2	-26.2	+319.3	-26.2	+1.06	+0.0	-27.3	+1.0000
	-219.3	+345.5	-110.7	-106.7	-1.87	+46.28	+0.000	+0.000
AIR TEMP: +60.00 SKIN: 36.10 C 44.81 MMHG								
0	+483.5	+41.8	+483.5	+693.0	+12.00	+9.6	+461.9	+0.6783
	-383.5	+0.0	-198.0	-181.7	-3.87	+0.00	+0.000	+0.000
AIR TEMP: +70.00 SKIN: 36.16 C 44.97 MMHG								
0	+656.4	+42.6	+656.4	+696.2	+12.71	+1.8	+641.9	+0.9391
	-556.4	+0.0	-294.0	-257.2	-5.21	+0.00	+0.000	+0.000
AIR TEMP: +80.00 SKIN: 36.20 C 45.06 MMHG								
0	+698.5	+43.4	+838.5	+698.5	+13.47	+0.0	+685.0	+1.0000
	-738.5	+140.1	-399.1	-332.9	-6.57	+0.00	+0.000	+0.000

METABOLIC HEAT TRANSFER - PROGRAM LISTING

A-22

TABLE A-11 (CONTINUED)

```

1080 U2=U0+U*Y2/100
1090 T9=U2
1100 G0SUB 2610
1110 G0SUB 2810
1120 W2=W9
1130 U3=(T7+U2)/2
1140 H3=597.4-.568*U3
1150 L3=G*(W2-W)*H3
1160 D3=G*(.2403+.216*(W2+W))*(U2-T)
1170 L7=H2*A1*(P3-P)*760
1180 L8=E1*A1*(P3-P)*760
1190 S3=C3+R3+D3
1200 IF L8 <= L4 THEN 1230
1210 R4=L4/L8
1220 G0T0 1240
1230 R4=1
1240 Z2=M0-L3-L7-R4*(L8-L7)-D3
1250 Z3=C3+R3
1260 IF Z3>Z2 THEN 1610
1310 K2=D5=0
1320 R1=R3
1330 C1=C3
1340 S=S3
1350 L6=M0-S
1360 L5=L6-L3
1370 IF L5>L8 THEN 1420
1380 R5=(L5-L7)/(L8-L7)
1410 G0T0 1440
1420 R5=1
1440 L1=R5*L8-L4
1450 L2=(1-R5)*L7
1460 L=L1+L2+L3+L4
1470 L0=L3+L7+R4*(L8-L7)
1480 L9=L8+L3
1490 X6=L6-L
1500 G0T0 2010
1610 R5=R4
1620 L0=L9+L3+L7+R5*(L8-L7)
1630 L6=M0-S3
1650 N=1
1660 N1=0
1670 N2=4/N
1680 FOR K2=N1 TO N1+4*N2 STEP N2
1690 F2=1+.1*K2
1700 F3=1/(1+.1*K2)
1710 F4=1/F2
1720 L2=F3*(1-R5)*L7
1730 E4=F4*L4
1740 Z5=M0-L3-D3-E4-L2
1750 T2=T3-.18*K2*Z5/A1
1770 B2=(T2+273.15)/100
1780 B0=(T0+273.15)/100
1790 C2=H1+F2*A1*(T2-T)
1800 R2=J1+F2*A2*(B2+4-B0+4)
1810 Z4=C2+R2
1820 IF Z4<Z5 THEN 1840
1830 NEXT K2
1840 IF N2<.0005 THEN 1980
1850 N1=K2-N2
1860 N=2*N
1870 G0T0 1670

```

TABLE A-11 (CONCLUDED)

```

1880 D5=T3-T2
1910 C1=C2
1920 R1=R2
1930 S=C1+R1+D3
1950 L1=0
1960 L=L1+L2+L3+E4
1970 X6=M0-S-L
2010 E5=L1+E4
2020 DEF FNR(Q)=(Q/M0)*100
2030 L=FNR(L)
2040 S=FNR(S)
2050 L0=FNR(L0)
2060 L6=FNR(L6)
2070 L9=FNR(L9)
2080 L3=FNR(L3)
2090 L2=FNR(L2)
2100 E5=FNR(E5)
2110 X6=FNR(X6)
2120 R1=FNR(R1)
2130 C1=FNR(C1)
2140 D3=FNR(D3)
2160 PRINT USING 200,Y2,L,L0,L6,L9,L3,L2,E5,R5
2170 PRINT USING 210,S,X6,R1,C1,D3,760*P,K2,D5
2180 NEXT Y2
2190 GOTO 610
2610 IF T9<0 THEN 2710
2620 Q1=-17.5604
2630 Q2=+1.79764
2640 Q3=+3.86061
2650 Q4=-1.41654
2660 Q6=373.15/(273.15+T9)
2670 Q7=Q6-1
2680 Q8=Q7/Q6
2690 Q9=Q1*Q7+Q2*LOG(Q6)+Q8*(Q3+Q4/Q6)
2700 GOTO 2780
2710 Q1=-20.9422
2720 Q2=-3.57231
2730 Q3=+2.02115
2740 Q6=273.15/(273.15+T9)
2750 Q7=Q6-1
2760 Q8=Q7/Q6
2770 Q9=Q1*Q7+Q2*LOG(Q6)+Q3*Q8-S.11145
2780 P9=EXP(Q9)
2790 RETURN
2810 X9=.62197*P9/(P8-P9)
2820 IF T9<0 THEN 2860
2830 Q0=66-T9
2840 Q5=1+.004*P8+1/(500+Q0+2)
2850 GOTO 2870
2860 Q5=1+(4200-15*T9+.375*T9+2)*.000001*P8
2870 C9=(P8-P9)/(P8/Q5-P9)
2880 W9=C9*X9
2890 RETURN
2900 PRINT
2910 PRINT "      M      M1      M0      L4      T6      P8"
2920 PRINT USING "6(XDDDD.DD)";M,M1,M0,L4,T6,P8
2930 PRINT "      A1      A2      J1      H1      E1      G"
2940 PRINT USING "6(XDDDD.DD)";A1,A2,J1,H1,E1,G
2950 PRINT " T3=34+1.5*ATN[0.1967*(T-31)] U0=28+T/10"
2970 PRINT " V1= ";.00925*H1+2;"M/S ";1.82*H1+2;"FPM"
2980 PRINT " T1=T0-T F2=1+.1*K2 F3=1/(1+.1*K2)"LIN(1)
3000 END

```

Appendix B

TABULATED DATA RELATING TO PARTIAL RECIRCULATION OF AIR

The salient results of the study relating to partial recirculation of ventilating air in shelters during cold weather are shown in graphic form on Figures 7 and 8 in Section III, Shelter Ventilation. Tables B-1 through B-5 represent data used for preparation of Figure 8, as well as some parameters that are not shown graphically. All of these tables relate to a recirculating system during winter operation with a minimal mixture temperature of 50°F (i.e., the temperature of air supplied to occupied spaces is 50°F). The data therefore apply when the fresh or outside air temperature is 50°F or less. Each table is based on a single value of fresh air temperature as indicated on the first tabulated line, along with WSAT, which is the humidity ratio of saturated air at the fresh air temperature. The first column in each table shows the two values for relative humidity of fresh air, $Y_1 = 0$ or 100 percent, used in the computations. In each of the other six columns there are values of two quantities for each value of relative humidity, as indicated by the upper and lower symbols at the head of each column. In column 2, SCFM2 is the total ventilating capacity or mixed air quantity, V_2 , in SCFM per person, and $V_2\text{CFM}$ is the mixed air volume corrected to actual conditions of temperature and humidity. In column 3, SCFM1 is the flow rate of fresh air in SCFM per person, and SCFM4 is the flow rate of recirculated air in SCFM per person. In column 4, T_3 (F) is the dry bulb temperature and DOPT3 is the dew point of air that is either recirculated or exhausted to the atmosphere. In column 5, MAIRW2 is the humidity ratio of mixed air, and RAIRW3 is the humidity ratio of air that is either recirculated or exhausted. In column 6, V_1/V_2 is the ratio of fresh to total air flow quantities. The difference, $W_3 - W_1$, is the increase in humidity ratio of air passing through the system, that is, the increase from outside to exhaust conditions. In column 7, DH/DW is the slope of the mixing process line in the coordinate system of specific enthalpy and humidity ratio. The quantity, LBW/DAY , is the amount of water added to the ventilating air by metabolic processes in pounds per day per person. Data relating to partial recirculation of ventilating air in shelters, as shown in these tables and plotted in Figure 8, were computed with the BASIC program listed in Table B-6.

TABLE B-1

PARTIAL RECIRCULATION OF VENTILATING AIR
 MIXED AIR TEMPERATURE = 50 °F
 FRESH AIR TEMPERATURE = 50 °F

RH1	SCFM2 V2CFM	SCFM1 SCFM4	T3(F) D3PT3	MAIRW2 RAIRW3	V1/V2 W3-W1	DH/DW LBW/DAY
FRESH AIR TEMP = +50.00 F, WSAT = 0.007659						
0	60.00	60.00	+54.58	0.000000	1.000000	4222.0
	57.83	0.00	-14.90	0.000351	0.000351	2.274
100	60.00	60.00	+54.52	0.007659	1.000000	4222.0
	58.54	0.00	+51.18	0.008009	0.000351	2.274
0	40.00	40.00	+56.87	0.000000	1.000000	4222.0
	38.55	0.00	-7.54	0.000526	0.000526	2.274
100	40.00	40.00	+56.78	0.007659	1.000000	4222.0
	39.03	0.00	+51.76	0.008185	0.000526	2.274
0	30.00	30.00	+59.16	0.000000	1.000000	4222.0
	28.91	0.00	-2.17	0.000702	0.000702	2.274
100	30.00	30.00	+59.03	0.007659	1.000000	4222.0
	29.27	0.00	+52.33	0.008360	0.000702	2.274
0	20.00	20.00	+63.73	0.000000	1.000000	4222.0
	19.28	0.00	+5.61	0.001053	0.001053	2.274
100	20.00	20.00	+63.54	0.007659	1.000000	4222.0
	19.51	0.00	+53.44	0.008711	0.001053	2.274
0	15.00	15.00	+68.29	0.000000	1.000000	4222.0
	14.46	0.00	+11.30	0.001404	0.001404	2.274
100	15.00	15.00	+68.04	0.007659	1.000000	4222.0
	14.63	0.00	+54.51	0.009062	0.001404	2.274
0	10.00	10.00	+77.40	0.000000	1.000000	4222.0
	9.64	0.00	+19.55	0.002105	0.002105	2.274
100	10.00	10.00	+77.03	0.007659	1.000000	4222.0
	9.76	0.00	+56.53	0.009754	0.002105	2.274
0	7.00	7.00	+87.58	0.000000	1.000024	3806.6
	6.75	-0.00	+29.24	0.003335	0.003335	2.521
100	7.00	7.00	+87.26	0.007659	1.000020	3856.4
	6.83	-0.70	+59.68	0.010951	0.003292	2.489
0	5.00	5.00	+92.79	0.000000	0.99962	2611.2
	4.82	0.00	+46.91	0.006911	0.006911	3.678
100	5.00	5.00	+92.66	0.007659	0.99996	2651.3
	4.88	0.00	+67.25	0.014364	0.006706	3.621
0	3.00	3.00	+94.86	0.000000	0.99993	1733.0
	2.89	0.00	+72.23	0.017099	0.017099	5.540
100	3.00	3.00	+94.95	0.007659	0.99990	1746.5
	2.93	0.00	+82.91	0.024626	0.016967	5.497
0	2.00	2.00	+95.00	0.000000	1.00024	1457.2
	1.93	-0.00	+99.33	0.030492	0.030492	6.596
100	2.00	V2 T33	L3W, 33DY	HEAT STORAGE		1463.8
100	2.41	2.41	+94.97	0.007659	1.00000	1563.4
	2.35	0.00	+90.01	0.031184	0.023526	6.121

TABLE B-2

PARTIAL RECIRCULATION OF VENTILATING AIR

MIXED AIR TEMPERATURE = 50 °F

FRESH AIR TEMPERATURE = 40 °F

RH1	SCFM2 V2CFM	SCFM1 SCFM4	T3(F) DPT3	M1RW2 RA1RW3	V1/V2 W3-W1	D4/DW LBW/DAY
FRESH AIR TEMP= +40.00 F, WSAT= 0.005213						
0	60.00	18.86	+54.58	0.000765	0.31433	4222.0
	57.90	41.14	+6.76	0.001116	0.001116	2.274
100	60.00	18.74	+54.53	0.005986	0.31231	4222.0
	58.38	41.26	+45.02	0.006337	0.001124	2.274
0	40.00	16.30	+56.86	0.000765	0.40746	4222.0
	38.60	23.70	+9.65	0.001292	0.001292	2.274
100	40.00	16.21	+56.80	0.005986	0.40519	4222.0
	38.92	23.79	+45.73	0.006512	0.001299	2.274
0	30.00	14.35	+59.14	0.000765	0.47332	4222.0
	28.95	15.65	+12.19	0.001467	0.001467	2.274
100	30.00	14.28	+59.06	0.005986	0.47597	4222.0
	29.19	15.72	+46.43	0.006698	0.001474	2.274
0	20.00	11.58	+63.71	0.000765	0.57900	4222.0
	19.70	8.42	+16.53	0.001818	0.001818	2.274
100	20.00	11.53	+63.58	0.005986	0.57670	4222.0
	19.46	8.47	+47.77	0.007039	0.001825	2.274
0	15.00	9.71	+68.27	0.000765	0.64711	4222.0
	14.47	5.29	+20.16	0.002169	0.002169	2.274
100	15.00	9.67	+68.09	0.005986	0.64496	4222.0
	14.60	5.33	+49.06	0.007390	0.002176	2.274
0	10.00	7.33	+77.36	0.000765	0.73338	4222.0
	9.65	2.67	+26.04	0.002871	0.002871	2.274
100	10.00	7.32	+77.11	0.005986	0.73153	4222.0
	9.73	2.68	+51.47	0.008091	0.002878	2.274
0	7.00	5.54	+87.55	0.000876	0.79103	3813.8
	6.76	1.46	+34.62	0.004209	0.004209	2.520
100	7.00	5.53	+87.33	0.006097	0.79013	3848.2
	6.81	1.47	+55.47	0.009390	0.004176	2.497
0	5.00	4.06	+92.76	0.001560	0.81296	2621.0
	4.83	0.94	+52.29	0.008343	0.008343	3.663
100	5.00	4.06	+92.67	0.006759	0.81285	2648.6
	4.87	0.94	+65.44	0.013471	0.008258	3.625
0	3.00	2.47	+94.85	0.003658	0.82340	1739.8
	2.91	0.53	+77.75	0.020683	0.020683	5.516
100	3.00	V2 T00 L0W, F0G IN MIXED AIR				1748.8
100	3.86	3.16	+94.30	0.007659	0.81949	2075.0
	3.77	0.70	+74.90	0.018762	0.013548	4.628
0	2.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1462.6
0	2.26	1.87	+94.98	0.005420	0.82616	1526.3
	2.20	0.39	+90.01	0.031179	0.031179	6.289
100	2.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1467.3
100	2.57	V2 T00 L0W, F0G IN MIXED AIR				1615.8
100	3.86	3.16	+94.30	0.007659	0.81949	2075.0
	3.77	0.70	+74.90	0.018762	0.013548	4.628

TABLE 8-3

PARTIAL RECIRCULATION OF VENTILATING AIR
 MIXED AIR TEMPERATURE = 50 °F
 FRESH AIR TEMPERATURE = 20 °F

RH1	SCFM2 V2CFM	SCFM1 SCFM4	T3(F) DPT3	MAIRW2 RAIRW3	V1/V2 W3-W1	DH/DW LBW/DAY
FRESH AIR TEMP= +20.00 F, WSAT= 0.002152						
0	60.00	7.95	+54.56	0.002296	0.13256	4222.0
	58.04	52.05	+24.33	0.002647	0.002647	2.274
100	60.00	7.93	+54.54	0.004457	0.13211	4222.0
	58.24	52.07	+37.95	0.004808	0.002656	2.274
0	40.00	7.46	+56.84	0.002296	0.18647	4222.0
	38.69	32.54	+25.69	0.002823	0.002823	2.274
100	40.00	7.44	+56.81	0.004457	0.18588	4222.0
	38.83	32.56	+38.86	0.004993	0.002832	2.274
0	30.00	7.02	+59.12	0.002296	0.23408	4222.0
	29.02	22.98	+26.97	0.002998	0.002998	2.274
100	30.00	7.00	+59.08	0.004457	0.23338	4222.0
	29.12	23.00	+39.73	0.005159	0.003007	2.274
0	20.00	6.29	+63.67	0.002296	0.31433	4222.0
	19.35	13.71	+29.34	0.003349	0.003349	2.274
100	20.00	6.27	+63.62	0.004457	0.31349	4222.0
	19.41	13.73	+41.41	0.005510	0.003358	2.274
0	15.00	5.69	+68.22	0.002296	0.37936	4222.0
	14.51	9.31	+31.49	0.003700	0.003700	2.274
100	15.00	5.68	+68.14	0.004457	0.37844	4222.0
	14.56	9.32	+43.00	0.005861	0.003709	2.274
0	10.00	4.78	+77.29	0.002296	0.47832	4222.0
	9.67	5.22	+35.73	0.004402	0.004402	2.274
100	10.00	4.77	+77.18	0.004457	0.47734	4222.0
	9.71	5.23	+45.94	0.006563	0.004411	2.274
0	7.00	3.91	+87.48	0.002619	0.55829	3828.1
	6.77	3.09	+43.36	0.005942	0.005942	2.512
100	7.00	3.90	+87.38	0.004766	0.55782	3843.4
	6.80	3.10	+51.41	0.008075	0.005923	2.501
0	5.00	2.96	+92.71	0.004630	0.59271	2638.0
	4.85	2.04	+60.71	0.011370	0.011370	3.640
100	5.00	2.96	+92.67	0.006767	0.59246	2649.0
	4.97	2.04	+65.45	0.013479	0.011327	3.625
0	3.00	V2 T03	L0W, F0G	IN MIXED AIR		1752.5
0	3.74	2.26	+94.41	0.007659	0.60514	2024.2
	3.65	1.48	+75.87	0.019396	0.019396	4.743
100	3.00	V2 T03	L0W, F0G	IN MIXED AIR		1756.1
100	4.54	2.71	+93.46	0.007659	0.59747	2397.1
	4.43	1.83	+70.01	0.015830	0.013678	4.004
0	2.00	V2 T03	L0W, B0DY HEAT ST0RAGE			1472.9
0	2.77	V2 T03	L0W, F0G	IN MIXED AIR		1679.8
0	3.74	2.26	+94.41	0.007659	0.60514	2024.2
	3.65	1.48	+75.87	0.019396	0.019396	4.743
100	2.00	V2 T03	L0W, B0DY HEAT ST0RAGE			1475.0
100	2.90	V2 T03	L0W, F0G	IN MIXED AIR		1724.7
100	4.54	2.71	+93.46	0.007659	0.59747	2397.1
	4.43	1.83	+70.01	0.015830	0.013678	4.004

TABLE B-4

PARTIAL RECIRCULATION OF VENTILATING AIR
 MIXED AIR TEMPERATURE = 50 °F
 FRESH AIR TEMPERATURE = 0 °F

RH1	SCFM2 V2CFM	SCFM1 SCFM4	T3(F) D3PT3	MAIRW2 RAIRW3	V1/V2 W3-W1	DH/DV LEW/DAY
FRESH AIR 1.41P= +0.00 F, WSAT= 0.000787						
0	60.00	5.04	+54.55	0.003827	0.08399	4222.0
	58.18	54.96	+34.42	0.004178	0.004178	2.274
100	60.00	5.03	+54.54	0.004620	0.08388	4222.0
	58.26	54.97	+39.79	0.004971	0.004183	2.274
0	40.00	4.84	+56.82	0.003827	0.12090	4222.0
	38.79	35.16	+35.45	0.004353	0.004353	2.274
100	40.00	4.83	+56.81	0.004620	0.12075	4222.0
	38.84	35.17	+39.67	0.005146	0.004359	2.274
0	20.00	4.65	+59.09	0.003827	0.15496	4222.0
	29.09	25.35	+36.44	0.004529	0.004529	2.274
100	30.00	4.64	+59.08	0.004620	0.15477	4222.0
	29.13	25.36	+40.53	0.005321	0.004534	2.274
0	20.00	4.31	+63.63	0.003827	0.21572	4222.0
	19.39	15.69	+38.32	0.004880	0.004880	2.274
100	20.00	4.31	+63.61	0.004620	0.21543	4222.0
	19.42	15.69	+42.16	0.005672	0.004885	2.274
0	15.00	4.03	+68.16	0.003827	0.26934	4222.0
	14.55	10.97	+40.09	0.005231	0.005231	2.274
100	15.00	4.02	+68.14	0.004620	0.26805	4222.0
	14.56	10.98	+43.71	0.006023	0.005236	2.274
0	10.00	3.55	+77.21	0.003827	0.35489	4222.0
	9.70	6.45	+43.32	0.005932	0.005932	2.274
100	10.00	3.55	+77.17	0.004620	0.35456	4222.0
	9.71	6.45	+46.58	0.006725	0.005938	2.274
0	7.00	3.02	+87.41	0.004349	0.43157	3840.2
	6.79	3.98	+50.01	0.007662	0.007662	2.504
100	7.00	3.02	+87.38	0.005136	0.43125	3844.2
	6.80	3.99	+52.62	0.008447	0.007660	2.50
0	5.00	2.33	+92.66	0.007648	0.46692	2652.6
	4.88	2.67	+67.23	0.014354	0.014354	3.621
100	5.00	V2 T00 L0W, F0G IN MIXED AIR				2656.3
100	5.31	2.45	+92.02	0.007659	0.46242	2833.8
	5.18	2.85	+65.64	0.013572	0.012785	3.389
0	3.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1764.5
0	3.20	V2 T00 L0W, F0G IN MIXED AIR				1832.6
0	5.00	2.33	+92.66	0.007659	0.46680	2651.6
	4.88	2.67	+67.25	0.014364	0.014364	3.621
100	3.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1766.2
100	3.25	V2 T00 L0W, F0G IN MIXED AIR				1852.3
100	5.31	2.45	+92.02	0.007659	0.46242	2833.8
	5.18	2.85	+65.64	0.013572	0.012785	3.389
0	2.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1483.2
0	3.20	V2 T00 L0W, F0G IN MIXED AIR				1832.6
0	5.00	2.33	+92.66	0.007659	0.46680	2651.6
	4.88	2.67	+67.25	0.014364	0.014364	3.621
100	2.00	V2 T00 L0W, B0DY HEAT ST0RAGE				1483.8
100	3.25	V2 T00 L0W, F0G IN MIXED AIR				1852.3
100	5.31	2.45	+92.02	0.007659	0.46242	2833.8
	5.18	2.85	+65.64	0.013572	0.012785	3.389

TABLE B-5

PARTIAL RECIRCULATION OF VENTILATING AIR

MIXED AIR TEMPERATURE = 50 °F

FRESH AIR TEMPERATURE = -20 °F

RH1	SCFM2 V2CFM	SCFM1 SCFM4	T3(F) D8PT3	MAIRW2 RAIRW3	V1/V2 W3-W1	LW/DW LBW/DAY
FRESH AIR TEMP= -20.00 F, WSAT= 0.000263						
0	60.00	3.69	+54.54	0.005358	0.06147	4222.0
	58.33	56.31	+42.31	0.005709	0.005709	2.274
100	60.00	3.69	+54.54	0.005623	0.06144	4222.0
	58.35	56.31	+43.50	0.005974	0.005711	2.274
0	40.00	3.58	+56.80	0.005358	0.08945	4222.0
	38.88	36.42	+43.11	0.005884	0.005884	2.274
100	40.00	3.58	+56.80	0.005623	0.08941	4222.0
	38.90	36.42	+44.25	0.006150	0.005887	2.274
0	30.00	3.47	+59.07	0.005358	0.11581	4222.0
	29.16	26.53	+43.87	0.006060	0.006060	2.274
100	30.00	3.47	+59.06	0.005623	0.11576	4222.0
	29.18	26.53	+44.98	0.006325	0.006062	2.274
0	20.00	3.28	+63.59	0.005358	0.16421	4222.0
	19.44	16.72	+45.33	0.006411	0.006411	2.274
100	20.00	3.28	+63.59	0.005623	0.16414	4222.0
	19.45	16.72	+46.39	0.006676	0.006413	2.274
0	15.00	3.11	+68.12	0.005358	0.20758	4222.0
	14.58	11.89	+46.72	0.006762	0.006762	2.274
100	15.00	3.11	+68.11	0.005623	0.20751	4222.0
	14.59	11.89	+47.73	0.007027	0.006764	2.274
0	10.00	2.82	+77.14	0.005358	0.28210	4222.0
	9.72	7.18	+49.32	0.007463	0.007463	2.274
100	10.00	2.82	+77.13	0.005623	0.28200	4222.0
	9.73	7.18	+50.25	0.007729	0.007466	2.274
0	7.00	2.46	+87.33	0.006066	0.35188	3851.8
	6.81	4.54	+55.41	0.009369	0.009369	2.497
100	7.00	2.46	+87.33	0.006332	0.35171	3851.9
	6.82	4.54	+56.17	0.009636	0.009373	2.493
0	5.00	V2 T00	L0W, F0G	IN MIXED AIR		2667.3
	6.02	2.23	+90.26	0.007659	0.37035	3279.1
	5.87	3.79	+62.59	0.012168	0.012168	2.931
100	5.00	V2 T00	L0W, F0G	IN MIXED AIR		2671.7
100	6.15	2.26	+89.90	0.007659	0.36789	3358.3
	6.00	3.89	+62.11	0.011962	0.011699	2.358
0	3.00	V2 T00	L0W, B0DY	HEAT STORAGE		1776.9
	3.57	V2 T00	L0W, F0G	IN MIXED AIR		1984.6
0	6.02	2.23	+90.26	0.007659	0.37035	3279.1
	5.87	3.79	+62.59	0.012168	0.012168	2.931
100	3.00	V2 T00	L0W, B0DY	HEAT STORAGE		1777.2
100	3.59	V2 T00	L0W, F0G	IN MIXED AIR		1992.4
100	6.15	2.26	+89.90	0.007659	0.36789	3358.3
	6.00	3.89	+62.11	0.011962	0.011699	2.358
0	2.00	V2 T00	L0W, B0DY	HEAT STORAGE		1493.2
	3.57	V2 T00	L0W, F0G	IN MIXED AIR		1984.6
0	6.02	2.23	+90.26	0.007659	0.37035	3279.1
	5.87	3.79	+62.59	0.012168	0.012168	2.931
100	2.00	V2 T00	L0W, B0DY	HEAT STORAGE		1493.2
100	3.59	V2 T00	L0W, F0G	IN MIXED AIR		1992.4
100	6.15	2.26	+89.90	0.007659	0.36789	3358.3
	6.00	3.89	+62.11	0.011962	0.011699	2.358

TABLE B-6

RECIRCULATION OF AIR - PROGRAM LISTING

```

100 REM: > RAVENS < 4/72
110 PRINT USING "4(DD)";TIM(3),TIM(2),TIM(1),TIM(C)
120 DIM AS(48),CS(60),DS(60),ES(50)
130 AS=" PARTIAL RECIRCULATION OF AIR"
140 CS=" RH1 SCFM2 SCFM1 T3(F) MAIRW2 V1/V2 DH/DW"
150 DS=" V2CFM SCFM4 D3PT3 RAIRW3 W3-W1 LBW/DAY"
160 IMAGE 16X,"MIXED AIR TEMP =",3D," F"
170 IMAGE " FRESH AIR TEMP=",S3D.DD," F, WSAT= ",D.6D
180 IMAGE X3D,X3D.DD,X3D.DD,XXS3D.DD,XXD.6D,XXD.5D,XX5D.D
190 IMAGE 5X3D.DD,X3D.DD,XXS3D.DD,XXD.6D,XXD.6D,XXDD.3D
200 IMAGE X3D,X3D.DD,XX,2A,10A,21A,XX5D.D
210 PB=1
220 C=.24026
230 A1=1061.09
240 A2=1061.25
250 B1=.4412
260 B2=.4362
270 B3=.5503
280 T0=82.5
290 S0=4222
300 W0=400
310 DATA 20
320 DATA 60,40,30,20,15,10,7,5,3,2
350 T2=50
360 T7=90
370 C0=C*T0
380 G0=A2+B2*T0
390 C2=C*T2
400 G2=A2+B2*T2
410 T9=(T2-32)/1.8
420 G2SUB 2610
430 G2SUB 2810
440 S2=W9
450 T9=(T7-32)/1.8
460 G2SUB 2610
470 G2SUB 2810
480 L3=W9
490 DATA 890,890
500 D=D0=D1=.01
510 ES="T1V2 T30 LBW, FOG IN MIXED AIRBODY HEAT STORAGE"
520 PRINT ".":LIN(2);AS
530 PRINT USING 160;T2
540 PRINT LIN(1);CS;LIN(1);DS
550 PRINT
560 READ T1
570 IF T1>T2 THEN 1210
580 C1=C*T1
590 IF T1<T2 THEN 620
600 G1=A2+B2*T1
610 G2T3 630
620 G1=A1+B1*T1
630 T9=(T1-32)/1.8
640 G2SUB 2610
650 G2SUB 2810
660 S1=W9
670 PRINT USING 170;T1,S1
680 READ V2
690 IF V2>404 THEN 2910
700 IF V2>303 THEN 520
710 IF V2>202 THEN 550

```

TABLE B-6 (CONTINUED)

```

720 D5=M0/(4.5*V2)
730 Y1=0
740 G3T3 760
750 Y1=100
760 W1=S1*Y1/100
770 H1=C1+G1*W1
780 W2=(W1*(S0-G1)+C2-C1)/(S0-G2)
790 IF W2>(S2+.00001) THEN 1190
800 H2=C2+G2*W2
810 W0=(W2*(S0-G2)+C0-C2)/(S0-G0)
820 H0=C0+G0*W0
830 V0=M0/(4.5*(H0-H2))
840 V=V1=1
850 IF V0>V2 THEN 910
860 H3=H2+D5
870 W3=W2+D5/S0
880 T3=(H3-A2*W3)/(C+B2*W3)
890 S=S0
900 G3T3 1000
910 H2=C2+G2*W2
920 L3=H2+D5
930 G3SUB 1510
940 IF V>3 THEN 1000
950 S=(H3-H1)/(W3-W1)
960 X2=(W1*(S-G1)+C2-C1)/(S-G2)
970 IF ABS(X2-W2)<(D1/1000) THEN 1000
980 W2=X2
990 G3T3 910
1000 V5=V2
1010 IF W3>L3 THEN 1410
1020 IF W2>(S2+.00001) AND T1<T2 THEN 1310
1040 T=459.67+T2
1050 U2=.001891*V5*T*(1+1.6079*W2)/PR
1060 D4=H3-H1
1070 V1=M0/(4.5*D4)
1080 R=V1/V5
1090 V4=V5-V1
1100 G3SUB 2260
1110 M3=4.5*V5*(W3-W2)
1120 PRINT USING 180;Y1,V5,V1,T3,W2,R,S
1130 PRINT USING 190;U2,V4,T5,W3,W3-W1,24*M3
1140 G3T3 1240
1190 PRINT USING 200;Y1,-11.11,ESC(1,2),ESC(5,14),ESC(15,30),S0
1200 IF Y1>59.9 THEN 1250
1210 READ V2
1220 IF V2<202 THEN 1210
1230 G3T3 690
1240 IF Y1<49.9 THEN 750
1250 G3T3 680
1310 V=3
1320 PRINT USING 200;Y1,V5,ESC(3,41),ESC(5,14),ESC(15,30),S
1330 W2=S2
1340 H2=C2+G2*W2
1350 S=(H2-H1)/(W2-W1)
1360 G3SUB 1510
1380 G3T3 1040
1410 V=2
1420 PRINT USING 200;Y1,V2,ESC(3,41),ESC(5,14),ESC(31),S
1430 V2=91
1440 G3SUB 1520
1460 G3T3 1020

```

TABLE B-6 (CONTINUED)

```

1510 V2=T0
1520 V4=95
1530 D1=D0
1540 V1=0
1550 T3=(V2+V4)/2
1560 V1=V1+1
1570 C3=C*T3
1580 G3=A2+B2*T3
1590 G3T0 V 3F 1660,1630,1600
1600 X3=(W1*(S-G1)+C3-C1)/(S-G3)
1610 L3=C3+G3*X3
1620 G3T0 1660
1630 L3=C3+G3*L3
1640 S=(L3-H1)/(L3-W1)
1650 W2=(W1*(S-G1)+C2-C1)/(S-G2)
1660 IF V1>15 THEN 1790
1670 W0=(W2*(S0-G2)+C0-C2)/(S0-G0)
1680 R1=(95-T0)/(95-T3)
1690 R2=(2305.2+T0)/(2305.2+T3)
1700 F2=R2*(R1/R2)+.006944
1710 W3=F2*(R3+W0)-R3
1720 H3=C3+G3*W3
1730 IF ABS(H3-L3)<.01 THEN 1850
1740 IF H3>L3 THEN 1770
1750 V2=T3
1760 G3T0 1550
1770 V4=T3
1780 G3T0 1550
1790 IF D1>.011 THEN 1860
1800 D1=2*D1
1810 IF D1>D THEN 1830
1820 G3T0 1840
1830 D=D1
1840 G3T0 1540
1850 G3T0 V 3F 1940,1920,1930
1860 G3T0 V 3F 1950,1900,1870
1870 W3=X3
1880 H3=L3
1890 G3T0 1930
1900 W3=L3
1910 H3=L3
1920 H2=C2+G2*W2
1930 V5=V0/(4.5*(H3-H2))
1940 RETURN
1950 Z3=G3-G2
1960 Z4=C3-H1
1970 Z5=D5-C3+C2
1980 Z2=Z3*G3
1990 Z1=(G2*D5+Z3*Z4-Z5*G3)/Z2
2000 Z0=(G2*D5*W1+Z4*Z5)/Z2
2010 W3=(SOR(Z1+2+4*Z0)-Z1)/2
2020 H3=C3+G3*W3
2030 S=(H3-H1)/(W3-W1)
2040 W2=(W1*(S-G1)+C2-C1)/(S-G2)
2050 N=4
2060 RETURN
2260 W9=W3
2270 G3SUB 2510
2280 P3=P9

```

TABLE B-6 (CONCLUDED)

```

2290 T9=0
2300 GOSUB 2610
2310 IF P9>P3 THEN 2340
2320 J1=J=1
2330 GOTO 2350
2340 J1=J=-1
2350 J2=0
2360 J3=32/J1
2370 FOR T9=J2 TO J2+3*J3 STEP J3
2380 GOSUB 2610
2390 J6=J*(P9-P3)
2400 IF J6=0 THEN 2470
2410 IF J6>0 THEN 2430
2420 NEXT T9
2430 IF ABS(J3)<.005 THEN 2470
2440 J2=T9-J3
2450 J1=2*J1
2460 GOTO 2360
2470 T5=32+1.8*T9
2480 RETURN
2510 F9=P8*W9/(.62197+W9)
2520 IF T9<0 THEN 2560
2530 Q0=66-T9
2540 Q5=1+.004*P8+1/(500+Q0+2)
2550 GOTO 2570
2560 Q5=1+(4200-15*T9+.375*T9+2)*.000001*P8
2570 P9=F9/Q5
2580 RETURN
2610 IF T9<0 THEN 2710
2620 Q1=-17.5604
2630 Q2=+1.79764
2640 Q3=+3.86061
2650 Q4=-1.41654
2660 Q6=373.15/(273.15-T9)
2670 Q7=Q6-1
2680 Q8=Q7/Q6
2690 Q9=Q1*Q7+Q2*LOG(Q6)+Q3*(Q3+Q4/Q6)
2700 GOTO 2780
2710 Q1=-20.9422
2720 Q2=-3.57281
2730 Q3=+2.02115
2740 Q6=273.15/(273.15-T9)
2750 Q7=Q6-1
2760 Q8=Q7/Q6
2770 Q9=Q1*Q7+Q2*LOG(Q6)+Q3*Q8-5.11145
2780 P9=EXP(Q9)
2790 RETURN
2810 X9=.62197*P9/(P8-P9)
2820 IF T9<0 THEN 2860
2830 Q0=66-T9
2840 Q5=1+.004*P8+1/(500+Q0+2)
2850 GOTO 2870
2860 Q5=1+(4200-15*T9+.375*T9+2)*.000001*P8
2870 C9=(P8-P9)/(P8/Q5-P9)
2880 W9=C9*X9
2890 RETURN
2910 PRINT
2940 PRINT " LHR=.25 (T<82.5F<T) LHR=.06*T-4.7"
2980 PRINT USING "2(3D),3X,4D,2(4D.0D)";TIM(1),TIM(0),X0,D1,D
3000 END

```